



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Flat Roof Repair & HVAC Replacement	
Solicitation No. - N° de l'invitation EZ899-210438/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client	Date 2020-08-06
GETS Reference No. - N° de référence de SEAG PW-SPWY-028-8803	
File No. - N° de dossier PWY-0-43032 (028)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2020-08-21	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lam (PWY), Tian	Buyer Id - Id de l'acheteur pwy028
Telephone No. - N° de téléphone (604) 363-7968 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: CSC - Chilliwack Correctional Centre - Chilliwack, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ899-210438/A

Amd. No. - N° de la modif.
001

Buyer ID - Id de l'acheteur
pwy028

Client Ref. No. - N° de réf. du client

File No. - N° du dossier CCC No./N°

CCC - FMS No./N° VME

Les documents seront disponibles en français sur demande.

The Solicitation Amendment 001 is raised to issue Addendum 002.

Please see Addendum 002 herein.

All other terms and conditions remain unchanged.

This addendum varies the Contract Documents and will form part of the Contract Documents and is to be read, interpreted and coordinated with all other parts, including General and Supplementary General Conditions of the Contract and all Sections in Division 1. The cost of all work contained herein is to be included in the Contract Sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above named project to the extent referenced and shall become a part thereof.

GENERAL

This addendum is issued prior to receipt of Bids to provide for certain revisions to and clarification to the Contract Documents.

The work required by this Addendum shall be executed in accordance with the requirements of the Contract and Contract Documents.

Include in the Stipulated Price, the cost of all work described in this Addendum.

ITEM 1: Reference Specifications 23 09 01, Section 1.2 Scope of Work

CLARIFICATIONS:

The existing HVAC Controls are Delta Controls products supplied by ESC Automation.

The existing supplemental screen was installed to allow technicians of any company to view the graphics and the live system data to help with the diagnostics of the equipment.



Photo: Existing HVAC control panel and screen in Mechanical Room.

ITEM 2: Reference Specifications 07 52 00, Section 2.3 Membrane

CLARIFICATIONS:

In response to Tender RFI-1 (dated July 28, 2020):

The "cold-applied" membrane cap sheet application method may be utilized as an approved equal to the "torch-applied" application method.

ITEM 3: Reference Specifications and Drawings

- **232123 Hydronic Pumps**
- **233400 HVAC Fans,**
- **237400 Packaged Outdoor HVAC Equipment,**
- **238200 Heating Coils**
- **Drawing M500 Circulation Pump Schedule, Fan Schedule, Heating Coil Schedule**

CHANGES:

In response to the Request for Equal (dated July 30, 2020):

The following manufacturers shall be added as Acceptable Materials

- Fan F-9 only: Accurex
- Heating Coils: Direct Coil

END OF ADDENDUM NO.2