



**RETURN BIDS TO:  
RETOURNER LES SUBMISSION À :**

Parks Canada Agency Bid Receiving Unit  
National Contracting Services

**Bid Fax:** 1-866-246-6893

**Bid Email:** [soumissionsouest-bidswest@canada.ca](mailto:soumissionsouest-bidswest@canada.ca)

This is the only acceptable email address for responses to bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address may not be accepted.

The maximum email file size is 25 megabytes. PCA is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

**REVISION 001 TO A  
INVITATION TO TENDER**

**RÉVISION 001 À UNE  
INVITATION À SOUMISSIONNER  
DEMANDE D'OFFRES À  
COMMANDES**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Offer remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'offre demeurent les mêmes.

**Issuing Office - Bureau de distribution :**  
Parks Canada Agency  
Calgary, AB

<b>Title - Sujet :</b> Staff Housing Remediation – Waterton Lakes National Park	
<b>Solicitation No. - N° de l'invitation :</b> 5P420-20-0139/A	<b>Date :</b> August 11, 2020
<b>Amendment No. - N° de modification :</b> 001	
<b>Client Reference No. - N° de référence du client :</b> 945	
<b>GETS Reference No.   N° de référence de SEAG :</b> PW-20-00921933	

<b>Solicitation Closes - L'invitation prend fin :</b> <b>At - à :</b> 2:00 PM <b>On - le :</b> August 13, 2020	<b>Time Zone - Fuseau horaire</b> MDT - HAR
----------------------------------------------------------------------------------------------------------------------	------------------------------------------------

<b>F.O.B. - F.A.B. :</b> <b>Plant - Usine :</b> <input type="checkbox"/> <b>Destination :</b> <input checked="" type="checkbox"/> <b>Other - Autre :</b> <input type="checkbox"/>		
<b>Address Enquiries to - Adresser toutes demande de renseignements à :</b> Rebecca Chen		
<b>Telephone No. - N° de telephone :</b> (587) 439-3529	<b>Fax No. -N° de télécopieur :</b> (866) 246-6893	<b>Email Address – Courriel :</b> <a href="mailto:rebecca.chen2@canada.ca">rebecca.chen2@canada.ca</a>
<b>Destination of Goods, Services, and Construction - Destination des biens, services, et construction :</b> Waterton Lakes National Park See Herein – Voir ici		

**TO BE COMPLETED BY THE BIDDER - À REMPLIR PAR LE SOUMISSIONNAIRE**

<b>Vendor/ Firm Name - Nom du fournisseur/ de l'entrepreneur :</b>	
<b>Address - Adresse :</b>	
<b>Telephone No. - N° de telephone :</b>	<b>Fax No. - N° de télécopieur :</b>
<b>Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur</b>	
<b>Signature :</b>	<b>Date :</b>

## Amendment 001

This amendment is being raised to distribute site visit information, questions and answers, and to make changes to the tender package.

### A. Optional Site Visit Attendees

Vendor	Representative's Name
Sunny South Insulators	Chris Beatine
Amron Construction	Sharon McNabb
J A Building Services	Deanna Henderson
Nitro Construction Ltd.	Ben Ginliker
Premiere Builders	Henry Dekok

### B. Question and Answer

**Q1** What are the hours of work permitted?

**A1** 7am to 8pm weekdays and 8am to 8pm Saturday, Sunday and Statutory holidays.

**Q2** Is October 31, 2020 completion date firm?

**A2** Yes

**Q3** What is the average depth of blown in cellulous insulation?

**A3** The existing blown in insulation varies in depth but an approximate average of 250mm

**Q4** What if the spec shingle is not available?

**A4** The work to match the existing shingling has been removed. The contractor is to remove and re-shingle the entire roof as per the specification revisions below.

**Q5** Do we have to completely rebuild shaft A. and C./D. from loft ceiling level to underside of roof sheathing?

**A5** Refer to Existing Shaft note: on Drawing A01.

**Q6** Can you post photos of typical attic spaces?

**A6** Yes: See photos below a. and b. for upper roof spaces 1&2 typical.

See photos c. and d. for lower vented roof spaces 1&2 typical.

See photo of existing eave space

**A:**



**B:**



**C:**



**D:**



### Existing Eave Space:



### C. Tender Package Revisions

**IN:** Drawings A02, Notes

**DELETE:**

~~Replacement fibreglass reinforced asphalt shingles to match existing (Cambridge or impact resistant – colour: driftwood or equivalent).~~ Replacement roof shingles to be acceptable for use in high wind conditions exceeding 200kph and shingle installation to allow for high wind conditions exceeding 200kph. refer to sheet a01 - loft floor plan & roof plan for approximate extent. ~~Bidding contractor to confirm availability. If the product is not available,~~ roof shingles to be replaced in its entirety to similar product. replacement product is subject to approval by the client and architect.

**REPLACE WITH:**

Replacement roof shingles to be acceptable for use in high wind conditions exceeding 200kph and shingle installation to allow for high wind conditions exceeding 200kph. refer to sheet a01 - loft floor plan & roof plan for approximate extent. Roof shingles to be replaced in its entirety to similar product. replacement product is subject to approval by the client and architect as per specification section 07 31 13

**ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED**