



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
1713 Bedford Row
Halifax, N.S./Halifax, (N.É.)
Halifax
Nova Scotia
B3J 1T3
Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions
1713 Bedford Row
Halifax, N.S./Halifax, (N.É.)
Halifax
Nova Scot
B3J 1T3

Title - Sujet Sea Containers	
Solicitation No. - N° de l'invitation W355B-207222/B	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client W355B-20-7222	Date 2020-08-12
GETS Reference No. - N° de référence de SEAG PW-SHAL-406-11023	
File No. - N° de dossier HAL-9-83081 (406)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2020-08-27	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Matheson, Valerie	Buyer Id - Id de l'acheteur hal406
Telephone No. - N° de téléphone (902) 403-6236 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Amendment 001 is issued to respond to questions and to extend the closing date

Delete: **Solicitation Closes at 02:00 PM on 2020-08-18**

Insert: **Solicitation Closes at 02:00 PM on 2020-08-27**

Q1: 4.1.1 Technical Evaluation
MANDATORY requirement at Solicitation closing date:

1. Bidder must provide proposed design drawings with all the required specifications for each container for evaluation purposes.

Do you have any information on the equipment going inside the containers?

A1: See copy of proposed layout for each container.

Q2: Page 19 of 24, Certification section Item 2 requires CSC plate provided with each container. Can you please confirm if re-certification to CSC required after modifications as per Annex A 1. b. and 2. b.?

A2: Both containers must pass all testing and certifications after modifications are complete.

Q3: Regarding Annex A 1. n. from vi to xi (inclusive); can you clarify if all circuits are to have receptacles (all t-slot?) or are some circuits hardwired?

A3: All 20 amp, 120 volt circuits are to have receptacles installed. The larger current and or 3 phase circuits can be capped in 4X4 square boxes or similar suitability sized boxes to allow the equipment to be connected after we receive the containers.


Q4: Regarding Annex A 1. n. xiv.; can you confirm if umbilical connectors are required for both containers, meaning the SOOW cable will be plugged to both containers, not hardwired to one of them? Do you have a preference for what type of connectors?

A4: Umbilical cord must plug in on both ends with suitable CSA approved male and female receptacles.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME



NATIONAL DEFENCE
DÉFENSE NATIONALE



PROJECT: SHIPPING CONTAINER LAYOUT

TITLE:

DESIGNED:

DRAWN: SPM

APPROVED:

SCALE: 1:50

DATE: 14/02/2019

DWG. NO.