



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Public Works and Government Services Canada  
Canada Place/Place du Canada  
10th Floor/10e étage  
9700 Jasper Ave/9700 ave Jasper  
Edmonton  
Alberta  
T5J 4C3  
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada  
Canada Place / Place du Canada  
10th Floor / 10e étage  
9700 Jasper Ave / 9700 ave Jasper  
Edmonton  
Alberta  
T5J 4C3

<b>Title - Sujet</b> Detached Garage	
<b>Solicitation No. - N° de l'invitation</b> ET858-210542/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b> PSPC ET858-210542	<b>Date</b> 2020-08-13
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWU-005-11869	
<b>File No. - N° de dossier</b> PWU-0-43036 (005)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2020-08-18</b>	<b>Time Zone Fuseau horaire Mountain Daylight Saving Time MDT</b>
<b>F.O.B. - F.A.B.</b>	
<b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Virakorn, Matthew	<b>Buyer Id - Id de l'acheteur</b> pwu005
<b>Telephone No. - N° de téléphone</b> (780) 278-6153 ( )	<b>FAX No. - N° de FAX</b> (780) 497-3510
<b>Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
ET858-210542/A  
Client Ref. No. - N° de réf. du client  
PSPC ET858-210542

Amd. No. - N° de la modif.  
002  
File No. - N° du dossier  
PWU-0-43036

Buyer ID - Id de l'acheteur  
pwu005  
CCC No./N° CCC - FMS No./N° VME

---

Amendment 002 has been raised to make the following changes:

**\*\* IMPORTANT UPDATE\*\* Effective April 16, 2020:**

Due to the impacts of the COVID-19 pandemic and to encourage physical distancing, the bid receiving unit in Edmonton will remain open but with limited staff and limited hours: Monday, Wednesday, Thursday and Friday, 9 am to 11 am and Tuesday, 9 am to 2 pm (local time).

Public tender openings will be suspended until further notice. Following solicitation closing, bid results will be recorded and may be obtained by e-mailing a request to the address indicated in the Invitation to Tender.

Please monitor Buyandsell.gc.ca closely as changes to bid closing dates may be necessary.

**\*\*IMPORTANT UPDATE\*\* New process for hand-delivered bids, Edmonton Office, Canada Place - Effective March 11, 2020**

Suppliers must be escorted by PSPC staff to access the Canada Place Bid Receiving Unit. Suppliers will not be issued a visitor's pass as previously communicated.

A courtesy phone will be available at the Commissionaire/Information desk in the main lobby. The courtesy phone will be preprogrammed with a direct line to PSPC reception.

A PSPC staff member will meet suppliers at the Commissionaire/Information desk and escort them to the Bid Receiving Unit within the building's secured space.

Please ensure adequate time is allotted to deliver a bid to account for this new security procedure.

It is the responsibility of suppliers to ensure that the bid, offer or arrangement, as applicable, is delivered on time to the Bid Receiving Unit.

Solicitation No. - N° de l'invitation  
ET858-210542/A  
Client Ref. No. - N° de réf. du client  
PSPC ET858-210542

Amd. No. - N° de la modif.  
002  
File No. - N° du dossier  
PWU-0-43036

Buyer ID - Id de l'acheteur  
pwu005  
CCC No./N° CCC - FMS No./N° VME

---

Addendum #001:

The following changes to the tender documents are effective immediately and will form part of the contract documents:

### **Questions & Answers**

1. There is mention of engineered drawings - are these drawings to be stamped by an Engineer licensed to practice in the Province of Manitoba?

Answer: Yes, the engineer must be licenced to practice in Manitoba

2. The scope of work mentions high density spray foams insulation - Is this to be applied to the underside of the roof deck as well with an open area above the bottom cord of the roof truss

Answer: Yes, insulation is to be applied to underside of roof deck, leaving an open, vaulted ceiling above bottom truss chord; the insulation is then to be followed with plywood being installed as interior finish.

3. Couple of questions I have received from electrical trades on this garage project... sub panel doesn't have a size... and no spec on interior lighting... Any idea where this info would be?

Answer: - Sub panel is to be 100 amp

- Interior lighting: as per scope, is to be 100 Lx LED;
  - i. Style is non-essential. To protect lighting from damage, shall be wall-mounted and flush, protruding minimally.

**ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME AND IN FULL EFFECT**