



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions/Travaux  
publics et Services gouvernementaux Canada  
See herein for bid submission  
instructions/

Voir la présente pour les  
instructions sur la présentation  
d'une soumission

NA  
Manitoba

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada -  
Western Region  
Victory Building/Édifrice Victory  
Room 310/pièce 310  
269 Main Street/269 rue Main  
Winnipeg  
Manitoba  
R3C 1B3

<b>Title - Sujet</b> Gearbox Assembly	
<b>Solicitation No. - N° de l'invitation</b> ET858-200794/A	<b>Amendment No. - N° modif.</b> 003
<b>Client Reference No. - N° de référence du client</b> PWGSC-ET858-200794	<b>Date</b> 2020-08-14
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$WPG-102-11045	
<b>File No. - N° de dossier</b> WPG-9-42173 (102)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2020-08-18</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Central Daylight Saving Time CDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Wiebe, Dallas	<b>Buyer Id - Id de l'acheteur</b> wpg102
<b>Telephone No. - N° de téléphone</b> (204) 899-5257 ( )	<b>FAX No. - N° de FAX</b> (204) 983-7796
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

**Amendment 003 to Solicitation No. ET858-200794/A is being issued for the following:**

**Questions and Answers:**

**-When is the planned start date for Task 2?**

As per the SOW, the vendor is requested to supply a schedule within 14 days of contract award, including Task 2. Please see: Annex A – Statement of Work – Section A4.1; Section A5.2  
The date will be after the dam is out for the season, which is approximately the first week of November 2020.

**-In order to determine the expected condition of the gearbox, when were the pictures in the Annex A taken? Can you share more pictures?**

The photos were taken in 2019; there are no other useful pictures to be shared.

**-Are the pocket wheels to be replaced? Does St Andrews have replacements?**

They are to be cleaned and machined to specifications;  
No, St Andrews Lock and Dam (SALD) does not have replacements.

**-Are the pillowblocks to be replaced?**

As per Annex A – Statement of Work – Section A4.5.4 (Task 5) : *“Based on the results of the previous overhaul of the gearbox assembly on the main frame crane, we expect that the work may include but need not be limited to items such as the following: (Sub Item #2) replacement of pillow block bearings, possibly including custom machining to get new parts to fit mounting points”*

**Regarding Task 6:**

**-What are the sizes of the reservoirs?**

About 80 - 100 liters

**-Clean out access ? top or sides?**

Top

**-What are the access cover dimensions**

10.5” by 10’.5”

**-Can you provide pictures and/or schematics of HPU?**

No schematics, however a picture is being provided.

**-Customer to provide new filters, oil?**

Vendor to provide all needed tools, parts, labour and supplies.

**-Who is supplying tote/barrels for used oil?**

Vendor to provide all needed tools, parts, labour and supplies.

**-Is there any training/orientation (fall arrest, site orientation, rigging)?**

SALD crew will operate the Overhead crane to remove unit from the center deck to ground level. We will also have a safety meeting with the vendor regarding hazards and the environment.

**-Is there access to bring equipment/tools?**

Yes, there is space to bring equipment & tools, however work is primarily going to be performed in the vendor’s shop.

**-What is the available power?**

There will be access to 110 volt plugs.

Solicitation No. - N° de l'invitation  
ET858-200794/A

Amd. No. - N° de la modif.  
003

Buyer ID - Id de l'acheteur  
wpg102

*If your bid has already been forwarded and you wish to revise the same, this revision should reach the Bid Receiving Unit identified before the closing date. The bid number and closing date are to be clearly identified.*

**END OF AMENDMENT 003**





