

#### Amendment 003

Q9. Could we get clarification on Specification Section 22 11 16 (Domestic Water Piping), Part 2, 2.3.4 (Fittings) & 2.4.2 (Joints). Both sections indicate 2 ½" and larger fittings and joints to be flanged. Copper fittings of this size cannot be purchased flanged. Are we expected to prefabricate these fittings and joints with flanges or will slip on fittings and couplings be accepted?

A9. Flanges are required as indicated in Section 22 11 16, and flanges are to be brazed to pipe and fittings.

Q9. Drawing M104, First Part Floor Plan Plumbing, Room 1014, Please confirm Eyewash is existing and not new as it is in 'dark colour' on the drawing.

A9. Eyewash in 1014 is existing.