
Title: Talbot Earth Dam North Embankment

Addendum No. 2

Specification Revisions

Page 1

Project No. R076951.806

Date: August 17 2020

The following changes in the bid documents are effectively immediately. This addendum will form part of the contract documents.

Revisions:

Part 1 – General

- 1.1 Specification Section 01 14 00
- .1 Refer to article 1.9
- .1 **Delete** 1.9.2
- .2 **Replace** with the following:
- .1 All in-water work must be completed on or before May 1st **2021**. This includes but is not limited to gabion removal, rip rap replacement, associated grading and earth works.
- 1.2 Specification Section 01 22 01
- .1 Refer to article 1.6
- .1 **Delete** 1.6.2
- .2 **Replace** with the following:
- .1 Make form of submittal parallel to Schedule of Values, with each line item identified same as Schedule of Values. Include in unit prices only:
- .1 Cost of Material
- .2 Delivery and unloading at site
- .3 Installation, overhead and profit.
- 1.3 Specification Section 01 45 00
- .1 Refer to article 1.11
- .1 **Delete** 1.11.1
- .2 **Replace** with the following:
- .1 Not Used.

1.4 Specification Section 31 22 13

.1 Refer to article 1.2

.1 **Delete** 1.2.5

.2 **Replace** with the following:

.1 Section 31 05 16 – Aggregate for Earth Works.

1.5 Specification Section 31 62 16.13

.1 Refer to article 2.1

.1 **Delete** 2.1.1 and 2.1.2

.2 **Replace** with the following:

.1 Steel sheet piles must be a minimum thickness of 7 gauge (4.5mm thick).

.2 Steel sheet piles: ASTM A328, cold or hot rolled and minimum 7 gauge (4.5mm thick).

1.6 Specification Section 31 62 16.13

.1 Refer to article 3.2

.1 **Delete** 3.2.4

.2 **Replace** with the following:

.1 When installation is complete, face of wall at top of sheet piles to be within 75mm of location as indicated and deviation from vertical not to exceed 2 degrees.