



**SEN-012 20/21**

**Interior Signage for The Senate of Canada**

**QUESTIONS AND ANSWERS #1**

---

**August 18<sup>th</sup>, 2020**

**Question 1:**

In Section 31, 32, 33, 34, 35 and 36, there are no dimensions of the signage. May you please provide us with the appropriate dimensions?

**Answer 1:**

31. Interior Signage Victoria Building - Directional signage - (Front of House – FoH):  
Overall dimension: 370mm (W) x 3mm (D) x 642mm (H)

32. Interior Signage Victoria Building - Evacuation Signage:  
Overall dimension: 370mm (W) x 3mm (D) x 642mm (H)

33. Interior Signage - Standard Offices and Workstations:  
Overall dimension: 300mm (W) x 3mm (D) x 120-211mm (H)

34. Interior Signage - Directional Signage:  
Overall dimension: 600mm (W) x 3mm (D) x 480mm (H)

35. Interior Signage - Directorate Signage:  
Overall dimension: 910mm (W) x 3mm (D) x 1020mm (H)

36. Interior Signage – Heritage:  
Overall dimension: 102mm (W) x 10mm (D) x 23mm (H)

---