



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Flat Roof Repair & HVAC Replacement	
Solicitation No. - N° de l'invitation EZ899-210438/A	Amendment No. - N° modif. 006
Client Reference No. - N° de référence du client	Date 2020-08-21
GETS Reference No. - N° de référence de SEAG PW-SPWY-028-8803	
File No. - N° de dossier PWY-0-43032 (028)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2020-08-28	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lam (PWY), Tian	Buyer Id - Id de l'acheteur pwy028
Telephone No. - N° de téléphone (604) 363-7968 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: CSC - Chilliwack Correctional Centre - Chilliwack, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ899-210438/A

Amd. No. - N° de la modif.
006

Buyer ID - Id de l'acheteur
pwy028

Client Ref. No. - N° de réf. du client

File No. - N° du dossier CCC No./N°

CCC - FMS No./N° VME

The Solicitation Amendment 006 is raised to issue Addendum 006.

Please see Addendum 006 herein.

All other terms and conditions remain unchanged.

This addendum varies the Contract Documents and will form part of the Contract Documents and is to be read, interpreted and coordinated with all other parts, including General and Supplementary General Conditions of the Contract and all Sections in Division 1. The cost of all work contained herein is to be included in the Contract Sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above named project to the extent referenced and shall become a part thereof.

GENERAL

This addendum is issued prior to receipt of Bids to provide for certain revisions to and clarification to the Contract Documents.

The work required by this Addendum shall be executed in accordance with the requirements of the Contract and Contract Documents.

Include in the Stipulated Price, the cost of all work described in this Addendum.

ITEM 1: Questions and Answers:

Q6-1. *There is no mechanical equipment schedule in the electrical drawings. Will the electrical consultant add this in their drawing?*

Answer:

-See Drawing E000 - Detail-2, and clarified in Addendum No.5.

Q6-2. *Mechanical equipment P-3 and MUA-1 are shown in the mechanical drawings but not shown in the electrical plans. Is the electrical consultant to revise their drawings to show this equipment?*

Answer:

-See Drawing M500 Mechanical Equipment Schedules – Fan Schedule: indicates existing unit tag “MUA-1” equipment tag is being renamed to new equipment tag “F-17”.

-See Drawing E102 – Detail-1 Electrical (Demo): Fan “F-20” tag should read “MUA-1”.

-See ITEM-2 of this Addendum for Pump P-3 electrical scope of work.

Q6-3. *Mechanical equipment F-17 is shown in the electrical drawings but not in the mechanical fan schedule, mechanical drawing M500. Pls confirm electrical requirements.*

Answer:

-See Drawing M500 Mechanical Equipment Schedules – Fan Schedule: existing unit tag “MUA-1” equipment tag is being renamed to new equipment tag “F-17”.

Q6-4. *Does the existing mechanical equipment being replaced have the same specification as the new mechanical equipment that will allow us to reuse the existing conduit and wiring currently feeding them?*

Answer: No.

ITEM 2: Refer to Electrical Drawings and Specifications

CHANGE: Add Pump P-3 Electrical Scope of Work:

-Electrical scope of work and requirements for Pump P-3 shall be identical to Pump P-4.

-Existing pump P-3 is located in the mechanical room, and shall connect to existing Panel-M.

ITEM 3: PHOTOS OF EXISTING MECHANICAL ROOM - HEATING PIPING









END OF ADDENDUM NO.6