

Amendment 005

Q. Since seismic is required can existing Structural drawings for my seismic engineer be provided.

A. Existing structural drawings, if available, will be provided to the winning proponent.

Q. Domestic piping insulation is under HVAC piping insulation in the specification. Is this correct or should piping Insulation be its own section?

A. Domestic water piping insulation shall adhere to Section 23 07 19.