



**RETURN BIDS TO:
RETOURNER LES SUBMISSION À :**

Parks Canada Agency Bid Receiving Unit
National Contracting Services

Bid Fax: 1-866-246-6893

Bid Email: soumissionsouest-bidswest@canada.ca

This is the only acceptable email address for responses to bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address may not be accepted.

The maximum email file size is 25 megabytes. Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

**REVISION 002 TO A
INVITATION TO TENDER**

**RÉVISION 002 À UNE
INVITATION À SOUMISSIONNER
DEMANDE D'OFFRES À
COMMANDES**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Offer remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'offre demeurent les mêmes.

Issuing Office - Bureau de distribution :
Parks Canada Agency
Calgary, AB

Title - Sujet : Hwy 93S Culvert Rehab KM 102 – Kootenay National Park	
Solicitation No. - N° de l'invitation : 5P420-20-0154/A	Date : August 24, 2020
Amendment No. - N° de modification : 002	
Client Reference No. - N° de référence du client : 2177-01	
GETS Reference No. N° de référence de SEAG : PW-20-00922910	

Solicitation Closes - L'invitation prend fin : At - à : 2:00 PM On - le : August 26, 2020	Time Zone - Fuseau horaire MDT - HAR
--	--

F.O.B. - F.A.B. : Plant - Usine : <input type="checkbox"/> Destination : <input checked="" type="checkbox"/> Other - Autre : <input type="checkbox"/>		
Address Enquiries to - Adresser toutes demande de renseignements à : Rebecca Chen		
Telephone No. - N° de telephone : (587) 439-3529	Fax No. -N° de télécopieur : (866) 246-6893	Email Address – Courriel : rebecca.chen2@canada.ca
Destination of Goods, Services, and Construction - Destination des biens, services, et construction : Kootenay National Park See Herein – Voir ici		

TO BE COMPLETED BY THE BIDDER - À REMPLIR PAR LE SOUMISSIONNAIRE

Vendor/ Firm Name - Nom du fournisseur/ de l'entrepreneur :	
Address - Adresse :	
Telephone No. - N° de telephone :	Fax No. - N° de télécopieur :
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Signature :	Date :

Amendment 002

This amendment is being raised to extend the solicitation closing date and to distribute questions and answers.

A. Bid Closing Date

The closing date for tender 5P420-20-0154/A is extended from August 25, 2020 to **August 26, 2020 at 2:00PM Mountain Daylight Time (MDT)**.

B. Question and Answer

Q11 Page 5 of 131 of the specs states that the contractor is responsible for sourcing potable water from outside of the National Parks. Accessing local water sources within Parks can be coordinated through the Departmental Rep and the ESO but will require the Contractor to obtain a Restricted Activity Permit (RAP). Can you confirm that the contractor can utilize potable from inside the National Park if a Restricted Activity Permit (RAP) is obtained?

A11 Contractors may be able to access local water sources with a RAP, however there is no guarantee this will be a potable source. If potable water is required the contractor should arrange for it outside of the National Park.

Q12 Are there any utilities anticipated in the work area that will affect construction activities?

A12 There are utilities in the area (fibre, power, sanitary) however none are inside the culvert.

Q13 Section 01 11 00 Summary of work Part 1.2.3.14 states "Riprap is to be sourced from outside the National Parks..." Section 01 14 00 Work Restrictions Part 1.9.4 states "The Contract must determine the quality and quantity of material available and the condition of the PCA pit or quarry made available to the Contractor." Can you please confirm that the contractor can source material from the PCA gravel pit or quarry? If a material source is made available, can you please indicate which PCA gravel pits or quarries will be made available to the Contractor and what source materials are available?

A13 There is no owner supply of riprap for this work. If other granular material are deemed to be required it will be included under prime cost sum, and Section 01 14 00, Part 1.9 may apply.

Q14 Can the Project Superintendent or Deputy Project Superintendent act as the Health & Safety Representative, QC Rep, Enviro Rep, and/or Traffic Control Supervisor?

A14 A individual can act in more than one role if they are competent, qualified and have sufficient time to complete all the work required by each role as determined by the departmental representative.

Q15 Is a full time QEP required for this project?

A15 No

Q16 What distance out from the inlet and outlet do you expect to place rip rap?

A16 Rip rap is to be placed as directed by the Departmental Representative, currently estimated as approximately 15m upstream of the inlet and 10m downstream of the outlet.

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED