



## RETURN BIDS TO:

## RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution  
Public Works and Government Services Canada - Pacific  
Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> CCG SAR Float Reconstruction	
<b>Solicitation No. - N° de l'invitation</b> F1700-204105/A	<b>Amendment No. - N° modif.</b> 005
<b>Client Reference No. - N° de référence du client</b> F1700-204105	<b>Date</b> 2020-08-25
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-036-8802	
<b>File No. - N° de dossier</b> PWY-0-43033 (036)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2020-08-28</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Pacific Daylight Saving Time PDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Martin (PWY), Delia	<b>Buyer Id - Id de l'acheteur</b> pwy036
<b>Telephone No. - N° de téléphone</b> (778) 707-2139 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> DFO - Port Hardy, BC	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

N° de l'invitation - Solicitation No.  
F1700-204105/A  
N° de réf. du client - Client Ref. No.

N° de la modif - Amd. No.  
005  
File No. - N° du dossier  
PWY-0-43033

Id de l'acheteur - Buyer ID  
PWY036  
N° CCC / CCC No. / N° VME - FMS

---

The Solicitation Amendment 005 is raised to issue Addendum #4. Please see Addendum #4 attached.

The Addendum will form part of the contract documents.

All other terms and conditions remain unchanged.

**Port Hardy CCG SAR – Float Replacement  
Addendum #4**

---

The following changes / clarifications in the tender documents are effective immediately. This Addendum will form part of the Contract Documents.

**Response to Bidders' Inquiries:**

Please find below a response to bidder's inquiries received to date.

**1. Are the float imbeds stainless steel?**

Inserts and bolts to be hot dip galvanized as per specifications Section 05 12 33.

**2. Is there a water stop at the bottom slab where it meets the walls or are you going to be merely scarifying the surface at the wall intersections?**

Water stop is not required, scarifying the surface at the wall intersection is acceptable.

**Amendments:**

Please find amendments to the following specifications.

**N/A**

**END OF ADDENDUM**