

- .1 ALL ELECTRICAL (120V) WIRING, INCLUDING CIRCUIT BREAKERS, SHALL BE PROVIDED (I.E. SUPPLIED & INSTALLED) BY THE CONTRACTOR.
- .2 ALL LOW VOLTAGE (24V) WIRING, INCLUDING 120/24VDC CONTROL TRANSFORMERS, SHALL BE PROVIDED (I.E. SUPPLIED & INSTALLED) BY THE CONTRACTOR.
- .3 ALL NETWORK/COMMUNICATION WIRING, INCLUDING DATA CONNECTIONS & DROPS, SHALL BE PROVIDED (I.E. SUPPLIED & INSTALLED) BY THE CONTRACTOR.
- .4 THE SCHEMATIC SHOWN BELOW IS NOT NECESSARILY INDICATIVE OF THE REQUIRED NUMBER OF ROOM-LEVEL INTEGRATION DEVICES.

THE SEQUENCE OF OPERATION FOR THE LABORATORY SYSTEM IS AS FOLLOWS:

- THE SEQUENCE OF OPERATION FOR THE LABORATORY SYSTEM IS AS FOLLOWS:
1. SYSTEM OPERATIONAL PRIORITY (I.E. AIR CHANGE RATE WITHIN THE LABORATORY SPACES) WILL BE BASED ON THE FOLLOWING PRIORITIES:
 1. OCCUPANCY (I.E. TIME-OF-DAY SCHEDULE).
 2. THERMAL COMFORT (I.E. HEATING/COOLING REQUIREMENTS OF THE SPACE).
 3. FUME HOOD OPERATION (I.E. INCREASED AIRFLOW DUE TO FUME HOODS OPERATIONAL).
 2. THE OPERATION OF THE SUPPLY, GENERAL EXHAUST AND FUME HOOD EXHAUST AIR VALVES WILL BE SELF-CONTAINED WITHIN THEIR MANUFACTURER-SPECIFIC PROGRAMMING. PROVIDE LABORATORY ROOM CONTROLLERS AS REQUIRED IF THE VALVES THEMSELVES DO NOT HAVE THE NECESSARY PROGRAMMABLE LOGIC CONTROL TO MODULATE TO MAINTAIN A VOLUMETRIC OFFSET SET-POINT BASED ON SYSTEM OPERATIONAL PRIORITY INPUTS PROVIDED BELOW. TO BE DONE WITHIN THE LAB-SPECIFIC PROGRAMMABLE LOGIC CONTROL, TO BE INSTALLED, PROGRAMMED AND COMMISSIONED TO MAINTAIN THE SPECIFIED AIRFLOW OFFSET (I.E. BETWEEN SUPPLY AND EXHAUST).
 1. OCCUPANCY (I.E. TIME-OF-DAY SCHEDULE), MULTI-STATE SIGNAL TO CHANGE FROM OCCUPIED ACH RATE (I.E. 4 ACHS) OR UNOCCUPIED ACH RATE (I.E. 2 ACHS)
 2. THERMAL COMFORT (I.E. HEATING/COOLING REQUIREMENTS OF THE SPACE), SEE ADDITIONAL REQUIREMENTS PROVIDED WITHIN THE SEQUENCE OF OPERATION BELOW. THE INDIVIDUAL LABORATORY CONTROLLERS & AIR VALVE CONTROLLERS SHALL CONTROL THE FUME HOODS.
 3. FUME HOOD OPERATION (I.E. INCREASED AIRFLOW DUE TO FUME HOODS OPERATIONAL), WHERE FUME HOODS ARE BEING CONVERTED TO VAV FUME HOODS, RAISING THE FUME HOOD SASH WILL INCREASE THE EXHAUST FLOW FROM THE FUME HOOD.
 3. A MINIMUM OF 15% OF THE NEW SUPPLY AIR VALVES AND 15% OF THE NEW GENERAL/FUME EXHAUST AIR VALVES SHALL BE COMPLETE WITH DIFFERENTIAL PRESSURE TRANSDUCERS (ANALOG) TO ALLOW FOR THE IMPLEMENTATION OF A STATIC PRESSURE RESET PROGRAM. THE AIR VALVES SHALL BE IDENTIFIED AT THE TIME OF SHOP DRAWINGS. THE CONTROLS CONTRACTOR SHALL IMPLEMENT THE STATIC PRESSURE RESET PROGRAM FOR THE MAIN SUPPLY AND EXHAUST SYSTEMS.

- | INCLUDING: | | | |
|------------|--------------------|-------------|------------|
| 1 | JAM_ALARM | BINARY | READ |
| 2 | FLOW_ALARM | BINARY | READ |
| 3 | EFF_VLV_CMD | ANALOG | READ |
| 4 | EFF_VLV_FLOW_FDBK | ANALOG | READ |
| 5 | BROKEN_SASH_CABLE | BINARY | READ |
| 6 | HOOD_OVERRIDE | BINARY | READ |
| 7 | SASH_HEIGHT_ALARM | BINARY | READ |
| 9 | FACE_VELOCITY | ANALOG | READ |
| 10 | SASH_OPEN_PERCENT | ANALOG | READ |
| 11 | USER_STATUS_STATE | BINARY | READ |
| 12 | OCCUPANCY_CMD | MULTI-STATE | READ/WRITE |
| 13 | EFF_OCC_MODE | MULTI-STATE | READ |
| 14 | EFF_EMER_MODE | MULTI-STATE | READ |
| 15 | EMER_MODE_CMD | MULTI-STATE | READ/WRITE |
| 16 | OCC_COOL_SETPT | ANALOG | READ/WRITE |
| 17 | OCC_HEAT_SETPT | ANALOG | READ/WRITE |
| 18 | UNOCC_COOL_SETPT | ANALOG | READ/WRITE |
| 19 | UNOCC_HEAT_SETPT | ANALOG | READ/WRITE |
| 20 | EFF_TEMP_SETPT | ANALOG | READ |
| 21 | OCC_TEMP_SETPT | ANALOG | READ/WRITE |
| 22 | AVG_SPACE_TEMP | ANALOG | READ |
| 23 | TEMP_CTRL_MODE | MULTI-STATE | READ |
| 24 | HVAC_MODE_OVERRIDE | MULTI-STATE | READ/WRITE |
| 25 | OFFSET | ANALOG | READ |
| 26 | OCC_MIN_SETPT | ANALOG | READ/WRITE |
| 27 | UNOCC_MIN_SETPT | ANALOG | READ/WRITE |
| 28 | TOTAL_ZONE_SUPPLY | ANALOG | READ |
| 29 | TOTAL_ZONE_EXHAUST | ANALOG | READ |
- ALL POINTS ABOVE SHALL BE TRENDED FOR 4 MONTHS USING CHANGE OF VALUE TRENDING (I.E. EACH TIME THE VALUE CHANGES, IT CREATES A TREND LOG INPUT). EACH ALARM IDENTIFIED ABOVE SHALL BE BROUGHT THROUGH AND ESCALATED BY DIRECTED BY STATION OPERATORS. ALL CONTROL GRAPHICS, EVENT MANAGEMENT, DATA LOG TRENDING, ALARM MONITORING, ETC. SHALL BE THROUGH THE EXISTING DELTA ENERGY MANAGEMENT AND CONTROL SYSTEM.

5. THE LABORATORY ROOM CONTROLLERS SHALL, IN ADDITION TO THE REQUIREMENTS OUTLINED ABOVE, PROVIDE:
1. SPACE TEMPERATURE CONTROL BY (A) VARYING THE SUPPLY AIRFLOW TO THE SPACE AND/OR (B) MODULATING THE REHEAT CONTROL VALVE. THROUGH THE ROOM INTEGRATOR THE BUILDING AUTOMATION SYSTEM WILL PROVIDE OCCUPIED/OCCUPYED SET POINTS BASED ON TIME-OF-DAY SCHEDULE, WITH MINOR (+/- 5°C) VARIABILITY AT THE LOCAL ROOM-LEVEL CONTROLLER.

- .6 USING THE "READ/WRITE" POINTS TO BE INTEGRATED ABOVE, THE BUILDING AUTOMATION SYSTEM WILL PROVIDE THE FOLLOWING CONTROLS:
- .1 SHALL PROVIDE OCCUPANCY TIME-OF-DAY SCHEDULE TO LABORATORY SPACES THROUGH A SIGNAL TO "OCCUPANCY_CMD". EACH LABORATORY SPACE WILL HAVE A SEPARATE SCHEDULE, WITH THE ABILITY TO GLOBALLY UPDATE/EDIT ALL SCHEDULES.
 - .2 THE BUILDING AUTOMATION SYSTEM WILL ALLOW FOR THE MANUAL SETTING OF THE FOLLOWING POINTS "OCC_MIN_SETUP", "UNOCC_MIN_SETUP" AND "EMER_MODE_CMD".
 - .3 THE "EMER_MODE_CMD" ALLOWS THE SYSTEM TO ESTABLISH FOUR (4) EMERGENCY CODE SCENARIOS, THE CONTRACTOR WILL PROGRAM AT LEAST ONE (1) CODE SUCH THAT IT ALLOWS THE USERS TO MANUALLY REVERT EACH LABORATORY SPACE TO FULL-FLOW & ONE (1) CODE SUCH THAT IT ALLOWS THE USERS WITHIN THE LABORATORY TO UTILIZE THE EMERGENCY FLOW. THE CONTRACTOR WILL ALSO PROVIDE A REVERTER THAT REVERTS THE LABORATORY SPACE TO FULL FLOW. REFER TO ADDITIONAL REQUIREMENTS AS OUTLINED ABOVE.

7. THE FOLLOWING FRONT-END CONTROL REQUIREMENTS WILL BE PROVIDED:
- 1. EVENT MANAGEMENT
 - 1. ALL ALARMS SHALL BE CREATED BY, AND VIEWED AND MANAGED THROUGH, THE EXISTING ENTLEVIEW OWS SYSTEM.
 - 2. ALARMS OBJECTS/EVENTS SHALL BE VIEWABLE, AND HAVE THE ABILITY TO BE ACKNOWLEDGED OR DISMISSED BY, THE EXISTING USERS AND USER GROUPS.
 - 3. CRITICAL ALARMS SHALL BE ROUTED THROUGH TO THE COMMISSIONAIRES DESK. CRITICAL ALARMS WILL BE AS REQUIRED BY THE DEPARTMENTAL REPRESENTATIVE AND AS REQUIRED WITHIN THE DRAWINGS AND SPECIFICATIONS.
 - 2. TRENDING AND ARCHIVING
 - 1. ALL PHYSICAL AND VIRTUAL INPUTS, OUTPUTS, AND TEMPERATURE & PRESSURE SET POINTS SHALL BE TRENDED AND ARCHIVED ON THE EXISTING HISTORIAN SOFTWARE PLATFORM FOR A PERIOD OF 1 YEAR.
 - 2. ARCHIVED TREND LOGS SHALL BE ALSO SET UP FOR THE POINTS DESCRIBED ABOVE.
 - 3. TRENDS SHALL BE CONFIGURED TO RECORD ON 15 MINUTE INCREMENTS.
 - 4. ARCHIVED TREND LOG DATA SHALL BE VISIBLE UTILIZING THE EXISTING ENTLEVIEW OWS.
 - 5. TREND LOG DATA SHALL BE SELECTED BASED ON OBJECT AND TIME FRAME, AND BE EXPORTED TO AN EXCEL, PDF, OR WORD DOCUMENT FORMAT.

- 3 NETWORK CONFIGURATION
- 1 SYSTEM LEVEL PANELS SHALL BE CONFIGURED TO COMMUNICATE ON THE EXISTING NETWORK UTILIZING BACNET IP.
- 2 PANELS, GATEWAYS, OR OTHER BACNET APPLIANCES SHALL BE SOFTWARE ADDRESSABLE. PANEL ADDRESSES TO BE APPROVED BY CONSULTANT TO AVOID CONFLICTS WITH THE EXISTING BAS PANELS.

4. GRAPHICS
- 1. GRAPHICS SHALL RESIDE ON THE EXISTING OWS ENTELIWEB SOFTWARE PLATFORM.
 - 2. GRAPHIC FILES SHALL:
 - 1. APPEAR LOGICALLY BENEATH THE RELEVANT BUILDING, WITHIN THE EXISTING BUILDING STOCK.
 - 2. LOGICALLY NAMED BY ROOM, SYSTEM OR DEVICE.
 - 3. BE USER SELECTABLE UTILIZING "POINT AND CLICK"
 - 3. GRAPHICS SHALL HAVE THE FUNCTIONALITY:
 - 1. MOUSE HOVER OVER A GRAPHIC POINT SHALL PROVIDE A REAL-TIME VALUE
 - 2. MOUSE HOVER OVER A GRAPHIC POINT SHALL PROVIDE ADDITIONAL POINT-AND-CLICK FUNCTIONALITY
 - 1. SET POINT TO AUTO
 - 2. SET POINT TO MANUAL, ALONG WITH AN APPROPRIATE ANALOGUE OR BINARY VALUE.
 - 4. GRAPHICS SHALL HAVE THE SAME STRUCTURE, LOOK AND FEEL OF THE EXISTING GRAPHICS.
 - 5. WORK IN EXISTING BUILDINGS SHALL UPDATE THE EXISTING GRAPHIC FILES TO REFLECT THE MECHANICAL, HARDWARE AND SOFTWARE CHANGES TO THE EXISTING BUILDINGS.
 - 6. NEW BUILDINGS OR ADDITIONAL BUILDINGS SHALL BE INCLUDED AND LINKED ON THE "STARTNEW" GRAPHIC PAGE, WHICH IS THE HOMEPAGE FOR ALL GRAPHICS AT SITE.
 - 7. OPERATING WORK STATION POINT COUNT:
 - 1. THE ENTELIWEB OWS SYSTEM AT BIO IS LICENSED TO OPERATE UP TO A TOTAL CONNECTED BACNET I/O POINT COUNT. THESE I/O POINTS MAY BE PHYSICAL OR VIRTUAL. OTHER BACNET POINTS DO NOT INCREASE THE NUMBER.
 - 2. EXCEEDING THIS POINT COUNT WILL CAUSE THE OWS SOFTWARE TO SHUT DOWN AFTER A MONTH DELAY.
 - 3. IT IS THE RESPONSIBILITY OF THE CONTROLS CONTRACTOR TO ENSURE THAT THE BACNET I/O OBJECTS ADDED TO THE BIO NETWORK DO NOT EXCEED THE MAXIMUM PERMISSIBLE I/O THE ENTELIWEB SERVER IS LICENSED FOR. IF THE I/O POINT COUNT IS EXCEEDED, ADDITIONAL I/O LICENSES CAN BE PURCHASED THROUGH CONTROLS & EQUIPMENT. THESE SHALL BE PURCHASED BY THE OWNER AS AN EXTRA TO THE CONTRACT ON AN AS-NEEDED BASIS, VERIFICATION, COORDINATION & MODIFICATION REQUIREMENTS SHALL BE PART OF THIS CONTRACT.

