

Solicitation No. - N° de l'invitation
EQ754-202087/A

Amd. No. - N° de la modif.

Buyer ID - Id de l'acheteur
pwl054

Client Ref. No. - N° de réf. du client
R.076951.806

File No. - N° du dossier
PWL-0-43010

CCC No./N° CCC - FMS No./N° VME

Attachment 021

Questions and Answers:

Q31) As it has been confirmed in previous addenda that all excavated materials must be disposed of off-site, under which item will the dry side slope fill as shown on D103 be paid and what type of material is to be placed in these fill areas.

A31) Drawing D103 will be updated to remove hatch showing fill area on the dry side slope as part of the Issued for Construction set. There are no fills required on the dry side slope.