



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Réception des soumissions - TPSGC / Bid Receiving -
PWGSC

1550, Avenue d'Estimauville

1550, D'Estimauville Avenue

Québec

Québec

G1J 0C7

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

TPSGC-PWGSC

601-1550, Avenue d'Estimauville

Québec

Québec

G1J 0C7

Title - Sujet Revitalisation du havre Grosse-Ile	
Solicitation No. - N° de l'invitation F3731-190013/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client F3731-190013	Date 2020-09-01
GETS Reference No. - N° de référence de SEAG PW-\$QCM-041-17972	
File No. - N° de dossier QCM-0-43076 (041)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2020-09-17	Time Zone Fuseau horaire Heure Avancée de l'Est HAE
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Beauchesne, Sonia	Buyer Id - Id de l'acheteur qcm041
Telephone No. - N° de téléphone (418) 576-9803 ()	FAX No. - N° de FAX (418) 648-2209
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Amendment 002

This amendment is raised to:

- A. Answer questions from bidders

A. Questions and Answers

- Q7.** Existing gangway to cut and modify: What are the exact modifications to be made?
A7. Disregard the indications on sheet 11(15 400mm gangway to modify), no modification to be made.
- Q8.** Gangways to be built: What are the respective quantity and dimensions as well as the details required for manufacturing?
A8. 3 gangways of 6000 mm to supply and install, all as indicated in Section 35 51 23 - Floating docks.
- Q9.** Wooden base for gangway:
 - On Drawings p 10 "floating docks layout" it is shown 1 single wooden base, however there seems to be 4 gangways
 - In detail 1 (03/10) it is indicated 3 wooden base?**A9.** 3 wooden bases are to be built according to details on drawings, the 4th gangway will be fixed to wharf # 3 (fieldfit installation).
- Q10.** How many ladders are there on wharves 1, 2 and 3 and what is their position?
A10. Please refer to question 1 (Q1/A1) in amendment 001.
- Q11.** What is the position of the mooring cleats?
A11. For new floating docks, 20 cleats so 2 per floating docks.
For wharves #1 and #2, 4 mooring bollard (see drawings - sheet 4) and 7 cleats (equal distribution on the wharf) and for wharf #2, 3 cleats (equal distribution on the wharf).
- Q12.** On page 10 of drawings "Configuration of the pontoons" It is indicated that there are 10 pontoons to be recovered, but there are no details of any modifications. So there is no work to be done on these pontoons ??
A12. True
- Q13.** On sheet 5 and 6, it is shown a wooden protective wall, but there are no details (type of wood, dimensions, bolts, etc.)?
A13. Please refer to question 6 (Q6/A6? In amendment 001.

Q14A. Is it possible to offer floating docks made of an aluminum structure and floats?

A14A. No, it is not possible to make a proposal for floating pontoons composed of an aluminum structure and floats. The pontoons must be manufactured according to the wooden concept because of its durability, its ease of repair on site with in stock material and to standardize floating dock systems in the Magdalen islands.

Q14B. And for the fixed portions (gangways), can they also be made with an aluminum structure with a wooden decking or aluminum grating.

A14B. For gangways and gratings, the specification requires that they be made of aluminum with a perforated grating.

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED