

Le 28-08-2020

Numéro d'addenda : ME-03 Mécanique-Électricité

Numéro de projet : R.094470.001

**Les modifications suivantes aux documents de soumissions entrent en vigueur immédiatement.**

**Le présent addenda fera partie des documents contractuels.**

**--- An English version follows on page 2 ---**

---


## PLAN

### 1. Plan E14

L'échelle pour la vue principale est 1 : 400

### 2. Drawing M30

COMPTEUR D'ÉNERGIE CE-01@03 /  
ENERGY METER CE-01 TO 03

 CONSOMMATION DU SYSTÈME /  
SYSTEM'S CONSUMPTION

Les compteurs d'énergie sont à raccorder au système d'automatisation du bâtiment et fourniront des données instantanées et cumulatives.

## DEVIS:

### 1. Section 00 11 01 – INFORMATION GÉNÉRALE SUR LES TRAVAUX

#### 1.1. Article 1.09

Le point 11 est modifié comme suit : Construire des barrières de protection temporaire pour protéger la zone de travaux.

### 2. Section 00 14 0 – RESTRICTIONS VISANT LES TRAVAUX

#### 2.1. Article 1.02

.4 est retiré

### 3. Section 01 41 00 EXIGENCES RÉGLEMENTAIRES

#### 3.1. Article 2.03 PERMIS

.2.2 est retiré

### 4. Section 23 05 00.02 EXIGENCES GÉNÉRALES CONCERNANT LES TRAVAUX DE CVCA

#### 4.1. Article 1.09 NATURE DES TRAVAUX

.11 Est modifié : Les travaux de contrôle pour l'ensemble des disciplines seront effectués par Honeywell. Honeywell fournira son prix directement à l'entrepreneur général.

August 28 2020

Addendum number : ME-03 Mechanical-Electricity

Project number : R.094470.001

The following changes to the tender documents are effective immediately. This addendum will be part of the contractual documents.

---

## DRAWING

### 3. Drawing E14

The scale for the main view is 1 : 400

### 4. Plan M30

COMPTEUR D'ÉNERGIE CE-01@03 /  
ENERGY METER CE-01 TO 03

EA CONSOMMATION DU SYSTÈME /  
SYSTEM'S CONSUMPTION

The energy meters are to be connected to the building's automation system and will provide instantaneous and cumulative data.

## SPECIFICATION:

### 1. Section 00 11 01 – GENERAL INFORMATION ABOUT THE WORK

#### 1.1. Article 1.09

.11 is modified: Build temporary protective barriers to protect the work area.

### 2. Section 00 14 00 – WORK RESTRICTIONS

#### 2.1. Article 1.02

.4 Is withdrawn

### 1. Section 01 41 00 – REGULATORY REQUIREMENTS

#### 1.1. Article 2.03 PERMITS

.2.2 Is withdrawn

### 2. Section 23 05 00.02 COMMON WORK RESULTS FOR HVAC

#### 2.1 Article 1.09 SCOPE OF WORK

.11 Is modified: Controls work for all disciplines will be carried out by Honeywell. Honeywell will provide its price directly to the general contractor.

Approuvé par / Approved by :



---

Patrick Dionne, ing. MBA  
Directeur mécanique et électricité