



Building Service Requests

Building: CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay NU
The criteria are at the end of the report.

Status Summary	Total	Emergency	Urgent	Normal
Acknowledged	5	0	2	3
Work Completed	134	1	43	90
Cancelled	1	0	0	1
Work Terminated	2	0	1	1
Totals	142	1	46	95

Service Class Summary	Total	Emergency	Urgent	Normal
Plumbing	38	1	11	26
2F - Plumbing	38	1	11	26
Cleaning	13	0	1	12
1B - Cleaning	10	0	1	9
2D - Interior Lighting	3	0	0	3
Other Building Maintenance	18	0	8	10
2H - Furnishings	2	0	1	1
2H - Other Building Maintenance	16	0	7	9
Structural/Roof	14	0	5	9
2E - Architectural/Structural	14	0	5	9
HVAC	29	0	10	19
2C - HVAC	29	0	10	19
Roads and Grounds	12	0	7	5
4B - Roads and Grounds	12	0	7	5
Security	6	0	1	5
4E - Security	6	0	1	5
Fire and Life Safety	4	0	1	3
2G - Fire and Life Safety	4	0	1	3
Electrical	8	0	2	6
2D - Electrical	8	0	2	6
Totals	142	1	46	95

Report ID 23002

Created 17 Aug 2020 09:26:30 PM GMT

1 of 49

Building Service Requests Version 3.5.0 - 17 Aug 2020. The controlled copy of this document is maintained electronically. All Paper copies are uncontrolled.

Fax: (877) 329-6722

Email: NSCC-CNAS@pwgsc.gc.ca



1-800-463-1850

Canada



Building Service Requests

Priority Summary		Total
Emergency		1
Normal		95
Urgent		46
Urgent B		0
Totals		142

Service Request Details

SR Number	5216627	Building ID	14303	Call Date	01 Apr 2019 07:38:17 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2C - HVAC		
Service Requester	Floor/Area		1		
Client					
Action Requested	Please increase the heating set-points (both occupied and un-occupied) for M-228 (new; old: M-237) by 3 degrees. Thanks.				

SR Number	5217430	Building ID	14303	Call Date	02 Apr 2019 02:09:33 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2E - Architectural/Structural		
Service Requester	Floor/Area		1		
Client					
Action Requested	As per client, please place a smoking pole at Loading Dock near M-Ex-14. And please ensure these are emptied on a weekly basis. Thank you				





Building Service Requests

SR Number	5217615	Building ID	14303	Call Date	02 Apr 2019 04:24:19 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2C - HVAC		
Service Requester		Floor/Area	1 / M-128		
Client	Indigenous and Northern Affairs Canada				
Action Requested	Please have the set-point in M-128 (new; old - M-138) lowered by 3 degrees for both occupied and unoccupied. Thanks.				
SR Number	5217647	Building ID	14303	Call Date	02 Apr 2019 05:30:53 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2E - Architectural/Structural		
Service Requester		Floor/Area	1 / NEAR 122		
Client	Polar Knowledge Canada (PKC)				
Action Requested	The door of Room 122 (photocopier room) door slams shut. Please adjust it. Thanks.				
SR Number	5218979	Building ID	14303	Call Date	04 Apr 2019 09:59:45 AM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	4E - Security		
Service Requester		Floor/Area	1 / MAIN DOORS		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please have the main doors to the MRB unlocked at 13:45 and locked at 16:15 every Wednesday as there will be building tours for the public. Thanks.				





Building Service Requests

SR Number	5221346	Building ID	14303	Call Date	08 Apr 2019 03:11:19 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU			Priority	Normal
				Status	Work Completed
				Type	4E - Security
Service Requester		Floor/Area		G / STAFF ENTRANCE / NORTH WEST SIDE	
Client					
Action Requested	The card reader does not work properly. Please repair it. Thanks.				

SR Number	5221920	Building ID	14303	Call Date	09 Apr 2019 12:33:28 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU			Priority	Normal
				Status	Work Completed
				Type	2H - Other Building Maintenance
Service Requester		Floor/Area		1 / MRB	
Client		Polar Knowledge Canada (PKC)			
Action Requested	Please unlock front entrance doors to the MRB for guest arrivals April 9th and 10th. Thanks.				

SR Number	5222021	Building ID	14303	Call Date	09 Apr 2019 01:49:55 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU			Priority	Normal
				Status	Work Completed
				Type	2C - HVAC
Service Requester		Floor/Area		2 / M-282	
Client		Indigenous and Northern Affairs Canada			
Action Requested	The main research building air exchange system is not working properly. Please attend. Thanks				

Report ID 23002

Created 17 Aug 2020 09:26:30 PM GMT

4 of 49

Building Service Requests Version 3.5.0 - 17 Aug 2020. The controlled copy of this document is maintained electronically. All Paper copies are uncontrolled.



1-800-463-1850

Fax: (877) 329-6722

Email: NSCC-CNAS@pwgsc.gc.ca

Canada



Building Service Requests

SR Number	5225155	Building ID	14303	Call Date	14 Apr 2019 07:55:58 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	1 / PUBLIC LWR		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Client reports that the water pressure needs to be checked in the bathroom, as some of the toilets are flushing very slowly. Thanks.				
SR Number	5227134	Building ID	14303	Call Date	16 Apr 2019 07:17:14 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	4B - Roads and Grounds		
Service Requester		Floor/Area	EXT / FLAG		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please reinstall the cap on the flag pole. Thanks.				
SR Number	5229093	Building ID	14303	Call Date	22 Apr 2019 06:37:58 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	4B - Roads and Grounds		
Service Requester		Floor/Area	EXT		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please remove the snow from the fire hydrants on the campus. They appear to be inaccessible. Thanks.				





Building Service Requests

SR Number	5229096	Building ID	14303	Call Date	22 Apr 2019 07:13:02 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2G - Fire and Life Safety		
Service Requester		Floor/Area	1		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please ensure all fire extinguishers are inspected monthly. The one in M-06 has not been inspected.				
SR Number	5234674	Building ID	14303	Call Date	30 Apr 2019 03:02:10 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2E - Architectural/Structural		
Service Requester		Floor/Area	1 / STAIRCASE		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Spiral stair case: one part of the handrail is very loose. If it detaches it could be dangerous. Please repair today. Thank you.				
SR Number	5235100	Building ID	14303	Call Date	01 May 2019 10:23:07 AM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2D - Electrical		
Service Requester		Floor/Area	1 / OFFICE AREA, PUBLIC SPACE / & DRY TOILETS		
Client	Polar Knowledge Canada (PKC)				
Action Requested	The lights in the office area, public space and the dry toilets are not turn on this morning. The lights should automatically turn on as someone walk in the room. The lights are on in other areas and can't be turned off. Please attend. Thank you				





Building Service Requests

SR Number	5235686	Building ID	14303	Call Date	01 May 2019 06:22:16 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2E - Architectural/Structural		
Service Requester		Floor/Area	2 / 219		
Client	Polar Knowledge Canada (PKC)				
Action Requested	The door is hard to push open and it seems to be off it's proper alignment. The bottom of the door hits the floor and the side hits the wall				
SR Number	5235691	Building ID	14303	Call Date	01 May 2019 06:41:53 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2E - Architectural/Structural		
Service Requester		Floor/Area	2 / 220		
Client	Polar Knowledge Canada (PKC)				
Action Requested	The large door handle is extremely loose and coming detached from the screws.				
SR Number	5236533	Building ID	14303	Call Date	02 May 2019 03:50:55 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	1 / LWR		
Client	Polar Knowledge Canada (PKC)				
Action Requested	The toilets are making burping noises when they are flushed. Please attend. Thanks				

Report ID 23002





Building Service Requests

SR Number	5237127	Building ID	14303	Call Date	03 May 2019 12:32:56 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Cancelled
		Type	1B - Cleaning		
Service Requester		Floor/Area	1 / MUTLI-USE SPACE		
Client	Polar Knowledge Canada (PKC)				
Action Requested	The windows need to be cleaned for a near future polar. Please attend. Thanks.				
SR Number	5238481	Building ID	14303	Call Date	06 May 2019 02:35:09 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	4B - Roads and Grounds		
Service Requester	Tetra Aaluk	Floor/Area	1 / DOORS M-EX-7 AND M-EX-8		
	867-391-0314				
Client	Polar Knowledge Canada (PKC)				
Action Requested	Falling snow and ice is a Health and Safety issue, please have the ice and snow that is in danger of falling on to employees from the roof over doors M-EX-7 and M-EX-8 removed ASAP. Thanks.				
SR Number	5239347	Building ID	14303	Call Date	07 May 2019 11:24:51 AM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	4B - Roads and Grounds		
Service Requester		Floor/Area	EXT / ENTRANCE WAYS / & PATHWAYS		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please remove the snow, ice and and icy debris cluttering the outside entrance ways and paths to doors 1 A, 1 B. This is a result of the snow and ice cleared from the roof yesterday. Thanks.				

Report ID 23002





Building Service Requests

SR Number	5241463	Building ID	14303	Call Date	09 May 2019 12:20:14 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2C - HVAC		
Service Requester		Floor/Area	ALL BUILDING		
Client	Polar Knowledge Canada (PKC)				
Action Requested	**REDISPATCHED on 09/05/2019 14:49: Client reports a nauseating smell of coming from the vent. Please attend. Thanks.				

SR Number	5242824	Building ID	14303	Call Date	12 May 2019 08:53:01 AM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	TRIPLEX 7		
Client	Indigenous and Northern Affairs Canada				
Action Requested	Client reports the sewage is high. Please empty the tank, thanks.				

SR Number	5244448	Building ID	14303	Call Date	14 May 2019 12:56:19 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	2C - HVAC		
Service Requester		Floor/Area	1 / 124		
Client	Polar Knowledge Canada (PKC)				
Action Requested	The temperature is too hot in the server room. Please attend ASAP. Thanks.				





Building Service Requests

SR Number	5246431	Building ID	14303	Call Date	16 May 2019 05:43:42 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	4E - Security		
Service Requester		Floor/Area	1 / 130		
Client	Polar Knowledge Canada (PKC)				
Action Requested	The client reports an alarm on the Tyco panel for intergrated fire and security system. Please reset it. Thanks				
SR Number	5248313	Building ID	14303	Call Date	21 May 2019 04:30:15 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	1 / ALL THE TOILETS (MWR / & LWR)		
Client	Polar Knowledge Canada (PKC)				
Action Requested	The toilets are blocked as per the clients it's in the pipes for all the toilets. The SP is already aware of the issue. Please attend. Thanks.				
SR Number	5250688	Building ID	14303	Call Date	24 May 2019 11:41:38 AM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	1 / M1C70		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Client reports that the floor drain in room MC170 is clogged. Please attend. Thanks.				

Report ID 23002





Building Service Requests

SR Number	5251000	Building ID	14303	Call Date	24 May 2019 04:40:15 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU			Priority	Urgent
				Status	Work Completed
				Type	2E - Architectural/Structural
Service Requester		Floor/Area		EXT / AQUATICS LAB	
Client	Polar Knowledge Canada (PKC)				
Action Requested	The client reports that the weeping tiles are overflowing in the Aquatics lab. The flowing water is outside just off the building's foundation. Please attend ASAP. Thanks.				

SR Number	5251842	Building ID	14303	Call Date	27 May 2019 12:44:47 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU			Priority	Normal
				Status	Work Completed
				Type	2C - HVAC
Service Requester		Floor/Area		2 / GENERAL ANALYTICAL LAB / 207 AND 207A	
Client	Polar Knowledge Canada (PKC)				
Action Requested	Rooms 207 and 207A needs temperature lowered to 18 Degrees Celsius. Please attend. Thanks.				

SR Number	5254267	Building ID	14303	Call Date	29 May 2019 06:21:14 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU			Priority	Urgent
				Status	Work Completed
				Type	2E - Architectural/Structural
Service Requester		Floor/Area		2 / LARGE BOARDROOM / ROOM 221	
Client	Polar Knowledge Canada (PKC)				
Action Requested	The large boardroom has a leak on the right entrance side of the room. Coming from the ceiling and in between the beams. Please attend ASAP. Thanks				

Report ID 23002

Created 17 Aug 2020 09:26:30 PM GMT

11 of 49

Building Service Requests Version 3.5.0 - 17 Aug 2020. The controlled copy of this document is maintained electronically. All Paper copies are uncontrolled.



1-800-463-1850

Fax: (877) 329-6722

Email: NSCC-CNAS@pwgsc.gc.ca

Canada



Building Service Requests

SR Number	5256506	Building ID	14303	Call Date	03 Jun 2019 11:09:42 AM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	1 / ROOM 113		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Room 113 toilet has problem flushing. Please investigate. Thank you				
SR Number	5257042	Building ID	14303	Call Date	03 Jun 2019 04:31:33 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	TOILETS		
Client	Polar Knowledge Canada (PKC)				
Action Requested	All the toilets in the main building are not flushing properly. They are gurgling and bubbling up.. Please investigate. Thank you.				
SR Number	5259674	Building ID	14303	Call Date	06 Jun 2019 01:11:02 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	4B - Roads and Grounds		
Service Requester		Floor/Area	EXT.		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please turn off all the outside lighting (lamp posts, decorative lights on building, etc) at the CHARS campus until August 31, 2019. Thank you				

Report ID 23002





Building Service Requests

SR Number	5262726	Building ID	14303	Call Date	11 Jun 2019 01:25:54 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2E - Architectural/Structural		
Service Requester		Floor/Area	2 / ROOM 202		
Client	Indigenous and Northern Affairs Canada				
Action Requested	Check the glass washer in the dirty glass room for leaks - Room 202				
SR Number	5263545	Building ID	14303	Call Date	12 Jun 2019 12:05:23 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	2H - Other Building Maintenance		
Service Requester		Floor/Area	1		
Client	Polar Knowledge Canada (PKC)				
Action Requested	The glass washer is still leaking. Please attend. ASAP. Thanks.				
SR Number	5263974	Building ID	14303	Call Date	12 Jun 2019 06:13:41 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	2 / LWR		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please have the women's washroom on the 2nd floor checked for a possible toilet blockage. Thanks.				

Report ID 23002





Building Service Requests

SR Number	5263982	Building ID	14303	Call Date	12 Jun 2019 06:26:52 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU			Priority	Normal
				Status	Work Completed
				Type	2C - HVAC
Service Requester		Floor/Area	1 / RM 137B COMPOST BATHROOM		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Client reports that the temprature needs to be decreased between 18-21 degrees. It is currently 28 degrees. Please attend, thanks.				

SR Number	5266549	Building ID	14303	Call Date	17 Jun 2019 03:10:04 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU			Priority	Normal
				Status	Work Completed
				Type	2C - HVAC
Service Requester		Floor/Area	2 / LWR 205		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Client reports that the temperature is too hot. Please adjust it. Thanks.				

SR Number	5266723	Building ID	14303	Call Date	17 Jun 2019 05:34:59 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU			Priority	Normal
				Status	Work Completed
				Type	2C - HVAC
Service Requester		Floor/Area	1 / COMPOST TOILET		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Compost Toilet room 135A temperature at 30.4 degrees, need to be lowered between 18 and 21 degrees. Thanks				

Report ID 23002





Building Service Requests

SR Number	5271111	Building ID	14303	Call Date	24 Jun 2019 01:20:38 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2H - Other Building Maintenance		
Service Requester		Floor/Area	1 / MRB MAIN DOORS		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please ensure MRB main doors are unlocked/open on Tues, Jul 2 and Wed, Jul 3 at 0800 and locked at 1645 on both days. Thanks.				

SR Number	5272444	Building ID	14303	Call Date	25 Jun 2019 06:46:24 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	1 / GCL		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Sewer gas smell in the GCL. Do the traps need to be primed? Thanks				

SR Number	5272471	Building ID	14303	Call Date	25 Jun 2019 07:36:50 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2H - Furnishings		
Service Requester		Floor/Area	1		
Client	Indigenous and Northern Affairs Canada				
Action Requested	Please check on the kitchen walk-in freezer (154C). Is not operating and reading 19 degrees (s/b -10). Thanks				

Report ID 23002





Building Service Requests

SR Number	5273327	Building ID	14303	Call Date	26 Jun 2019 05:54:35 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2C - HVAC		
Service Requester		Floor/Area	1		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please lower the set-point in the Equipment Storage Room (201) to 18 degrees.				
SR Number	5273987	Building ID	14303	Call Date	27 Jun 2019 01:52:40 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2G - Fire and Life Safety		
Service Requester		Floor/Area			
Client	Polar Knowledge Canada (PKC)				
Action Requested	The client is requesting a follow up to the June 26 fire alarm. Please advise of the cause, the fix and the activities to bring campus back on-line. Please action. Thanks				
SR Number	5275083	Building ID	14303	Call Date	28 Jun 2019 06:06:25 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	2C - HVAC		
Service Requester		Floor/Area	1 / SEVER ROOM 124		
Client	Polar Knowledge Canada (PKC)				
Action Requested	**UPDATED on 05/07/2019 17:12: The client called back to report this same issue, as per SP the request made today (SR#5279301) is a duplicate. They are working on repairing the issue. Thanks. ----- **UPDATED on 28/06/2019 18:09: The temperature is too hot in the server room. Please attend ASAP. Thanks. La température est trop chaude dans la salle des serveurs. Veuillez vérifier rapidement. Merci.				

Report ID 23002

Created 17 Aug 2020 09:26:30 PM GMT

16 of 49

Building Service Requests Version 3.5.0 - 17 Aug 2020. The controlled copy of this document is maintained electronically. All Paper copies are uncontrolled.



1-800-463-1850

Fax: (877) 329-6722

Email: NSCC-CNAS@pwgsc.gc.ca

Canada



Building Service Requests

SR Number	5276980	Building ID	14303	Call Date	03 Jul 2019 12:56:15 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	2 / LWR, ROOM 206		
Client	Polar Knowledge Canada (PKC)				
Action Requested	One toilet overflowed. Please attend ASAP. Thanks.				

SR Number	5279301	Building ID	14303	Call Date	05 Jul 2019 05:08:25 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Terminated
		Type	2C - HVAC		
Service Requester		Floor/Area	1 / MAIN SERVER ROOM 124		
Client	Polar Knowledge Canada (PKC)				
Action Requested	**WORK TERMINATED on 05/07/2019 17:14: As per SP , this is a duplicate of SR#5275083 which is still in progress. Please work terminate this request. Thanks. ----- The temperature is too hot in the server room (26.7C). Please attend ASAP. Thanks.				

SR Number	5279392	Building ID	14303	Call Date	05 Jul 2019 09:47:55 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Emergency	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	ENTIRE BLDG UNIT		
Client	Polar Knowledge Canada (PKC)				
Action Requested	**UPDATED on 05/07/2019 23:05: Called SP for update, he stated that he dispatch it out but has no other details and may not get updates for tonight. ----- Client reports that there is no water in the entire complex building. Gurgling sounds can be heard from the washrooms. Please attend, thanks.				

Report ID 23002

Created 17 Aug 2020 09:26:30 PM GMT

17 of 49

Building Service Requests Version 3.5.0 - 17 Aug 2020. The controlled copy of this document is maintained electronically. All Paper copies are uncontrolled.



1-800-463-1850

Fax: (877) 329-6722

Email: NSCC-CNAS@pwgsc.gc.ca

Canada



Building Service Requests

SR Number	5279552	Building ID	14303	Call Date	07 Jul 2019 10:30:20 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU			Priority	Urgent
				Status	Work Completed
				Type	2F - Plumbing
Service Requester		Floor/Area		KITCHEN LIGHTBOARD / TRIPLEX 9C	
Client	Indigenous and Northern Affairs Canada				
Action Requested	The client reports that there is a trouble on the lightboard, indicating that the sewage is high. Please attend ASAP. Thanks.				

SR Number	5280638	Building ID	14303	Call Date	08 Jul 2019 09:43:53 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU			Priority	Urgent
				Status	Work Completed
				Type	2H - Other Building Maintenance
Service Requester		Floor/Area			
Client	Polar Knowledge Canada (PKC)				
Action Requested	Client is running out of fresh water, low domestic water.. Please refill the water tank ASAP. Thanks.				

SR Number	5282458	Building ID	14303	Call Date	10 Jul 2019 02:09:04 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU			Priority	Urgent
				Status	Work Completed
				Type	2H - Other Building Maintenance
Service Requester		Floor/Area		1 / RM 141B	
Client	Polar Knowledge Canada (PKC)				
Action Requested	Freezer room, in the walking freezer there is excessive condensation on the exterior and water is running down to the floor. Thanks.				





Building Service Requests

SR Number	5282461	Building ID	14303	Call Date	10 Jul 2019 02:09:15 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2C - HVAC		
Service Requester		Floor/Area	2 / 201 AND247		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Reduce the temperature to 18 degrees. Please attend. Thanks.				
SR Number	5283108	Building ID	14303	Call Date	11 Jul 2019 11:28:25 AM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	1 / KITCHEN / NEAR 129		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Client reports there's a small leak coming from the faucet in this area. Please attend. Thanks .				
SR Number	5283572	Building ID	14303	Call Date	11 Jul 2019 05:13:36 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	2H - Furnishings		
Service Requester		Floor/Area	1 / ROOM 141B		
Client	Polar Knowledge Canada (PKC)				
Action Requested	The client reports that the freezer temperature is at -2 and should be at -20. Please attend ASAP. Thanks.				

Report ID 23002





Building Service Requests

SR Number	5283934	Building ID	14303	Call Date	12 Jul 2019 10:58:18 AM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU			Priority	Urgent
				Status	Work Completed
				Type	2H - Other Building Maintenance
Service Requester			Floor/Area	B / M005 (DOOR TO ELEVATORS)	
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please send security to unlock this door as a technician requires access. Thanks.				

SR Number	5284851	Building ID	14303	Call Date	15 Jul 2019 11:33:06 AM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU			Priority	Normal
				Status	Work Completed
				Type	4E - Security
Service Requester			Floor/Area	M / MAIN DOORS	
Client	Polar Knowledge Canada (PKC)				
Action Requested	Client is requesting to have the main doors of the building unlocked on July 15th - July 19th 2019. Please contact client for more details if needed. Please action. Thanks.				

SR Number	5285186	Building ID	14303	Call Date	15 Jul 2019 03:09:20 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU			Priority	Normal
				Status	Work Terminated
				Type	2F - Plumbing
Service Requester	Floor/Area			2 / 206 - MWR	
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please increase the water pressure. It's too low. Thanks.				





Building Service Requests

SR Number	5285351	Building ID	14303	Call Date	15 Jul 2019 05:52:25 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2C - HVAC		
Service Requester		Floor/Area	1 / NEAR 135A - WASHROOM		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Client reports that the temperature is too hot. Please adjust it. Thanks.				

SR Number	5286380	Building ID	14303	Call Date	16 Jul 2019 04:26:03 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	1 / ROOM 116		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Room 116: Men's toilet is blocked. Please unclog and verify all others since other toilets are gurgling. Thank you.				

SR Number	5286490	Building ID	14303	Call Date	16 Jul 2019 05:48:45 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	1 / COMM. KITCHEN		
Client	Polar Knowledge Canada (PKC)				
Action Requested	The first sink on the left in the multiple sink area: the drain from the sink / drain pipe connection leaks. Come and see client if needed. Thank you				

Report ID 23002





Building Service Requests

SR Number	5286499	Building ID	14303	Call Date	16 Jul 2019 05:59:18 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2E - Architectural/Structural		
Service Requester		Floor/Area	1 / DOOR 152.3		
Client	Polar Knowledge Canada (PKC)				
Action Requested	The door 152.3 (access to loading dock near security) sometimes does not latch properly and it is possible to re-enter the secured area without using an access card. Please repair it. Thank you.				
SR Number	5287544	Building ID	14303	Call Date	17 Jul 2019 05:37:09 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	BSMT / CRAWLSPACE		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Client is reporting a leak, please call client. SP is already aware, Thanks				
SR Number	5288343	Building ID	14303	Call Date	18 Jul 2019 03:50:36 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2H - Other Building Maintenance		
Service Requester		Floor/Area			
Client	Polar Knowledge Canada (PKC)				
Action Requested	MRB Access: Sat, Jul 20 Unlock/lock 0845-16:45 and Sun, Jul 21 Unlock/lock 08:45-14:00. Please call client if more details are required. Thanks.				





Building Service Requests

SR Number	5289222	Building ID	14303	Call Date	20 Jul 2019 10:29:45 AM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	7A		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Resident reports, they have run out of water.				

SR Number	5292120	Building ID	14303	Call Date	24 Jul 2019 08:16:16 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	UNIT 7A		
Client	Polar Knowledge Canada (PKC)				
Action Requested	No water coming out of the taps				

SR Number	5292374	Building ID	14303	Call Date	25 Jul 2019 09:55:18 AM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	2E - Architectural/Structural		
Service Requester		Floor/Area	B, 1 / CROSSPACE - KITCHENETTE		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Water is leaking from the ceiling. Please attend ASAP. Thanks.				





Building Service Requests

SR Number	5292669	Building ID	14303	Call Date	25 Jul 2019 01:23:55 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	2 / STAFF KITCHEN		
Client	Polar Knowledge Canada (PKC)				
Action Requested	**REDISPATCHED on 25/07/2019 13:25: **UPGRADED to Urgent on 25/07/2019 13:24: The small faucet in the kitchen sink runs continuously . Please attend. Thanks.				

SR Number	5293191	Building ID	14303	Call Date	26 Jul 2019 10:19:26 AM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2D - Electrical		
Service Requester		Floor/Area	2		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please restore the power in this area. Thanks.				

SR Number	5293455	Building ID	14303	Call Date	26 Jul 2019 02:12:59 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	2 / WSHRM 205		
Client	Polar Knowledge Canada (PKC)				
Action Requested	One toilet is plugged. Please unplug it. Thanks.				

Report ID 23002





Building Service Requests

SR Number	5294440	Building ID	14303	Call Date	29 Jul 2019 01:32:50 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	2C - HVAC		
Service Requester		Floor/Area	1 / LAN ROOM 124		
Client	Polar Knowledge Canada (PKC)				
Action Requested	The temperature is too hot in the server room (25C). Please attend ASAP. Thanks.				
SR Number	5295198	Building ID	14303	Call Date	30 Jul 2019 10:58:06 AM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	1B - Cleaning		
Service Requester		Floor/Area	1 / LAUNDRY ROOM		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please bring a box of powdered detergent and some dryer sheets to the second floor MRB laundry room. We will start using the machines soon. Thank you.				
SR Number	5295640	Building ID	14303	Call Date	30 Jul 2019 03:23:25 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	2 / 204		
Client	Polar Knowledge Canada (PKC)				
Action Requested	One toilet is plugged. Please unplug it. Please note that this is an accessibility related issue, thanks ----- Une toilette est bouchée. Veuillez le ou la déboucher. Veuillez noter que ceci concerne une requête relater à l'accessibilité, merci				

Report ID 23002

Created 17 Aug 2020 09:26:30 PM GMT

25 of 49

Building Service Requests Version 3.5.0 - 17 Aug 2020. The controlled copy of this document is maintained electronically. All Paper copies are uncontrolled.



1-800-463-1850

Fax: (877) 329-6722

Email: NSCC-CNAS@pwgsc.gc.ca

Canada



Building Service Requests

SR Number	5296329	Building ID	14303	Call Date	31 Jul 2019 12:38:43 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU			Priority	Normal
				Status	Work Completed
				Type	2C - HVAC
Service Requester		Floor/Area		1 / ROOM 135A / COMPOST TOILET	
Client		Polar Knowledge Canada (PKC)			
Action Requested		Client reports that the temperature is too hot (31.5C) and the radiator is on. Please adjust, thanks.			

SR Number	5297257	Building ID	14303	Call Date	01 Aug 2019 02:17:37 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU			Priority	Normal
				Status	Work Completed
				Type	2H - Other Building Maintenance
Service Requester		Floor/Area			
Client		Polar Knowledge Canada (PKC)			
Action Requested		Beginning Monday, Aug 5, the MRB main doors should now be unlocked daily, Mon to Fri (holidays excluded) at 0845 and locked nightly at 1645. Upcoming holidays include: Mon, Sept 2; Mon, Oct 14; Mon, Nov 11; and Wed & Thur Dec 25 & 26. Please note we are open and working this Mon, Aug 5. Thanks			

SR Number	5297665	Building ID	14303	Call Date	02 Aug 2019 10:27:00 AM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU			Priority	Normal
				Status	Work Completed
				Type	2F - Plumbing
Service Requester		Floor/Area		ALL FLOORS	
Client					
Action Requested		The sewage tank is full and the tank needs to be emptied, please do so.			

Report ID 23002





Building Service Requests

SR Number	5297714	Building ID	14303	Call Date	02 Aug 2019 11:03:10 AM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	UNIT 9B		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Client reports that the sewage light is on. Please investigate ASAP. Thanks.				
SR Number	5297851	Building ID	14303	Call Date	02 Aug 2019 01:00:09 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	1 / APTMT 9A		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Client reports that the sink in the kitchen is broken. Please repair it. Also, they reported that the sewage tank is very high and needs to be emptied. Please attend, thanks again.				
SR Number	5298960	Building ID	14303	Call Date	06 Aug 2019 01:54:36 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	1 / MAIN MWR		
Client	Polar Knowledge Canada (PKC)				
Action Requested	One urinal is plugged. Please unplug it. Thanks.				





Building Service Requests

SR Number	5299693	Building ID	14303	Call Date	07 Aug 2019 01:09:33 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2C - HVAC		
Service Requester		Floor/Area	1 / M-144		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please decrease the humidity level. It's too high. Thanks.				

SR Number	5300690	Building ID	14303	Call Date	08 Aug 2019 02:08:19 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2C - HVAC		
Service Requester		Floor/Area	1		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Need air compressor operational. Please attend to.				

SR Number	5301699	Building ID	14303	Call Date	11 Aug 2019 05:32:53 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	2C - HVAC		
Service Requester		Floor/Area	1 / M-144		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Cold Lab (M-144) is running warm at 16 degrees. This is above the program set-points. Please address.				

SR Number	5301705	Building ID	14303	Call Date	11 Aug 2019 08:41:22 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	1 / UNIT 9B		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Client reports that the septic tank light is indicating that it is full. Please attend ASAP. Thanks.				

Report ID 23002





Building Service Requests

SR Number	5302174	Building ID	14303	Call Date	12 Aug 2019 01:44:00 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	4E - Security		
Service Requester		Floor/Area	1 / EXT DOOR 1A		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Exterior door 1A card swipe is not working this morning. Please verify if it is an electrical issue. Thank you.				
SR Number	5304142	Building ID	14303	Call Date	14 Aug 2019 07:11:17 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2D - Electrical		
Service Requester		Floor/Area	1		
Client	Polar Knowledge Canada (PKC)				
Action Requested	As per client: Please confirm via return email the lighting schedule for M-109 (Multi-use Space).				
SR Number	5304638	Building ID	14303	Call Date	15 Aug 2019 12:29:23 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	1B - Cleaning		
Service Requester		Floor/Area	1		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please have all external garbage and debris near/around the FMB, MRB and Triplex units cleaned. Thanks.				
SR Number	5304695	Building ID	14303	Call Date	15 Aug 2019 01:08:01 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	1B - Cleaning		
Service Requester		Floor/Area	1		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please drop off two boxes of large garbage bags to Client by end of business day. Thanks.				

Report ID 23002





Building Service Requests

SR Number	5304845	Building ID	14303	Call Date	15 Aug 2019 02:51:57 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2H - Other Building Maintenance		
Service Requester		Floor/Area	1 / ROOM 110		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please close the access door to the crawl space by the end of today. Thank you.				
SR Number	5305442	Building ID	14303	Call Date	16 Aug 2019 01:43:39 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2D - Interior Lighting		
Service Requester		Floor/Area	2 / LWR		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please replace the flickering light in the women's washroom on the second floor of Main Research Building. Thank you.				
SR Number	5306410	Building ID	14303	Call Date	19 Aug 2019 01:36:18 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2C - HVAC		
Service Requester		Floor/Area	2 / ROOM 244 / ANALYTICAL LAB		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please increase the room's set point temperature by 2 degrees C. Thank you.				

Report ID 23002





Building Service Requests

SR Number	5306437	Building ID	14303	Call Date	19 Aug 2019 01:55:32 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2H - Other Building Maintenance		
Service Requester		Floor/Area	1		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Room M-141A: out of state, investigate and correct (back date to August 17, 2019).				
SR Number	5309150	Building ID	14303	Call Date	23 Aug 2019 03:02:36 AM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	2G - Fire and Life Safety		
Service Requester		Floor/Area			
Client	Polar Knowledge Canada (PKC)				
Action Requested	Client is reporting a fire alarm, and fire department was dispatched. False alarm, this is for report only. No action needed. Thanks				
SR Number	5310093	Building ID	14303	Call Date	26 Aug 2019 09:59:07 AM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	1B - Cleaning		
Service Requester		Floor/Area	1 / COMMERCIAL KITCHEN AREA		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please empty the two large garbage cans near the commercial kitchen. Thanks.				





Building Service Requests

SR Number	5313789	Building ID	14303	Call Date	30 Aug 2019 08:58:09 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	2C - HVAC		
Service Requester		Floor/Area	1 / COLD LAB		
Client	Polar Knowledge Canada (PKC)				
Action Requested	**ESCALATED on 30/08/2019 21:32: Client reports that the temperature is at -17C and should be at +4C in the lab. Please attend ASAP. Thanks.				

SR Number	5319522	Building ID	14303	Call Date	10 Sep 2019 06:30:30 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2D - Interior Lighting		
Service Requester		Floor/Area	1 / MULTI-USE SPACE		
Client	Polar Knowledge Canada (PKC)				
Action Requested	The lights do not appear to be coming on. Please verify them. Thanks.				

SR Number	5319548	Building ID	14303	Call Date	10 Sep 2019 07:04:45 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2C - HVAC		
Service Requester		Floor/Area	1 / ROOM 135A		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Client reports that the temperature is too hot (26C). Please adjust it. Thanks.				

Report ID 23002





Building Service Requests

SR Number	5322816	Building ID	14303	Call Date	16 Sep 2019 02:35:29 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2D - Electrical		
Service Requester		Floor/Area	1 / MRB		
Client	Polar Knowledge Canada (PKC)				
Action Requested	As per client, please check the lighting schedule. At 20:00 last night (Sunday) all the office lights in the MRB were on. Thanks.				
SR Number	5323954	Building ID	14303	Call Date	17 Sep 2019 08:02:00 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2H - Other Building Maintenance		
Service Requester		Floor/Area	1		
Client	Polar Knowledge Canada (PKC)				
Action Requested	As per client please ensure the MRB is unlocked on Sat, Sep 21 at 0800 and locked at 1300. The Kitikmeot Chamber of Commerce will be hosting their Annual General Meeting in the MRB Boardroom. Thanks.				
SR Number	5325474	Building ID	14303	Call Date	19 Sep 2019 03:24:24 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	2D - Electrical		
Service Requester		Floor/Area	1 / M-192.5 / FUMEHOODS		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please check the power to the breakers that lead into the fumehoods ASAP. Thanks.				





Building Service Requests

SR Number	5327104	Building ID	14303	Call Date	23 Sep 2019 01:18:12 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Acknowledged
		Type	2C - HVAC		
Service Requester		Floor/Area	1 / M-144		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please check on the Cold Lab. Set points are 2 to 7. Current reading is -17. The condenser unit is frozen and there is ice build-up. It may need to be shut down. Please attend ASAP. Thanks.				
SR Number	5328111	Building ID	14303	Call Date	24 Sep 2019 02:21:48 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2G - Fire and Life Safety		
Service Requester		Floor/Area	EXT		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please check on a faulty fire hydrant and advise what impact (if any) this has on the operations or on water supply to buildings. Client didn't provide the exact location of the fire hydrant, if any questions please contact the client. Thanks.				
SR Number	5328313	Building ID	14303	Call Date	24 Sep 2019 06:27:43 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	1		
Client	Polar Knowledge Canada (PKC)				
Action Requested	As per client, please have the hose disconnected and stored from the exterior sump pump connection on the south side of MRB. Thanks.				

Report ID 23002





Building Service Requests

SR Number	5330179	Building ID	14303	Call Date	26 Sep 2019 06:34:17 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2F - Plumbing		
Service Requester	Floor/Area				
Client	Polar Knowledge Canada (PKC)				
Action Requested	The water purification system (PWS-01) has a leak. Please attend to. Also, salt softener needs to be added ASAP.				
SR Number	5330568	Building ID	14303	Call Date	27 Sep 2019 12:08:24 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2C - HVAC		
Service Requester	Floor/Area 1				
Client	Polar Knowledge Canada (PKC)				
Action Requested	As per client " : The pressure monitor outside M-119.2 is not functioning" Please repair. Thanks.				
SR Number	5330991	Building ID	14303	Call Date	28 Sep 2019 04:48:05 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	2F - Plumbing		
Service Requester	Floor/Area B				
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please check on water softener equipment (Chem-Aqua ALT B) is showing ERROR. Thanks.				

Report ID 23002





Building Service Requests

SR Number	5330992	Building ID	14303	Call Date	28 Sep 2019 04:52:07 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	B		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please check on the Temperature Regulating Unit, it is making noises (unsure if operating properly). Reference: PT:MRB-Potable Water HWT-02 1/3rd Mod TCV-76 NODE: 22.1.03-UO-11 PNL: MNBC-M-LO-02. Thanks.				

SR Number	5331006	Building ID	14303	Call Date	28 Sep 2019 08:33:58 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	1B - Cleaning		
Service Requester		Floor/Area	B		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please have all water on the floor at various leaks mopped and the areas dried. Thanks.				

SR Number	5331056	Building ID	14303	Call Date	29 Sep 2019 02:17:20 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	B		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Client reports that water on the floor it may be coming from sump pump. Please attend, thank you				

Report ID 23002

Created 17 Aug 2020 09:26:30 PM GMT

36 of 49

Building Service Requests Version 3.5.0 - 17 Aug 2020. The controlled copy of this document is maintained electronically. All Paper copies are uncontrolled.



1-800-463-1850

Fax: (877) 329-6722

Email: NSCC-CNAS@pwgsc.gc.ca

Canada



Building Service Requests

SR Number	5331685	Building ID	14303	Call Date	30 Sep 2019 01:44:28 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	BSMT		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please switch over the sump pump lever to pump into the tank and not outside. Thanks.				
SR Number	5331694	Building ID	14303	Call Date	30 Sep 2019 01:52:02 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	1B - Cleaning		
Service Requester		Floor/Area	1		
Client	Polar Knowledge Canada (PKC)				
Action Requested	There is still greywater from sewage tank overflow on Sun on the floor. This should be mopped and cleaned ASAP. Thanks				
SR Number	5333053	Building ID	14303	Call Date	02 Oct 2019 12:26:33 AM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2E - Architectural/Structural		
Service Requester		Floor/Area	1		
Client	Polar Knowledge Canada (PKC)				
Action Requested	A wooden toe-cap for the circular staircase has come undone. Currently in Clients possession.				





Building Service Requests

SR Number	5337633	Building ID	14303	Call Date	08 Oct 2019 01:34:01 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2C - HVAC		
Service Requester		Floor/Area	1		
Client	Polar Knowledge Canada (PKC)				
Action Requested	The people in M-103.2 (office area) and M-117.3 (Business Incubation) are saying them areas are cold. It does appear as if the air coming from the floor vents is cool.				
SR Number	5342637	Building ID	14303	Call Date	16 Oct 2019 06:13:09 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2D - Electrical		
Service Requester		Floor/Area	1 / M-207		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Client reports a noise coming from an open electrical solenoid switch in the ceiling. Please investigate, thanks.				
SR Number	5344297	Building ID	14303	Call Date	18 Oct 2019 01:27:41 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	4B - Roads and Grounds		
Service Requester		Floor/Area	1		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Ice conditions between MRB and FMB could result in slip-and-fall by employees travelling between buildings. Please attend. Thanks.				

Report ID 23002

Created 17 Aug 2020 09:26:30 PM GMT

38 of 49

Building Service Requests Version 3.5.0 - 17 Aug 2020. The controlled copy of this document is maintained electronically. All Paper copies are uncontrolled.



1-800-463-1850

Fax: (877) 329-6722

Email: NSCC-CNAS@pwgsc.gc.ca

Canada



Building Service Requests

SR Number	5347591	Building ID	14303	Call Date	23 Oct 2019 07:52:18 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU			Priority	Normal
				Status	Acknowledged
				Type	2D - Interior Lighting
Service Requester		Floor/Area	1 / M-174.1, M-178 / AND F-121.2		
Client	Polar Knowledge Canada (PKC)				
Action Requested	There are burnt out light fixtures in M-174.1 and M-178. The same type of fixture continues to flicker in F-121.2. Please replace the bulbs. Thanks.				

SR Number	5350519	Building ID	14303	Call Date	28 Oct 2019 04:39:14 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU			Priority	Urgent
				Status	Work Completed
				Type	2H - Other Building Maintenance
Service Requester		Floor/Area	1		
Client	Polar Knowledge Canada (PKC)				
Action Requested	As per client "ERV system in the MRB has shut itself down due to a FreezeStat Alarm." Please attend ASAP. Thanks.				

SR Number	5350546	Building ID	14303	Call Date	28 Oct 2019 05:12:29 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU			Priority	Urgent
				Status	Work Completed
				Type	2C - HVAC
Service Requester		Floor/Area	1 / M-141A		
Client	Polar Knowledge Canada (PKC)				
Action Requested	The exterior thermostat for M-141A did not come back on line after the power outage. Please repair it ASAP. Thanks.				

Report ID 23002





Building Service Requests

SR Number	5351556	Building ID	14303	Call Date	29 Oct 2019 06:06:00 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2D - Electrical		
Service Requester		Floor/Area	1		
Client	Polar Knowledge Canada (PKC)				
Action Requested	The lights in the multi-use space have not come on. Please attend. Thanks.				
SR Number	5352699	Building ID	14303	Call Date	30 Oct 2019 05:40:33 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	2E - Architectural/Structural		
Service Requester		Floor/Area	1 / MRB		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please check ventilation air pressure in the MRB. A number of exterior doors are staying open. Thanks.				
SR Number	5357748	Building ID	14303	Call Date	06 Nov 2019 01:57:03 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	2E - Architectural/Structural		
Service Requester		Floor/Area			
Client					
Action Requested	Ticket for record purposes only: FMB main fuel tank FT-01 fuel disruption to boilers BO-01, BO-02, B0-03.				

Report ID 23002

Created 17 Aug 2020 09:26:30 PM GMT

40 of 49

Building Service Requests Version 3.5.0 - 17 Aug 2020. The controlled copy of this document is maintained electronically. All Paper copies are uncontrolled.



1-800-463-1850

Fax: (877) 329-6722

Email: NSCC-CNAS@pwgsc.gc.ca

Canada



Building Service Requests

SR Number	5366660	Building ID	14303	Call Date	19 Nov 2019 11:00:25 AM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	1 / 7-B		
Client	Polar Knowledge Canada (PKC)				
Action Requested	One toilet is plugged. Please unplug it as soon as possible. Permission to enter the unit granted. Thanks.				

SR Number	5369334	Building ID	14303	Call Date	21 Nov 2019 06:20:32 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2H - Other Building Maintenance		
Service Requester		Floor/Area	1 / FRONT ENTRANCE		
Client	Polar Knowledge Canada (PKC)				
Action Requested	As per client, "Main Research Building front entrance door to be kept unlocked until 8:00pm Mountain time, November 21st, 22nd and as well the whole week of the 25th-29th." Please attend. Thanks.				

SR Number	5369335	Building ID	14303	Call Date	21 Nov 2019 06:30:50 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	1B - Cleaning		
Service Requester		Floor/Area	1 / PUBLIC AREAS		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please perform a sweep of the public areas daily after closing. Thanks.				





Building Service Requests

SR Number	5384298	Building ID	14303	Call Date	12 Dec 2019 12:54:00 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2C - HVAC		
Service Requester		Floor/Area	1 / M-128		
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please attend to investigate and repair the noise from the radiator. Thank you.				
SR Number	5387719	Building ID	14303	Call Date	17 Dec 2019 05:06:28 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	4B - Roads and Grounds		
Service Requester		Floor/Area	EXT / RING ROAD		
Client	Polar Knowledge Canada (PKC)				
Action Requested	**REDIRECTED on 17/12/2019 17:42: Client reports the circumferential ring road on the CHARS Campus is not fully plowed clear of snow. Please clear the snow, thanks.				
SR Number	5389545	Building ID	14303	Call Date	19 Dec 2019 12:59:13 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	4B - Roads and Grounds		
Service Requester		Floor/Area	1		
Client	I				
Action Requested	**REDIRECTED on 19/12/2019 13:00: The exterior plugs/electrical receptacles between the loading docks on the north side of the MRB do not appear to be working. Please have them reset. Thanks.				

Report ID 23002

Created 17 Aug 2020 09:26:30 PM GMT

42 of 49

Building Service Requests Version 3.5.0 - 17 Aug 2020. The controlled copy of this document is maintained electronically. All Paper copies are uncontrolled.



1-800-463-1850

Fax: (877) 329-6722

Email: NSCC-CNAS@pwgsc.gc.ca

Canada



Building Service Requests

SR Number	5390521	Building ID	14303	Call Date	20 Dec 2019 12:30:31 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	1		
Client	Polar Knowledge Canada (PKC)				
Action Requested	The warning light for MRB sewage tank is on indicating it should be emptied. Please attend. Thanks.				
SR Number	5390528	Building ID	14303	Call Date	20 Dec 2019 12:33:08 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	4B - Roads and Grounds		
Service Requester		Floor/Area	BIKE SHELTER		
Client	Polar Knowledge Canada (PKC)				
Action Requested	The bike shelter light is not operational. It may be on the same circuit as the lamp posts in the area to the west between the FMB and the FSS. Please attend, thanks.				
SR Number	5390533	Building ID	14303	Call Date	20 Dec 2019 12:34:16 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	4B - Roads and Grounds		
Service Requester		Floor/Area	1		
Client	Polar Knowledge Canada (PKC)				
Action Requested	A number of electrical receptacles in the parking area to the east of the FMB are not operating. Please attend. Thanks				

Report ID 23002





Building Service Requests

SR Number	5392960	Building ID	14303	Call Date	30 Dec 2019 06:05:08 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	2C - HVAC		
Service Requester		Floor/Area	1 / SERVER ROOM M-173		
Client	Polar Knowledge Canada (PKC)				
Action Requested	The temperature is too hot in the server room (26C). BAS shows alarm issues with Chiller system. Please attend ASAP. Thanks.				
SR Number	5393236	Building ID	14303	Call Date	31 Dec 2019 12:02:19 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2H - Other Building Maintenance		
Service Requester		Floor/Area	1		
Client	Polar Knowledge Canada (PKC)				
Action Requested	The BACView for HP-01 and HP-02 is showing an alarm although neither of HP-01/02 are in alarm. Please attend. Thanks				
SR Number	5394375	Building ID	14303	Call Date	03 Jan 2020 10:54:32 AM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	4B - Roads and Grounds		
Service Requester		Floor/Area	1 / EAST PARKING AREAS / POSTS ON EAST SIDE		
Client	Polar Knowledge Canada (PKC)				
Action Requested	There is no electrical power to the posts in the east parking areas. Please attend. Thanks.				





Building Service Requests

SR Number	5412723	Building ID	14303	Call Date	28 Jan 2020 08:54:13 AM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU			Priority	Urgent
				Status	Work Completed
				Type	4B - Roads and Grounds
Service Requester		Floor/Area		EXT. / DRIVEWAY & PARKING LOT	
Client	Polar Knowledge Canada (PKC)				
Action Requested	Please remove the snow around the building. Thanks.				

SR Number	5418918	Building ID	14303	Call Date	05 Feb 2020 10:59:00 AM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU			Priority	Urgent
				Status	Work Completed
				Type	2F - Plumbing
Service Requester		Floor/Area		1	
Client	Polar Knowledge Canada (PKC)				
Action Requested	The sewage tank is slowly overflowing and water/effluent on the floor can create a hazard. Thanks				

SR Number	5421997	Building ID	14303	Call Date	10 Feb 2020 01:30:06 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU			Priority	Urgent
				Status	Work Completed
				Type	2D - Electrical
Service Requester		Floor/Area		1 / NORTH SIDE OF MRB	
Client	Polar Knowledge Canada (PKC)				
Action Requested	The client reports that the exterior electrical receptacles on the north side of the MRB between the loading docks are not working. Please attend. Thank you.				

Report ID 23002

Created 17 Aug 2020 09:26:30 PM GMT

45 of 49

Building Service Requests Version 3.5.0 - 17 Aug 2020. The controlled copy of this document is maintained electronically. All Paper copies are uncontrolled.



1-800-463-1850

Fax: (877) 329-6722

Email: NSCC-CNAS@pwgsc.gc.ca

Canada



Building Service Requests

SR Number	5431198	Building ID	14303	Call Date	23 Feb 2020 02:05:15 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	2H - Other Building Maintenance		
Service Requester		Floor/Area	BASEMENT		
Client	Polar Knowledge Canada (PKC)				
Action Requested	A small glycol leak was identified. Please attend. Thanks. Service providers have already been notified. Thanks.				

SR Number	5467816	Building ID	14303	Call Date	25 Jun 2020 03:12:22 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	1B - Cleaning		
Service Requester		Floor/Area	2 / ROOM M207 & 207A		
Client	Polar Knowledge Canada (PKC)				
Action Requested	**UPDATED on 25/06/2020 15:57: **UPDATED on 25/06/2020 15:54: The client is requesting enhanced cleaning for the whole main research building. Please attend ASAP. Thanks. ----- **REDISPATCHED on 25/06/2020 15:30: The client is requesting enhanced cleaning of these 2 rooms for the surfaces (high touch point). Please action ASAP. Thanks.				

SR Number	5474015	Building ID	14303	Call Date	20 Jul 2020 10:51:45 AM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Acknowledged
		Type	4E - Security		
Service Requester		Floor/Area			
Client	Polar Knowledge Canada (PKC)				
Action Requested	NOTIFICATION ONLY On July 10th at 2pm the security camera and security card programs could not connect to the server. On 7:13pm Polar Knowledge was informed. Thanks				

Report ID 23002

Created 17 Aug 2020 09:26:30 PM GMT

46 of 49

Building Service Requests Version 3.5.0 - 17 Aug 2020. The controlled copy of this document is maintained electronically. All Paper copies are uncontrolled.



1-800-463-1850

Fax: (877) 329-6722

Email: NSCC-CNAS@pwgsc.gc.ca

Canada



Building Service Requests

SR Number	5475780	Building ID	14303	Call Date	24 Jul 2020 05:09:25 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Acknowledged
		Type	2F - Plumbing		
Service Requester	Floor/Area				
Client	Indigenous and Northern Affairs Canada				
Action Requested	***Notification purpose only Water supply line to triplex 9 broke and began spraying large volumes of water between 9 and 10 am this morning. At 12 noon, to make repairs, fire prevention system was put off line. At 2 pm repairs were completed and fire system was put back on line. Incident report with additional details to follow. Thanks.				

SR Number	5477531	Building ID	14303	Call Date	30 Jul 2020 07:00:28 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Acknowledged
		Type	2H - Other Building Maintenance		
Service Requester	Floor/Area M				
Client	Polar Knowledge Canada (PKC)				
Action Requested	NOTICE OF RE-OCCUPANCY The client requests that the office space be prepared for the return of employees to the building. 1. Planned re-occupancy date: August 17 2. How many employees will be returning: 25 3. Which floor/area will be occupied: m				

SR Number	5477773	Building ID	14303	Call Date	31 Jul 2020 02:49:28 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2E - Architectural/Structural		
Service Requester	Floor/Area 2 / M-218				
Client	Polar Knowledge Canada (PKC)				
Action Requested	The door to room M-218 will not shut. Please repair it, thanks.				

Report ID 23002





Building Service Requests

SR Number	5478490	Building ID	14303	Call Date	04 Aug 2020 04:28:43 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	1B - Cleaning		
Service Requester		Floor/Area	1 / M-218		
Client	Polar Knowledge Canada (PKC)				
Action Requested	The new soap dispenser does not operate as intended or designed. Please repair it, thanks.				
SR Number	5479276	Building ID	14303	Call Date	06 Aug 2020 06:06:43 PM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Normal	Status	Work Completed
		Type	2F - Plumbing		
Service Requester		Floor/Area	2 / M-205/206		
Client	Polar Knowledge Canada (PKC)				
Action Requested	The water pressure at the sinks in the public washrooms is too low to allow for proper cleaning and washing of hands. Please increase the water pressure, thanks.				
SR Number	5481832	Building ID	14303	Call Date	16 Aug 2020 11:17:33 AM
Location	CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay, NU	Priority	Urgent	Status	Work Completed
		Type	2C - HVAC		
Service Requester		Floor/Area	2 / ROOM M-240 / MAIN ELECTRICAL ROOM		
Client	Polar Knowledge Canada (PKC)				
Action Requested	It's extremely warm in this room (31C). Please adjust it ASAP. Thanks.				

Report ID 23002

Created 17 Aug 2020 09:26:30 PM GMT

48 of 49

Building Service Requests Version 3.5.0 - 17 Aug 2020. The controlled copy of this document is maintained electronically. All Paper copies are uncontrolled.



1-800-463-1850

Fax: (877) 329-6722

Email: NSCC-CNAS@pwgsc.gc.ca

Canada



Building Service Requests

Report Criteria

Building: CHARS Complex - Main Research building (MRB) 1 Uvajuq Place Cambridge Bay NU

Client: All

Service Provider: All

Service Activity: All

Service Class: All

Start Date: 01 Apr 2019 12:00:00 AM

End Date: 16 Aug 2020 11:59:00 PM

Outstanding Service Requests Only: No

Contains data as of: All

Regular Hours Service Requests Only: No

After Hours Service Requests Only: No

Emergency Service Requests Only: All

