



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Réception des soumissions - TPSGC / Bid Receiving -
PWGSC
1550, Avenue d'Estimauville
1550, D'Estimauville Avenue
Québec
Québec
G1J 0C7

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Title - Sujet Revitalisation du havre Grosse-Île		
Solicitation No. - N° de l'invitation F3731-190013/A		Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client F3731-190013		Date 2020-09-04
GETS Reference No. - N° de référence de SEAG PW-\$QCM-041-17972		
File No. - N° de dossier QCM-0-43076 (041)	CCC No./N° CCC - FMS No./N° VME	
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2020-09-24		Time Zone Fuseau horaire Heure Avancée de l'Est HAE
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Enquiries to: - Adresser toutes questions à: Beauchesne, Sonia		Buyer Id - Id de l'acheteur qcm041
Telephone No. - N° de téléphone (418) 576-9803 ()		FAX No. - N° de FAX (418) 648-2209
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:		

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Issuing Office - Bureau de distribution
TPSGC-PWGSC
601-1550, Avenue d'Estimauville
Québec
Québec
G1J 0C7

Solicitation No. - N° de l'invitation F3731-190013/A	Amd. No. - N° de la modif. 003	Buyer ID - Id de l'acheteur QCM041
Client Ref. No. - N° de réf. du client 722497004	File No. - N° du dossier QCM-0-43076	CCC No./N° CCC - FMS No./N° VME

Amendment 003

This amendment is raised to:

- A. Extend the solicitation closing date
- B. Answer questions from bidders

A. Solicitation Closing Date

The closing date for solicitation F3731-190013/A, titled “Harbour revitalization Grosse-Île (Magdalen Islands)”, is extended from September 17, 2020 until **September 24, 2020 at 2:00 PM.**

If you have already submitted your bid, you are invited to send us your revisions, where necessary, by fax to 418-648-2209. Please indicate the solicitation number on all correspondence.

B. Questions and Answers


Q15. In the Specifications, the work shall be completed by March 31st, 2022, on the other hand the slabs shall be installed by March 31st, 2021. Can you confirm that the completion date of the work is in 2021 or 2020? Also, are there any delivery milestones to be observed or periods that certain work such as dredging is not allowed?

A15.

1. Regarding the construction of concrete slabs, the requirement of March 31, 2021 is withdrawn. Note that if it is precast slabs, the manufacture plant must comply with CAN / CSA A 23.4.
2. Maritime work (in water) will be prohibited between April 15th and August 15th in order to not disturb fishing activities and to respect environmental constraints (July 16th to August 10th);
3. More specifically, dredging work will be prohibited in the entrance channel between July 16th and August 10th, i.e. during the period of maximum concentration of American lobster and rock crab larvae;
4. Land works will be permitted during this period (between April 15th and August 15th) but within the limits of the construction site.

Q16. Is it possible to have more details on the existing floating docks system that is to be removed? (anchor blocks on the sea bottom and the number / cables / etc ...)

A16. The floating docks with blocks and chains to be handed over to Departmental Representative is made up of 3 series of 2 anchor blocks spaced about 10 m from the floating dock line (see sketch on next page)



Q17. About precast concrete slabs.

Our suppliers tell us that the slabs requested do not have enough steel reinforcement to withstand the constraints of transport.

With 6.096m in length, it would take two rows of steel and a little more thickness to keep the 2 rows apart.

The other option would be to cut the slabs in half to make 3.048m sections
Kindly validate the design and specify the requirements.

A17. The use of precast slabs of the same dimensions had been carried out without problem in the past for other projects in the Magdalen Islands. So adapt handling and transportation methods in order to not damage precast slabs.

Q18. In order to be able to validate the conditions that may influence the execution of the work and optimize our service offer, a site visit must be carried out.

However, the flights and prerequisite for offer implies a certain additional time to prepare our service offer.

Therefore, we ask you to extend tender period of ± 3 days.

A18. Please see section A.

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED