



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Bid Receiving - PWGSC / Réception des soumissions -  
TPSGC

11 Laurier St./11 rue Laurier

Place du Portage, Phase III

Core 0B2 / Noyau 0B2

Gatineau, Québec K1A 0S5

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**

Raison sociale et adresse du  
fournisseur/de l'entrepreneur

**Issuing Office - Bureau de distribution**

Construction Services Division/Division des services de  
construction

140 O'Connor Street

140, rue O'Connor

Ontario

Ottawa

K1A 0S5

<b>Title - Sujet</b> Construction- MCDC Roof Replacement	
<b>Solicitation No. - N° de l'invitation</b> EP076-210297/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b> 20210297	<b>Date</b> 2020-09-04
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$\$FG-374-79003	
<b>File No. - N° de dossier</b> fg374.EP076-210297	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2020-09-09</b>	
<b>Time Zone</b> Fuseau horaire Eastern Daylight Saving Time EDT	
<b>F.O.B. - F.A.B.</b>	
<b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Vani-Machado , Alba	<b>Buyer Id - Id de l'acheteur</b> fg374
<b>Telephone No. - N° de téléphone</b> (873) 355-4048 ( )	<b>FAX No. - N° de FAX</b> ( ) -
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> Raison sociale et adresse du fournisseur/de l'entrepreneur	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
EP076-210297/A

Amd. No. - N° de la modif.  
002

Buyer ID - Id de l'acheteur  
FG374

Client Ref. No. - N° de réf. du client  
R.108750.002

File No. - N° du dossier  
FG374 EP076-210297

CCC No./N° CCC - FMS No./N° VME

---

**The following changes to the tender documents are effective immediately. This amendment will form part of the contract documents.**

---

Amendment 002 is issued for the following:

- (1) Issue Addendum 1

**ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME**

Solicitation No. - N° de l'invitation  
EP076-210297/A

Amd. No. - N° de la modif.  
002

Buyer ID - Id de l'acheteur  
FG374

Client Ref. No. - N° de réf. du client  
R.108750.002

File No. - N° du dossier  
FG374 EP076-210297

CCC No./N° CCC - FMS No./N° VME

---

## **Addendum 1**

The following changes in the bid documents are effective immediately. This addendum will form part of the contract documents.

**DRAWINGS****1. Drawing ME1, General Notes:****.1 ADD** General Note 8 to read:

Disconnect the existing Liebert rooftop condenser unit during the roof replacement construction period. Disconnect the refrigerant piping and all associated accessories. Provide temporary air conditioner units for building data center that current using Liebert indoor unit and connect to roof mounted Liebert condensing unit. Including attendance, setup and maintenance. Provide temporary power supply 208V, 50A, 1ph and safety 60A, 1ph weatherproofed disconnects for temporary air conditioner units. Maintain strict supervision of operation of temporary cooling equipment to:

- Conform with applicable codes and standards.
- Enforce safe practices.
- Prevent abuse of services.

**.2 ADD** General Note 9 to read:

Rental portable air conditioner units with total 15 Tons cooling capacity. Rental shall include delivery to site, start-up, monthly inspections, and maintenance. Provide temporary duct (3-150Ø), condensing drain piping and all associated accessories as required for the portable air conditioner units. Rental to be carried for entire roof replacement period. Provide all field services required for installation and connection.

**.3 ADD** General Note 10 to read:

Upon completion of roof replacement, reinstate existing Liebert condensing unit with a full operating charge of refrigerant (R-22) and make fully functional. Contractor shall be responsible for the following:

- Disengage and remove all temporary duct, piping, and wiring etc.
- Remove rental portable air conditioners from data center and clean up the space.

**End of Addendum No. 01**