



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Bid Receiving - PWGSC / Réception des soumissions -  
TPSGC

11 Laurier St./11 rue Laurier  
Place du Portage, Phase III  
Core 0B2 / Noyau 0B2  
Gatineau, Québec K1A 0S5

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**

Construction Services Division/Division des services de  
construction  
140 O'Connor Street  
140, rue O'Connor  
Ontario  
Ottawa  
K1A 0S5

<b>Title - Sujet</b> Construction- MCDC Roof Replacement	
<b>Solicitation No. - N° de l'invitation</b> EP076-210297/A	<b>Amendment No. - N° modif.</b> 003
<b>Client Reference No. - N° de référence du client</b> 20210297	<b>Date</b> 2020-09-08
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$\$\$FG-374-79003	
<b>File No. - N° de dossier</b> fg374.EP076-210297	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2020-09-09</b>	<b>Time Zone Fuseau horaire Eastern Daylight Saving Time EDT</b>
<b>F.O.B. - F.A.B.</b>	
<b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Vani-Machado , Alba	<b>Buyer Id - Id de l'acheteur</b> fg374
<b>Telephone No. - N° de téléphone</b> (873) 355-4048 ( )	<b>FAX No. - N° de FAX</b> ( ) -
<b>Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
EP076-210297/A

Amd. No. - N° de la modif.  
003

Buyer ID - Id de l'acheteur  
FG374

Client Ref. No. - N° de réf. du client  
R.108750.002

File No. - N° du dossier  
FG374 EP076-210297

CCC No./N° CCC - FMS No./N° VME

---

**The following changes to the tender documents are effective immediately. This amendment will form part of the contract documents.**

---

Amendment 003 is issued for the following:

- (1) Issue Addendum 2

**ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME**

Solicitation No. - N° de l'invitation  
EP076-210297/A

Amd. No. - N° de la modif.  
003

Buyer ID - Id de l'acheteur  
FG374

Client Ref. No. - N° de réf. du client  
R.108750.002

File No. - N° du dossier  
FG374 EP076-210297

CCC No./N° CCC - FMS No./N° VME

---

## **Addendum 2**

MCDC Roof Replacement Questions  
Solicitation – EP076-210297

<p><b>Q1</b> - Could you confirm if this project is to close at the address mentioned? If so, do we need an electronic bond instead of a physical bond?</p>	<p><b>A1</b> – Bid as per solicitation documents. Refer to SI05 and SI06. Bids may be submitted using the epost Connect service provided by Canada Post Corporation. A bid bond may be submitted in an electronic or digital format if it meets the criteria detailed under 2.2 in SI05.</p>
<p><b>Q2</b> - Would U-flow connection drains be considered for this project due to the specifics of the building? If not, we will need photos of the interior. (The plumber may ask to visit the site.)</p>	<p><b>A2</b> – Bid as per contract documents. Refer to detail 14/A4. All drains are to have mechanical connections. A drain will be switched to a U-flow connection if an area is not accessible. Photos and additional site visits will not be provided.</p>
<p><b>Q3</b> - Is there work to be done on the skylight located at Roof Area 101?</p>	<p><b>A3</b> - Bid as per contract documents. Refer to details 4/A3 and 24/A6. All glass, glazing gaskets, seals, spacers, and flashing are to be replaced on both the upper and lower skylights, with all existing framing to be retained and cleaned. The vertical wall between both skylights is not included in the glass replacement, but all glass perimeters are to be cap beaded with silicone.</p>
<p><b>Q4</b> - Can you identify the location of the skylight at Roof Area 201 which will not be modified?</p>	<p><b>A4</b> - Bid as per contract documents. Refer to details 4/A3, 5/A3, 24/A6, 25/A7, &amp; 26/A7. The vertical wall between both skylights is not included in the glass replacement, but all glass perimeters are to be cap beaded with silicone.</p>
<p><b>Q5</b> - Would it be possible to clarify the scope of work for the skylights. Roof plan states to change all waterproofing items but details and specifications are showing full replacement of glass and everything else except the frame. Also, is it both skylights and all elevations?</p>	<p><b>A5</b> - Bid as per contract documents. Refer to details 4/A3 and 24/A6. All glass, glazing gaskets, seals, spacers, and flashing are to be replaced on both the upper and lower skylights, with all existing framing to be retained and cleaned. The vertical wall between both skylights is not included in the glass replacement, but all glass perimeters are to be cap beaded with silicone.</p>