



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Travaux publics et Services gouvernementaux
Canada
Place Bonaventure, portail Sud-Oue
800, rue de La Gauchetière Ouest
7e étage, suite 7300
Montréal
Québec
H5A 1L6
FAX pour soumissions: (514) 496-3822

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Travaux publics et Services gouvernementaux Canada
Place Bonaventure, portail Sud-Oue
800, rue de La Gauchetière Ouest
7e étage, suite 7300
Montréal
Québec
H5A 1L6

Title - Sujet Remplacement des chaudières	
Solicitation No. - N° de l'invitation EF236-210581/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client R.094470.001	Date 2020-09-08
GETS Reference No. - N° de référence de SEAG PW-\$MTC-035-15800	
File No. - N° de dossier MTC-0-43064 (035)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2020-09-15	Time Zone Fuseau horaire Heure Avancée de l'Est HAE
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lussier, Joël	Buyer Id - Id de l'acheteur mtc035
Telephone No. - N° de téléphone (514) 708-3582 ()	FAX No. - N° de FAX (514) 496-3822
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

INVITATION TO TENDER

Replacement boilers at Port-Cartier Institution.

This amendment 004 of the solicitation is raised for :

- **Questions and Answers from bidders**

Questions / Answers :

- No 01 : Supply of direct expansion coolers can be found on drawing M32 (plumbing-heating), in the description, it is mentioned that they are supplied by the ventilation contractor. In the nature of heating-cooling work (23 05 00.01 →1.10.10), it seems that the heating-cooling contractor must provide them. In the nature of the ventilation works (23 05 00.02 →1.09), there is nothing concerning their supply. Could you validate who should provide them.
 - o The ventilation contractor must provide the condenser as prescribed in the specification table of drawing M32. The precision concerning the separate condensers in section 23 05 00.01 article 1.10.10 is used only to specify the type of equipment connected to the chiller.
- No 02; Is it possible to postpone the submission of the tender. We have difficulty receiving prices from suppliers. Thank you.
 - o Yes, date to be confirmed with the client
- On page 1 of addendum ME-02 it indicates that the bidder must include an amount of \$10,000 for asbestos work. Which bidder(s) should include this amount? Is it the general contractor, the ventilation, the plumbing division?
 - o This amount is the responsibility of the general contractor.
- In drawing M44, note #5, we ask for non-return valves on the dryer ducts. Usually due to the risk of lint buildup on the valve, a lint filter is also added to the duct. Is this required?
 - o Not required at this time
- I could not find on the existing plans, the ventilation system #1@6 extras on drawing M42. Can you locate these 6 systems and provide us with details on them?
 - o These mechanical rooms are on the second floor. These rooms are visible on the key plan. Also on drawing M46, the dimensions of the vapor distributors are indicated in the table of humidifiers.

All other terms and conditions of the original solicitation remains unchanged