



## RETURN BIDS TO:

## RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution  
Public Works and Government Services Canada - Pacific  
Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Tower and Concrete Foundations	
<b>Solicitation No. - N° de l'invitation</b> F1705-200011/A	<b>Amendment No. - N° modif.</b> 003
<b>Client Reference No. - N° de référence du client</b> F1705-200011	<b>Date</b> 2020-09-14
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-019-8822	
<b>File No. - N° de dossier</b> PWY-0-43067 (019)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2020-09-17</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Pacific Daylight Saving Time PDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Ngan, Ken (PWY)	<b>Buyer Id - Id de l'acheteur</b> pwy019
<b>Telephone No. - N° de téléphone</b> (604) 671-0219 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> DFO – Telegraph Cove, BC	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
F1705-200011/A  
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.  
003  
File No. - N° du dossier  
pw-0-43067

Buyer ID - Id de l'acheteur  
pw019  
CCC No./N° CCC - FMS No/ N° VME

---

This Solicitation Amendment 003 is raised to incorporate responses to additional questions received.

Q5.) Although the specifications say no fires, would it be acceptable to use a woodstove for heat?

A5.) This is acceptable provided provincial regulations are met.

Q6.) The specifications are written favouring ready-mix batching off site. What provisions/allowances, if any, could be made for testing concrete batched on site?

A6.) For on site concrete batching, CCG will permit the contractor to sample concrete, test air content and slump, record concrete age, and cast cylinders for compressive tests provided that the person performing the work has been adequately trained and follows the proper procedures outlined in CSA A23.2. Contractor to submit proof of training for CCG acceptance. CCG may choose to monitor the procedure. Cylinders are to be sent to an Independent Testing Agency for testing.

Q7.) The specifications call for, "Each batch of concrete is to be sampled." Does this mean every truckload, or every pour? Is there a minimum threshold for small pours?

A7.) This means every truckload, or every batch mixed on site. If multiple ready-mix trucks are used for a single pour, a random selection of trucks will be made. The number of trucks selected will be determined based on the number loads. If the Contractor can demonstrate consistent good results, CCG may remove the requirement of testing concrete for the solar panel foundations, stair landings, and waveguide bridge foundations; however, the Contractor must be prepared to test all concrete as indicated.

**All other terms and conditions remain unchanged.**