



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Tower and Concrete Foundations	
Solicitation No. - N° de l'invitation F1705-200011/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client F1705-200011	Date 2020-09-14
GETS Reference No. - N° de référence de SEAG PW-\$PWY-019-8822	
File No. - N° de dossier PWY-0-43067 (019)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2020-09-17	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ngan, Ken (PWY)	Buyer Id - Id de l'acheteur pwy019
Telephone No. - N° de téléphone (604) 671-0219 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO – Telegraph Cove, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
F1705-200011/A
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.
003
File No. - N° du dossier
pw-0-43067

Buyer ID - Id de l'acheteur
pw019
CCC No./N° CCC - FMS No/ N° VME

Les documents français seront disponibles sur demande.

This Solicitation Amendment 003 is raised to incorporate responses to additional questions received.

Q5.) Although the specifications say no fires, would it be acceptable to use a woodstove for heat?

A5.) This is acceptable provided provincial regulations are met.

Q6.) The specifications are written favouring ready-mix batching off site. What provisions/allowances, if any, could be made for testing concrete batched on site?

A6.) For on site concrete batching, CCG will permit the contractor to sample concrete, test air content and slump, record concrete age, and cast cylinders for compressive tests provided that the person performing the work has been adequately trained and follows the proper procedures outlined in CSA A23.2. Contractor to submit proof of training for CCG acceptance. CCG may choose to monitor the procedure. Cylinders are to be sent to an Independent Testing Agency for testing.

Q7.) The specifications call for, "Each batch of concrete is to be sampled." Does this mean every truckload, or every pour? Is there a minimum threshold for small pours?

A7.) This means every truckload, or every batch mixed on site. If multiple ready-mix trucks are used for a single pour, a random selection of trucks will be made. The number of trucks selected will be determined based on the number loads. If the Contractor can demonstrate consistent good results, CCG may remove the requirement of testing concrete for the solar panel foundations, stair landings, and waveguide bridge foundations; however, the Contractor must be prepared to test all concrete as indicated.

All other terms and conditions remain unchanged.