



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works & Government Services
Canada/Réception des soumissions Travaux publics et
Services gouvernementaux Canada

1713 Bedford Row

Halifax, N.S./Halifax, (N.E.)

Halifax

Nova Scotia

B3J 1T3

Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions

1713 Bedford Row

Halifax, N.S./Halifax, (N.E.)

Halifax

Nova Scot

B3J 1T3

| | |
|---|---|
| Title - Sujet BIO Ellis Lab Roof | |
| Solicitation No. - N° de l'invitation EB144-210747/A | Amendment No. - N° modif. 001 |
| Client Reference No. - N° de référence du client EB144-21-0747 | Date 2020-09-15 |
| GETS Reference No. - N° de référence de SEAG PW-SPWA-405-6038 | |
| File No. - N° de dossier PWA-0-84038 (405) | CCC No./N° CCC - FMS No./N° VME |
| Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2020-09-30 | Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT |
| F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/> | |
| Address Enquiries to: - Adresser toutes questions à: Kendell (PWA), Byron | Buyer Id - Id de l'acheteur pwa405 |
| Telephone No. - N° de téléphone (902) 497-5345 () | FAX No. - N° de FAX (902) 496-5016 |
| Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: | |

Instructions: See Herein

Instructions: Voir aux présentes

| | |
|--|--|
| Delivery Required - Livraison exigée | Delivery Offered - Livraison proposée |
| Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur | |
| Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur | |
| Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie) | |
| Signature | Date |

Solicitation Amendment 001 is being raised to extend the Solicitation Period, offer an Optional Site Visit and answer bidder questions, as follows:

Refer to Solicitation Front Page:

Solicitation closing date:

Delete: 17 September, 2020

Insert: 30 September, 2020

Questions and Answers:

Question 1: After reviewing the specification, it was noticed that it calls for a torched on base and cap. Would it be possible to price the project as an adhered system with a torch on cap in the field but cold applied at the perimeter (our firm's standard on re-roof)? We prefer to explore options that remove the open flame from parapets and any possible openings.

Answer 1: As an alternative to the specified roof system, it is acceptable to use a cold applied adhesive as specified to install the base and cap sheet flashing on parapets and curbs in lieu of torch applied membranes provided installation is performed to manufacturer's recommendations and is fully warranted. Flashing membranes remain as specified with the exception of facers to suit adhesive application.

Optional Site Visit:

Bidders may visit the site between the hours of 10:00 am and 12:00 pm (ADT) on Tuesday, September 22nd, 2020 by contacting Vanessa.Morrison@pwgsc-tpsgc.gc.ca. Please contact before 2:00 pm (ADT) on Monday, September 21st, 2020. Bidders are to meet at the BIO Jetty Gate by following Baffin Blvd to the Jetty area (NOT the main entrance of BIO as per usual site visits). Bidders MUST bring a printed copy the Pre-Screening Questionnaire below and sign the document at the time of entry to the facility. Failure to provide the Questionnaire for each individual visit will preclude the bidders from accessing the site.

Contractors will be escorted to the site for a period of 30-45 mins in groups of no more than 4 on a first come first serve basis. **A maximum of 2 representatives** from each company may attend. **All attendees must wear a mask at all times.**

No questions will be answered on the site tour. All tender questions MUST be sent to the Supply Officer, Byron.Kendell@pwgsc-tpsgc.gc.ca.

Generic COVID requirements for a bidders visit are below.

- Proponents will be subject to a pre-screening upon entering the facility. Please see pre-screening questions below.
- While on site proponents must follow social distancing requirements of separation of at least 2m. Where separation is not possible masks must be worn.
- Proponents must follow all on site signage (i.e. one way corridors, elevator capacity limits etc.)

Pre-Screening Questionnaire (TO BE PRINTED AND SIGNED ON THE DAY OF THE SITE TOUR)

1. Are you now, or within the past 14 days, experiencing any of the following symptoms:

- Fever
- Cough
- Difficulty Breathing
- Fatigue
- Pneumonia in Both Lungs

2. Within the past 14 days, have you travelled outside of the Atlantic Provinces or internationally?

3. Within the past 14 days, have you been in close contact with anyone who has a presumptive or positive case of COVID19 or who is symptomatic? This includes caring for anyone in quarantine, exhibiting COVID-19 symptoms, waiting for presumptive test results, etc.

By answering "yes" to any screening questions, or presenting with a fever, you will NOT be granted access to the facility.

All other terms and conditions remain the same.