



September 16th 2020

RFP 9F030-20200101

Replacement, repair and excavation work on an as needed basis at the Canadian Space Agency (CSA) at St-Hubert

First series of questions and answers

Question 1

Articles 1.3 and 2.4 of the tender form

What must be included as equipment, labour? Example 1 team of 5 people, 2 pieces of equipment or other?

Answer 1

Provide at least one breakage repair team, i.e. one operator, 2 workers, a foreman, a truck driver and any other manpower required according to the working method.

Question 2

How deep is your water system?

Answer 2

The depth is about 2 meters.

Question 3

In appendix C - Article 1.0 Watermain - Repair of an aqueduct leak - line I) the repair of surfaces damaged by the work when required

It is virtually impossible to evaluate this work in an hourly rate not knowing the repair in question; concrete, asphalt turf; the hourly rate will become completely illogical.

Example: Sidewalk repairs at \$200.00/m² over an area of 10m² = \$2,000.00 for an 8-hour job, so for the repair only, provide \$250.00/hour for the sidewalk, and the water leak is not in the calculation.

Answer 3

The contractor must ensure that the excavation is backfilled to the projected level of infrastructure or topsoil. The repair of surface infrastructure such as paving or turf will not be included in this item 1.3 of the tender form.

Question 4

The characterization of soils is not mentioned in any document. Must we plan for it?
No items in the tender form for the disposal of contaminated soil? Do you have contaminated soil?

Answer 4

The excavation surplus will be kept on the site. The contractor will be responsible for transporting materials to the locations designated by the agency.

Question 5

Article 4.0 Equipment of the tender form
Must we plan for equipment mobilization within the expected quantities?

Answer 5

The hourly rates should include equipment mobilization. In addition, the number of hours to invoice corresponds to the number of hours of operation.

Question 6

Tender form - Article 5.0 List of Equipment and Labour
5.3 Various equipment - In what circumstances will various trench box equipment be paid for if in article 1.0 Water works, shoring up must be provided?

Answer 6

Currently, there is no specific work planned that requires a trench box. That's why the item is in the optional section.