

## CLARIFICATIONS

### Questions and Responses:

- 1) Q: Can you provide more clarity on the grating that is specified as you cannot get swagged pressure locked galvanized grating. I believe this grating only comes in aluminum.  
R: Grating was changed from Metal to FRP in addendum 1.
- 2) Q: Is the grating to be slip resistant?  
R: The Grating specified in Addendum 1 calls for slip resistant top surface.
- 3) Q: Is FRP grating an option?  
R: Grating was changed from Metal to FRP in addendum 1.
- 4) Q: Are kickplates required for the stair treads? If so, can you please provide a detail.  
R: Kickplates are required. See attached addendum #2.