



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

| | |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------|
| Title - Sujet Strengthening Bridge Design | |
| Solicitation No. - N° de l'invitation EZ899-210470/A | Amendment No. - N° modif. 006 |
| Client Reference No. - N° de référence du client | Date 2020-09-22 |
| GETS Reference No. - N° de référence de SEAG PW-\$PWY-019-8812 | |
| File No. - N° de dossier PWY-0-43047 (019) | CCC No./N° CCC - FMS No./N° VME |
| Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2020-09-24 | Time Zone Fuseau horaire Pacific Daylight Saving Time PDT |
| F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/> | |
| Address Enquiries to: - Adresser toutes questions à: Ngan, Ken (PWY) | Buyer Id - Id de l'acheteur pwy019 |
| Telephone No. - N° de téléphone (604) 671-0219 () | FAX No. - N° de FAX (604) 775-6633 |
| Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: PWGSC - Lower Liard River Bridge, km 763.3 – Alaska Highway, BC | |

Instructions: See Herein

Instructions: Voir aux présentes

| | |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------|
| Delivery Required - Livraison exigée | Delivery Offered - Livraison proposée |
| Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur | |
| Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur | |
| Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie) | |
| Signature | Date |

Solicitation No. - N° de l'invitation
EZ899-210470/A
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.
006
File No. - N° du dossier
pwy-0-43047

Buyer ID - Id de l'acheteur
pwy019
CCC No./N° CCC - FMS No/ N° VME

This Solicitation Amendment 006 is raised to incorporate response to an additional question received.

Q83.) In addendum #2, answer 55 states two coat system will be permitted for all steel surface that are in full contact and bolted and answer 29 states all steel surfaces for both existing and new steel should have a surface profile of 50 to 100 microns and be free of corrosion. Is there a specific slip class required for the faying surfaces? Is a sharp angular blast-profile required in the faying surface?

A83.) No specific slip class is required for faying surfaces. If an existing faying surface has local corrosion, a powered cleaning is required on the existing surface as specified in the drawings.

All other terms and conditions remain unchanged.