



1
M1.0

SUBBASEMENT MECHANICAL PLAN
SCALE: 1 : 50

KEY NOTES

- EXISTING DIESEL FUEL PIPING TO REMAIN. DEMOLISH EXPOSED ABANDONED HEAT TRACING SERVING THE DIESEL FUEL PIPE. DEMOLISH APPROXIMATELY 30 FEET OF EXPOSED HEAT TRACING. CONFIRM EXACT LENGTH ON SITE.
- CAP PIPE AT THIS LOCATION.
- DEMOLISH EXPOSED, SURFACE MOUNTED PIPING AND VALVES. PIPE IS ASSUMED TO BE INACTIVE.
- DISCONNECT PORTION OF EXISTING PIPING AND HOSE BIBBS LOCATED ON THIS FACE OF THE WALL.
- RECONNECT PIPING AND HOSE BIBBS TO EXISTING PIPING ON THIS FACE OF THE WALL. MODIFY AND EXTEND PIPING AS NEEDED.

DEMOLITION GENERAL NOTES

- PROTECT EXISTING MATERIALS, EQUIPMENT, AND SYSTEMS WHICH ARE NOT TO BE DEMOLISHED.
- CONDUCT DEMOLITION TO MINIMIZE INTERFERENCE WITH OCCUPIED BUILDING AREAS.
- CAREFULLY DISMANTLE EXISTING MECHANICAL EQUIPMENT TO BE REMOVED OR RELOCATED. TEMPORARILY DISCONNECT, REMOVE, AND REINSTALL EXISTING EQUIPMENT, PIPING, DUCTWORK, AND SIMILAR ITEMS, WHICH INTERFERE WITH THE NEW INSTALLATION AFTER COMPLETION OF NEW WORK OR OF EXISTING INSTALLATIONS TO BE DEMOLISHED. STORE EQUIPMENT AND MATERIALS ON THE PREMISES AS DIRECTED BY THE OWNER.
- DEMOLISH IN AN ORDERLY AND CAREFUL MANNER. REMOVE DEMOLISHED MATERIALS FROM SITE EXCEPT WHERE SPECIFICALLY NOTED OTHERWISE. UPON COMPLETION OF WORK, LEAVE AREAS IN CLEAN CONDITION.
- ALL USABLE SALVAGED EQUIPMENT AND MATERIALS SHALL REMAIN THE PROPERTY OF THE OWNER UNLESS SPECIFICALLY NOTED OTHERWISE.
- FIRESTOP ALL MECHANICAL PENETRATIONS THROUGH FIRE-RATED FLOOR AND WALL ASSEMBLIES WHERE PIPES OR DUCTS WERE REMOVED. SEE ARCHITECTURAL DRAWINGS FOR LOCATION AND TYPE OF RATINGS.
- THE ABANDONMENT OF EXISTING EQUIPMENT AND MATERIAL IN PLACE IS NOT ACCEPTABLE. ALL REDUNDANT SERVICES ARE TO BE REMOVED BACK TO ACTIVE MAINS, WHICH SHALL THEN BE CAPPED AT EXISTING POINT OF CONNECTION.

LINE TYPE LEGEND

	EXISTING
	DEMOLISHED

PLUMBING SYMBOLS

	PIPE RISE
	PIPE DROP
	KEY NOTE
	DEMOLITION NOTE
	DRAWING HEADER

Public Works and
Government Services
Canada

Travaux publics et
Services gouvernementaux
Canada

REAL PROPERTY SERVICES
Western Region
SERVICES IMMOBILIERS
Région de l'ouest

epp siepman
engineering

400 - 136 Market Avenue
Winnipeg, MB R3B 0P4
T 204 453 1090

Certificate of Authorization
Epp Siepman Engineering Inc.
No. 4035

This is a print of a document that has been electronically authenticated with technology authorized by the APEGM. The original is in electronic form.

0	ISSUED FOR TENDER AND CONSTRUCTION	20.08.14
Revision	Description	Date
Client		client
PUBLIC WORKS AND GOVERNMENT SERVICES CANADA		
Project title	STONY MOUNTAIN INSTITUTION BUILDING C12 POWERHOUSE REPAIRS	
Designed by GC	Conçu par	
Drawn by GC	Dessiné par	
Approved by DS	Approuvé par	
PWGSC Project Manager MICHAEL STEINBORN	Administrateur de Projets TPSGC	
Drawing title	SUBBASEMENT MECHANICAL PLAN	
Project no./No. du projet R.109027	Drawing no./No. du dessin M1.0 OF M1.0	Revision no.