



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
1713 Bedford Row
Halifax, N.S./Halifax, (N.É.)
Halifax
Nova Scotia
B3J 1T3
Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions
1713 Bedford Row
Halifax, N.S./Halifax, (N.É.)
Halifax
Nova Scotia
B3J 1T3

Title - Sujet Polyethylene Tank	
Solicitation No. - N° de l'invitation W0102-21008D/B	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client W0102-21-008D	Date 2020-09-28
GETS Reference No. - N° de référence de SEAG PW-SHAL-406-11066	
File No. - N° de dossier HAL-0-85029 (406)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2020-10-07	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Matheson, Valerie	Buyer Id - Id de l'acheteur hal406
Telephone No. - N° de téléphone (902) 403-6236 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation Amendment 003 is issued to respond to questions

Delete: 6.4.1 Delivery Date

Insert: **6.4.1 Delivery Date**

All deliverables shall be received and installed by *December 18, 2020*.

To be completed by Supplier:

While the delivery and installation at destination is being requested by December 18, 2020, the ***best available delivery and installation date*** that can be offered by the Contractor is ***weeks/days from date of contract award***.

Q1: In Technical Requirements 2.2.1.(h) can you confirm the desired rate of flow and the head pressure for the Transfer pump

A1: Pump is not required as the current one is serviceable and sufficient.

Q2: For the level control; will you consider going through the top of the tank using an adapted equipment that can be added to the tank to see the liquid level?

A2: Yes

Q3: If providing a gauge to determine remaining product level could it be a float alarm that alerts at a certain level or would a continuous electric sensor showing exact level be preferred?

A3: The tank we currently have is a translucent yellow color and the chemical is dark so we can see the chemical levels through the plastic tank, if this does not work, a continuous electric sensor showing level will be sufficient.

Q4: Please confirm maximum capacity of forklift that will be used to move tank.

A4: The lifting capacity of the forklift is 10000Lbs.

Q5: Will the tank be moved once it has liquid in it?

A5: Once the tank is filled it will never be moved.

Q6: Would a horizontal tank on a skid system be considered?

A6: There is not enough space where the tank is going to be placed, therefore, it has to be a vertical tank.

A7: Is this to be the same as the existing tank?

A7: Tank needs to be reasonably the same as the existing tank, however, the color does not have to be the same.

See attached photos.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME









