

The following changes in the bid documents are effectively immediately. This addendum will form part of the contract documents.

Section:

Part 1 – Centrifugal Water Chillers

1.1 Specification Section 23 64 16

.1 Free Cooling Subsection 2.9

- .1 **Delete** : A free cooling cycle shall be provided for the centrifugal chiller. The proposed chiller shall provide required material (including controls, valves, piping, and additional storage vessels) to allow cooling of chilled water by transferring heat to cold condenser water without operating the compressor. This shall be a factory installed option on the centrifugal chiller. The following details shall apply:
- .2 **Replace** with the following: A free cooling cycle shall be provided for the centrifugal chiller. The proposed chiller shall provide required material (including controls, valves, piping) to allow cooling of chilled water by transferring heat to cold condenser water without operating the compressor. This shall be a factory installed option on the centrifugal chiller. The following details shall apply: