



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving - PWGSC / Réception des soumissions
→ TPSGC
10th Floor, 4900 Yonge Street /
10e étage, 4900 rue Yonge
Toronto
Ontario
M2N 6A6

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
Ontario Region
10th Floor, 4900 Yonge Street
Toronto
Ontario
M2N 6A6

Title - Sujet CCIW CHILLER	
Solicitation No. - N° de l'invitation KW405-210260/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client KW405-210260	Date 2020-10-01
GETS Reference No. - N° de référence de SEAG PW-\$PWL-012-2534	
File No. - N° de dossier PWL-0-43021 (012)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2020-10-13	
Time Zone Fuseau horaire Eastern Daylight Saving Time EDT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Caporusso, Mary	Buyer Id - Id de l'acheteur pwl012
Telephone No. - N° de téléphone (416) 318-8637 ()	FAX No. - N° de FAX (416) 952-1257
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: CCIW 867 Lakeshore Rd. Burlington, Ontario L7S 1A1	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
KW405-210260

Amd. No. - N° de la modif.
004

Buyer ID - Id de l'acheteur
pwl012

Client Ref. No. - N° de réf. du client
ECCC-3666

File No. - N° du dossier CCC No./N° CCC - FMS No./N° VME
PWL-0-043021

Solicitation Amendment No. 004 is issued to provide the following changes:

1. Extension of Time

Notice is hereby given that the closing date for reception of tenders previously due October 6, 2020 is extended to October 13, 2020 14:00 hours.

2. Questions and Answers- Revision to Response 9

Q9. Please provide additional details on free cooling option 2.9 requested including temperature inlet and out let for evaporator and condensers and also flow rate.

R9. Delete R9 in its entirety.

Insert At Questions and Answers

Q9. Please provide additional details on free cooling option 2.9 requested including temperature inlet and out let for evaporator and condensers and also flow rate.

R9a. There is no free cooling on the new chiller. Section 2.9 has been deleted.
Refer to Attachment 010 for Revised Questions and Answers - R9 revision included.

3. Addendum No. 2 - Revision to Specification

To provide Addendum No. 2 - Refer to Attachment 012