

The following changes to the tender documents are effective immediately and will form part of the contract documents:

1. Enquires during the Solicitation Period:

Question No.1: Will your customer accept electric defrost with KE2 Therm / Guardian / ESP control as an alternative to hot gas defrost”

Response Question No.1: Alternative is rejected. Defrost is to remain in conformance with original documentation.

Question No.2: Acceptable Materials: Master-Bilt "has advised that “in consideration of current Factory Load and Manufacturing processes, we must “Decline to Quote”.”

Response Question No.2: “Norbec” and “Coldmatic” could be potential acceptable materials, provided that subsequent to the “Optional Site Visit” where the Bidders have the opportunity to make themselves aware of all the conditions, a formal and fully documented “Request for Equal” is submitted.

Question No. 3: Reference Drawing M3, are there any specific model/type you would like us to provide? Should we be requesting equals on these?

Response Question 3: There is no specific requirement for these particular grilles, beyond what is called on the drawings, and the required compliance to the performance requirements.

2. Approval of Alternative or Acceptable Materials:

Specification Section	Item	Product Specified	Approved Alternative or Acceptable Product
23 34 00	Exhaust Fans	Cook	Greenheck

END OF ADDENDUM NO. 2