



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet East Cache Crk. Culvert Replacement	
Solicitation No. - N° de l'invitation EZ899-210904/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client	Date 2020-11-04
GETS Reference No. - N° de référence de SEAG PW-\$PWY-028-8847	
File No. - N° de dossier PWY-0-43075 (028)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Pacific Standard Time PST on - le 2020-11-10 Heure Normale du Pacifique HNP	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Isabell, Park	Buyer Id - Id de l'acheteur pwy028
Telephone No. - N° de téléphone (604) 365-0073 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: PWGSC - East Cache Creek, km 140.3 – Alaska Highway, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Amendment 004

This amendment is raised to issue Addendum 004 and 005.

Attachment

Addendum 004 2020-11-03

Addendum 005 2020-11-04

All other terms and conditions remain unchanged.

PUBLIC WORKS AND GOVERNMENT SERVICES CANADA

Professional and Technical Services, Real Property Services Branch, Pacific Region	
Km 140.3 East Cache Creek Culvert	Addendum 004
Replacement, Alaska Highway, BC	
Project No. R.109448.002	2020-11-03

The following changes in the tender documents are effective immediately. This addendum will form part of the Contract documents.

Questions from Bidders and Responses

Question 1: The headwalls are ± 3.1 m above culvert invert: Is a steel handrail required?

Response 1: No, steel handrails are not required.

Question 2: The headwalls are ± 3.1 m above culvert invert: Would a no post barrier be required to prevent vehicles from entering the creek bed?

Response 2: No, no post barriers are not required.

PUBLIC WORKS AND GOVERNMENT SERVICES CANADA

Professional and Technical Services, Real Property Services Branch, Pacific Region	Addendum 005
Km 140.3 East Cache Creek Culvert	
Replacement, Alaska Highway, BC	
Project No. R.109448.002	2020-11-04

The following changes in the tender documents are effective immediately. This addendum will form part of the Contract documents.

Questions from Bidders and Responses

Question 1: Do portable DMS signs need to be provided or is it to the contractor's discretion?

Response 1: The use of DMS signs are at the Contractor's discretion.

Explanation of Addendum Presentation: Changes to the Specifications and Changes to the Contract Drawings sections of this Addendum have been presented as follows:

- *New text has been underlined for ease of identification.*
- *Removed text has a "strikethrough" and is to be deleted from the text.*

Changes to the Specifications:

1. Section 01 35 00 – Traffic Management

Delete:

3.2 – Traffic Management, Item .5.2.3

Insert:

3.2 – Traffic Management, Item .5.2.3:

- .3 The use of portable dynamic message sign (DMS) is at the Contractor's discretion. If used by the Contractor, the ~~portable dynamic message sign (DMS)~~ DMS shall be positioned in the location identified in 7.2 Typical Construction Speed Zone Signing – Two-Lane, Two-way Roadway (see Item 3.2 – Traffic Management, subsection .1.5.3 of this specification).

Delete:

3.2 – Traffic Management, Item .5.3.1

PUBLIC WORKS AND GOVERNMENT SERVICES CANADA

Professional and Technical Services, Real Property Services Branch, Pacific Region	
Km 140.3 East Cache Creek Culvert	Addendum 005
Replacement, Alaska Highway, BC	
Project No. R.109448.002	2020-11-04

Insert:

3.2 – Traffic Management, Item .5.3.1:

- .3 The use of a DMS is at the Contractor's discretion. If used by the Contractor, a DMS shall be positioned approximately 300 m prior to the sign C-018-2A.