

This Addendum shall be read in conjunction with and considered as an integral part of the Contract Documents; revisions supersede the information contained in the original drawings, specifications or previously issued Addendum. Tender Price submitted shall include all items of this Addendum.

No consideration will be allowed for any extras due to Bidder not being familiar with the contents of this Addendum.

1.0 ELECTRICAL/GENERAL

1.1 QUESTIONS:

- .1 "The lighting spec is incomplete to be able to match to existing. Can a complete product code be provided or a site visit allowed?"

RESPONSE: The luminaire schedule shows a Type A luminaire from Williams 4AR series. Based on that product's model number generator on the company website and a site photo (see attached), it looks to be approximately similar to Williams 4AR-L15/830-DIM1-UNV-OW-OF-CS-MWT-N-F1.



- .2 "It shows an existing communication conduit to be intercepted and install a pullbox. How many existing cables that are staying need to be pulled back and rerouted?"

RESPONSE: Comment refers to Drawing E1.10 Attached photos show the two 103mm conduits and their contents. The conduit being removed appears to have 12 ethernet cables in it currently.

..over



end.

END OF ARCHITECTURAL ADDENDUM - 2