



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions/Travaux
publics et Services gouvernementaux Canada
See herein for bid submission
instructions/

Voir la présente pour les
instructions sur la présentation
d'une soumission

NA

Manitoba

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Public Works and Government Services Canada -
Western Region
Victory Building/Édifice Victory
Room 310/pièce 310
269 Main Street/269 rue Main
Winnipeg
Manitoba
R3C 1B3

Title - Sujet Standby Electrical Generators	
Solicitation No. - N° de l'invitation 5P423-200293/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client 5P423-200293	Date 2020-11-24
GETS Reference No. - N° de référence de SEAG PW-\$WPG-120-11102	
File No. - N° de dossier WPG-0-43109 (120)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Central Standard Time CST on - le 2020-12-03 Heure Normale du Centre HNC	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Aquino, Jill	Buyer Id - Id de l'acheteur wpg120
Telephone No. - N° de téléphone (431) 373-1718 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Amendment No. 001 to Solicitation No. 5P423-200293/A is raised to address the following:

1. Reference Request for Proposal, page 1 of 1, Solicitation Closes at:

DELETE: Solicitation Closes at 02:00 PM CDT on 2020-12-01.

INSERT: Solicitation Closes at 02:00 PM CDT on **2020-12-03**.

2. Delete Article 2.3, SACC Manual Clause B1000T (2014-06-26), Condition of Material - Bid, in its entirety

3. Reference Annex A, Requirement, Mandatory Requirements for each Generator Unit, and **insert:**

Line Item #1.14 All generators must come with a snow hood to prevent excessive snow build up.

4. Questions/Answers

Q1: Please confirm if the generators are to be sized to match the full capacity of the service sizes for sites 1-4 or if a demand factor is to be applied?

A1: A demand factor is to be applied for sites 1-4.

Q2: Please confirm power factor to size generators for sites 1-4, i.e. 0.8 pf is commonly used for 3phs, 1.0 pf is commonly used for 1phs.

A2: Yes, please use the commonly used power factor for sites 1-4.

Q3: Please confirm starting method of motors for sites 1-9, Across-the-line or VFD?

A3: All generators must start Across-the-line.

Q4: Please confirm that the loads at 5-9 are exclusively the motor loads as indicated. If not, please provide information on other loads that may be at each facility.

A4: The loads at locations 5 -9 are the motor loads, exclusively.

Q5: For sites 5-9, please confirm if generators are to be sized to start motors sequentially (in separate load steps) or to start motors simultaneously in a single load step.

A5: For sites 5-9, generators are to be sized to be able to accommodate both pumps running at the same time.

Q6: Please provide site elevation/altitude of each site. Altitude can impact generator size.

A6: All generators are in the valley bottom, 3500 to 3700 feet above sea level.

Q7: Please confirm if PMG (Permanent Magnet Generators) are required for all generators on each site.

A7: Please supply whatever you feel will supply adequate power, Brush and coil or Permanent magnet is at the discretion of the supplier.

Q8: Will you accept a delivery date of June 15th, 2021?

A8: Reference Article 6.4.2, Delivery Date - All the deliverables must be received on or before March 15, 2021.

-
- Q9: Please provide the hyperlink for SACC Manual Clause C3011T (2013-11-06), Exchange Rate Fluctuation.
- A9: SACC Manual Clause [C3011T](#) (2013-11-06), Exchange Rate Fluctuation
- Q10: What is the site specific requirement in terms of kW or kva for each generator?
- A10: Elevation, volts, and Amperage have been provided. It is the bidders responsibility to size the generator appropriately to meet these requirements.
- Q11: Does the end user need the generators to be skidded or mounted?
- A11: Reference Annex A, Mandatory Performance Specifications, Line Item 1.6, the supplied generator, and transfer switch, must be able to be mounted on and be fastened to a concrete pad in a manner that the unit cannot be stolen or tampered with.
- Q12: Will snow hoods be required for excessive snow build up or will normal enclosures suffice?
- A12: Snow hoods will be required.
- Q13: Will the transfer switches be mounted to the generator enclosure, on their own stands or in an existing electrical room?
- A13: They can be mounted to the generator enclosure or on their own, but must be accessible. Reference Annex A, Mandatory Performance Specifications, Line Item 1.6, the supplied generator, and transfer switch, must be able to be mounted on and be fastened to a concrete pad in a manner that the unit cannot be stolen or tampered with.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME