



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works and Government Services Canada
Canada Place/Place du Canada
10th Floor/10e étage
9700 Jasper Ave/9700 ave Jasper
Edmonton
Alberta
T5J 4C3
Bid Fax: (780) 497-3510

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
Canada Place / Place du Canada
10th Floor / 10e étage
9700 Jasper Ave / 9700 ave Jasper
Edmonton
Alberta
T5J 4C3

Title - Sujet Air Handling Units Replacement	
Solicitation No. - N° de l'invitation EP922-211362/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client CSC-EP922-211362	Date 2020-11-27
GETS Reference No. - N° de référence de SEAG PW-SPWU-404-11935	
File No. - N° de dossier PWU-0-43145 (404)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Mountain Standard Time MST on - le 2020-12-01 Heure Normale des Rocheuses HNR	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Singh, Vinay	Buyer Id - Id de l'acheteur pww404
Telephone No. - N° de téléphone (587) 341-8025 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

SOLICITATION AMENDMENT No. 002

Statement to bidders: Please note this an acquisition only tender. The construction and installation tender will be issued in January/February

The following questions were submitted for clarification purposes.

1. Question:

Who is the mechanical engineer on record so we can confirm design criteria that is not listed on the drawing M1? With the schedules we need to know the following to accurately quote this; entering air conditions, leaving air conditions, gas input/output for each unit (temperature rise)

Answer:

Mechanical drawing layout to show the venting for the interior units Controls strategy required indicated on a schedule attached.

Information on AHUs

AHU-1 – Wood Shop

Gas In – 380kw

Gas Out 308kW

ΔT - 37°C

AHU-2 – Metal Shop

Gas In - 380kW

Gas Out – 308kW

ΔT - 50°C

AHU-6 – Central Stores

Gas In – 161kW

Gas Out – 130kW

ΔT – 36°C

AHU-7 – Paint Shop

Gas In – 132kW

Gas Out – 107kW

ΔT – 24°C

AHU-8 – Combined

Gas In – 410kW

Gas Out – 332kW

ΔT – 37°C

MUA-1 – Paint Shop

Gas In – 1,159kW

Gas Out – 940kW

ΔT – 65°C

Heating Supply Air Temperature to be 35-38°C

Mechanical Layout Drawings and Controls Sequences will be issued as part of the Installation Tender

2. Question:

Are discharge dampers required on the units? They were not part of the design.

Please provide heating capacity data (natural gas inputs/outputs, temp rise, minimum efficiency etc.)

Answer:

Discharge dampers will not be required. Temperature rise and gas input/output addressed in question 1 above and minimum efficiency for the burners is 80%.

All other terms and conditions of the solicitation remain unchanged.