



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet PWRC Roof Replacement	
Solicitation No. - N° de l'invitation K4A22-210296/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client K4A22-210296	Date 2020-11-30
GETS Reference No. - N° de référence de SEAG PW-SPWY-031-8859	
File No. - N° de dossier PWY-0-43113 (031)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Pacific Standard Time PST on - le 2020-12-03 Heure Normale du Pacifique HNP	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Leung, Janie	Buyer Id - Id de l'acheteur pwy031
Telephone No. - N° de téléphone (778) 919-3273 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: ECCC – Pacific Wildlife Research Centre – Delta, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
K4A22-210296/A

Amd. No. - N° de la modif.
003

Buyer ID - Id de l'acheteur
PWY031

Client Ref. No. - N° de réf. du client

File No. - N° du dossier
PWY-0-43113

CCC No./N° CCC - FMS No./N° VME

Les documents français seront disponibles sur demande.

This Amendment 003 is raised to issue Addendum No. 2.

All other terms and conditions remain unchanged.



Addendum No.2

QSF-7-090 R-05 JAN31/10

Project:	Roof Replacement Program 2020	Page No:	1 of 1
Facility:	Pacific Wildlife Research Centre	Date:	November 30, 2020
Address:	5421 Robertson Rd Delta, BC V4K 3N2	IRC Ref. No:	VR20-092SP-21476
		Client Ref.	n/a

All Bidders are hereby notified of the following changes and clarifications to the Bid Documents made by this Addendum, issued by IRC Group prior to Bid Closing.

Following are additions, modifications, and clarifications to the project specifications:

1.0 SUMMARY OF WORK

Add to Specification Section 01 11 00 Summary of Work, sub-sections 1.9 and 1.10 Steep Slope Cedar Shingle Replacement, line items 1.9.1.17 and 1.10.1.15 as follows:

- Contractor is to apply an end-cut preservative treatment to all exposed sides of the shingles that have been split, cut, or sawn. Contractor is to carefully brush two (2) coats of a preservative treatment to all exposed cut ends and ensure that the exposed ends of the shingles are protected. Coating should be applied in a manner so that the preservative is contained to the ends of the shingles and does not drip or run onto the top surface of the shingles, same if field applied. Allow for protection of the existing building components as needed in order to protect from drips and spills of the treatment, if field applied.

2.0 CEDAR SHINGLES

Add to Specification Section 07 31 29 Cedar Shingles, sub-section 3.4 Cedar Shingles, line item 2.4.1.2 as follows:

- Treatment for split, cut, or sawn ends: Two (2) Coats of Copper Napthenate preservative.

Enclosed: n/a

End of Addendum No. 2