



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Chemical Storage Bldgs Replacement	
Solicitation No. - N° de l'invitation EZ899-211338/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client	Date 2020-11-30
GETS Reference No. - N° de référence de SEAG PW-\$PWY-036-8869	
File No. - N° de dossier PWY-0-43136 (036)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Pacific Standard Time PST on - le 2020-12-08 Heure Normale du Pacifique HNP	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Martin (PWY), Delia	Buyer Id - Id de l'acheteur pwy036
Telephone No. - N° de téléphone (778) 707-2139 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: AAFC – Agassiz Research and Development Centre – Agassiz, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation. - N° de l'off. à comm.
EZ899-211338/A

Amd. No. - N° de la modif.
001

Buyer ID - Id de l'acheteur
pwy036

Client Ref. No. - N° de réf. du client

File No. - N° du dossier
PWY-0-43136

CCC No./N° CCC - FMS No/ N° VME

This Amendment #001 is raised to issue an Addendum.

Please see Addendum No. 1 attached.

The addendum will form part of the contract documents.

All other terms and conditions remain unchanged.

ADDENDUM #1

Date: November 30, 2020

PACIFIC REGION
AGASSIZ RESEARCH & DEVELOPMENT CENTRE
CHEMICAL STORAGE BUILDINGS REPLACEMENT
AGASSIZ, B.C.
Project No: R.110899.001

The following revisions supersede the information contained in the original drawings and specification issued for the above named project, and shall become part thereof. No consideration will be allowed for extras due to the contractor or any subcontractor not being familiar with this Addendum.

1.0 QUESTIONS AND ANSWERS

- Q.1 Will the chemical storage containers be emptied of all chemical products prior to the start of work by others?
- A.1 All chemicals will be removed from the container prior to hand over to the contractor.**
- Q.2 What are the weights of the existing containers?
- A.2 The inventory record states the units were from Dynavent INC (Quebec) Model 42B size 23 feet x 9 ft 19.3 M2 height 8 ft 7 inch, weight of the container units is not listed, and therefore not known.**
- Q.3 Are the existing containers connected to any utilities? Will the new containers need to be hooked up to any utilities or feed from a tank attached to the container?
- A.3 Refer to drawings and specifications which shows the scope of services disconnection and new services connection. There is no direct electrical utility connections to the containers. They are fed from building sub-distribution which is detailed on the drawings.**

END OF ADDENDUM #1