

1.1 DESCRIPTION OF WORK

- .1 In general, work under this contract consist of:
 - .1 Supply and installation of two new chilled water cooling units, including associated work.
 - .2 Commissioning and integration of new cooling unit control into building management system.
- .2 Site of Work is at: 275 Pope Road, Summerside, PE, C1N 0E1.

1.2 FAMILIARIZATION WITH SITE

- .1 PWGSC may arrange for a bidders site visit. It is recommended that bidders visit the site to review and verify the form, nature and extent of the work, materials needed, the means of access and the temporary facilities required to perform the Work.

1.3 CODES AND STANDARDS

- .1 Perform work in accordance with the National Building Code of Canada (NBC) 2010 and National Fire Code of Canada (NFC) 2015, and any other code of provincial or local application, including all amendments up to bid closing date, provided that in any case of conflict or discrepancy, the more stringent requirement shall apply.
- .2 Materials and workmanship must meet or exceed requirements of specified standards, codes and referenced documents.

1.4 INTERPRETATION OF DOCUMENTS

- .1 For Federal Government projects, Division 01 Sections take precedence over technical specification sections in other Divisions of this Project Manual.

1.5 TERM ENGINEER

- .1 Unless specifically stated otherwise, the term Engineer where used in the Specifications and on the Drawings shall mean the Departmental Representative as defined in the General Conditions of the Contract.

1.6 SETTING OUT WORK

- .1 Assume full responsibility for and execute complete layout of work to locations, lines and elevations indicated.

1.7 COST BREAKDOWN

- .1 Before submitting first progress claim submit breakdown of Contract Amount in detail as directed by Departmental Representative and aggregating contract amount. Required forms will be provided for application of progress payment.
- .2 List items of work numerically following the same division/section number system of the specification manual and thereafter sub-divide into major work components and building systems as directed by Departmental Representative.
- .3 Upon approval, cost breakdown will be used as basis for progress payment.

1.9 DOCUMENTS REQUIRED

- .1 Maintain at job site, one copy each of the following:
 - .1 Contract Drawings.
 - .2 Specifications.
 - .3 Addenda and amendments.
 - .4 Reviewed Shop Drawings.
 - .5 List of outstanding shop drawings.
 - .6 Change Orders.
 - .7 Other modifications to Contract.
 - .8 Field Test Reports.
 - .9 Copy of Approved Work Schedule.
 - .10 Health and Safety Plan and other safety related documents.
 - .11 Other documents as stipulated elsewhere in the Contract Documents.

1.10 PERMITS

- .1 In accordance with the General Conditions, obtain and pay for certificates, licenses and other permits as required by municipal, provincial and federal authorities.
- .2 Provide appropriate notifications of project to municipal and provincial inspection authorities.
- .3 Obtain compliance certificates as prescribed by legislative and regulatory provisions of municipal, provincial and federal authorities as applicable to the performance of work.
- .4 Submit to Departmental Representative, copy of application forms and approval documents received from above referenced authorities.

1.11 ALTERATIONS, ADDITIONS OR REPAIRS TO EXISTING BUILDING

- .1 Execute work with least possible interference or disturbance to building operations, and normal use of premises. Arrange with Departmental Representative to facilitate execution of work.
- .2 Provide temporary dust screens, barriers, warning signs in locations where renovation and alteration work is adjacent to areas which will be operative during such work.

1.12 ROUGHING-IN

- .1 Be responsible for obtaining manufacturer's literature, for assuring fit in the room, fit thru the doors and halls, and for correct roughing-in and hook-up of equipment.

1.13 CUTTING, FITTING AND PATCHING

- .1 Ensure that cutting and patching required by all trades is included in total bid amount submitted for the work.
- .2 Execute cutting [including excavation], fitting and patching required to make work fit properly.
- .3 Where new work connects with existing and where existing work is altered, cut, patch and make good to match existing work. This includes patching of openings in existing work resulting from removal of existing services.
- .4 Do not cut, bore, or sleeve load-bearing members, except where specifically approved by Departmental Representative.
- .5 Make cuts with clean, true, smooth edges. Make patches inconspicuous in final assembly.
- .6 Fit work airtight to pipes, sleeves ducts and conduits.

1.15 LOCATION OF FIXTURES

- .1 Location of equipment, fixtures and outlets, shown or specified shall be considered as approximate. Actual location shall be as required to suit conditions at time of installation and as is reasonable.
- .2 Locate equipment, fixtures and distribution systems to provide minimum interference and maximum usable space and in accordance with manufacturer's recommendations for safety, access and maintenance.
- .3 Inform Departmental Representative when impending installation conflicts with other new or existing components. Follow directives for actual location.
- .4 Submit field drawings to indicate relative position of various services and equipment when required by Departmental Representative.

1.16 EXISTING SERVICES

- .1 Where work involves breaking into or connecting to existing services, carry out work at times directed by governing authorities, with minimum of disturbance to tenant operations.
- .2 Before commencing work, establish location and extent of service lines in area of work and notify Departmental Representative of findings.
- .3 Submit schedule to and obtain approval from Departmental Representative for any shut-down or closure of active service or facility. This includes disconnection of electrical power and

communication services to tenant's operational areas. Adhere to approved schedule and provide notice to affected parties.

- .4 Provide temporary services when directed by Departmental Representative to maintain critical building and tenant systems.
- .5 Where unknown services are encountered, immediately advise Departmental Representative and confirm findings in writing.
- .6 Protect, relocate or maintain existing active services as required. When inactive services are encountered, cap off in manner approved by authorities having jurisdiction over service. Record locations of maintained, re-routed and abandoned service lines.

1.17 BUILDING SMOKING & SECURITY ENVIRONMENT

- .1 Comply with smoking and security restrictions.

END OF SECTION

1.1 SUBMITTALS

- .1 Upon acceptance of bid and prior to commencement of work, submit to Departmental Representative the following work management documents:
 - .1 Work Schedule as specified herein.
 - .2 Shop Drawing Submittal Schedule specified in section 01 33 00.
 - .3 Waste Management Plan specified in section 01 74 22.
 - .4 Health and Safety Plan specified in section 01 35 29.
 - .5 Hot Work Procedures specified in section 01 35 24.
 - .6 Lockout Procedures specified in section 01 35 25.
 - .7 Dust Control Plan specified in section 01 50 00.
 - .8 List of workers requiring security clearance and those to be placed on Site Security Control list as specified in section 01 35 54.

1.2 WORK SCHEDULE

- .1 Upon acceptance of bid submit:
 - .1 Preliminary work schedule within 7 calendar days of contract award.
 - .2 Detailed work schedule within 21 calendar days of contract award.
- .2 Schedule to indicate all calendar dates from commencement to completion of all work within the time stated in the accepted bid.
- .3 Provide sufficient details in detailed schedule to clearly illustrate entire implementation plan, depicting efficient coordination of tasks and resources, to achieve completion of work on time and permit effective monitoring of work progress in relation to established milestones.
- .4 Detailed work schedule content to include as a minimum the following:
 - .1 Bar (GANTT) Charts, indicating all work activities, tasks and other project elements, their anticipated durations, planned dates for achieving key activities and major project milestones supported with;
 - .2 Written narrative on key elements of work illustrated in bar chart, providing sufficient details to demonstrate a reasonable implementation plan for completion of project within designated time.
 - .3 Generally Bar Charts derived from commercially available computerized project management system are preferred but not mandatory.
- .5 Schedule work in cooperation with the Departmental Representative. Incorporate within Detailed Work Schedule, items identified by Departmental Representative during review of preliminary schedule.
- .8 Completed schedule shall be approved by Departmental Representative. When approved, take necessary measures to complete work within scheduled time. Do not change schedule without Departmental Representative's approval.
- .9 Ensure that all subtrades and subcontractors are made aware of the work restraints and operational restrictions specified.
- .10 Schedule Updates:
 - .1 Provide information and pertinent details explaining reasons for necessary changes to implementation plan.
 - .2 Identify problem areas, anticipated delays, impact on schedule and proposed corrective

measures to be taken.

- .11 Departmental Representative will make interim reviews and evaluate progress of work based on approved schedule. Frequency of such reviews will be as decided by Departmental Representative. Address and take corrective measures on items identified by reviews and as directed by Departmental Representative. Update schedule accordingly.
- .12 In every instance, change or deviation from the Work Schedule, no matter how minimal the risk or impact on safety or inconvenience to tenant or public might appear, will be subject to prior review and approval by the Departmental Representative.

1.3 PROJECT PHASING

- .1 Be aware that Facility must be kept operational for the full duration of work of this contract. Building services to areas under use by tenants must also be maintained at all times during the Facility's operational hours and as specifically defined in operational restrictions specified in this section.
- .2 Perform Work of this contract in individual phases in the following sequence of activities:
 - .1 Installation of first chilled water unit with piping roughed-in.
 - .2 Removal of existing chilled water unit.
 - .3 Piping installation of first chilled water unit.
 - .4 Start-up of first chilled water unit.
 - .5 Removal of portable cooling unit.
 - .6 Installation of second cooling unit.
- .3 Unless indicated or approved otherwise, complete all work of a particular phase prior to commencement of another phase. Obtain Departmental Representative's permission prior to moving between phases.

1.4 OPERATIONAL RESTRICTIONS

- .1 The Contractor must recognize that building occupants will be affected by implementation of this Contract. The Contractor must perform the work with utmost regard to the safety and convenience of building occupants and users. All work activities must be planned and scheduled with this in mind. The Contractor will not be permitted to disturb any portion of the building without providing temporary facilities as necessary to ensure safe and direct passage through disturbed or otherwise affected areas.
- .2 Contractor to meet with the Departmental Representative on a weekly basis to identify intended work areas, activities and scheduling for the coming week.
- .4 Off Hours: means a period of time which is outside the daily operational hours of the tenants of the Facility. For the purposes of this contract, Off-Hours are defined as follows:
 - .1 Weekend Off-Hours: between the hours of 21:00 Friday evening to 05:00 Monday morning.
 - .3 Dependent on the nature and location of the construction activity and due to an unanticipated operational requirement of the Tenant, certain off-hour periods may be redefined by adjusting the start and end time periods or cancellation of a specific off-hour workshift during the course of the Work.
- .5 Departmental Representative reserves the right to stop certain daytime work activities, if the nature

of that activity generates excessive noise or dust and have Contractor re-schedule that particular work to be performed during the Off-Hour period.

- .6 See section 01 35 54 in regards to:
 - .1 Special security requirements which must be observed in the course of work.
 - .2 Provision of security personnel by Contractor as part of the Work.
- .7 Facility circulation maintained:
 - .1 Ensure that entrances, corridors, stairwells, fire exits and other circulation routes are maintained free and clear providing safe and uninterrupted passage for Facility users and public at all times during the entire work.
 - .2 Maintain those areas clean and free of construction materials and equipment. Provide temporary dust barriers and other suitable enclosures to ensure users are not exposed to construction activities and are protected from exposure to dust, noise and hazardous conditions.
 - .3 Provide temporary corridors, walkways, passageways, access to offices, etc. when required due to nature of work. Such circulation routes must be constructed to barrier free requirements unless approved otherwise by Departmental Representative.
 - .4 Maintain fire escape routes accessible and fire fighting access open all times for the duration of the project.
 - .5 Do not under any circumstances block fire exit doors. Do not leave construction materials or debris in corridors, stairwells building entrances and exits.
- .8 Safety Signage:
 - .1 Provide on site, and erect as required during progress of work, proper bilingual signage, mounted on self-supporting stands, warning the public and building occupants of construction activities in progress and alerting need to exercise caution in proceeding through disturbed areas of the facility, and directing building occupants through any detours which may be required.
 - .2 Signage to be professionally printed and mounted on wooden backing, coloured and to express messages as directed by the Departmental Representative.
 - .3 Generally maximum size of sign should be in the order of 1.0 square meters. Number of signs required will be dependent on number of areas in facility under renovation at any one time.
 - .4 Include costs for the supply and installation of these signs in the bid amount.
- .12 Dust and Dirt Control:
 - .1 See section 01 50 00 and 01 74 11 for dust control and cleaning requirements.
 - .2 Effectively plan and implement dust control measures and cleaning activities as an integral part of all construction activities. Review all measures with the Departmental Representative before undertaking work, especially for major dust generating activities.
 - .3 Do not allow demolition debris and construction waste to accumulate on site and contribute to the propagation of dust.
 - .4 As work progresses, maintain construction areas in a tidy condition at all times. Remove gross dust accumulations by cleaning and vacuuming immediately following the completion of any major dust generating activity.
 - .5 Immediately remove all debris and dust from within occupied areas as generated by work therein during a given workshift.
 - .6 Disconnect and seal-off ductwork of HVAC servicing the construction area to stop spread of dust into other areas of Facility.
 - .7 Avoid situations and practises which results in dust and dirt being brought from the construction areas or from the exterior and tracked inside the building and into occupied areas used by tenants.
 - .8 Stop workers with soiled footwear from entering building. This includes roofing mechanics and heavy civil workers.
 - .9 Inform workers and make them sensitive to the need for dust and dirt control. Stringently enforce rules and regulations, immediately address non-compliance.
 - .10 Keep access doors to work areas closed at all times. Use only designated doors for entry or

eggress.

- .13 Work in Occupied Areas:
 - .1 Where work must be carried out in an occupied area beyond the boundaries of the enclosed construction site, perform such work during the non-operational off-hour periods of the Facility.
 - .2 Ensure that all dust, dirt, debris, construction waste, materials, tools and equipment are completely removed at the end of each "off-hour" workshift. Clean and reinstate area ready for daytime use by tenant.
 - .3 Provide temporary dust barriers around immediate work areas and place fabric drop sheets over workstations, equipment and other furnishings located immediately adjacent to such work.
 - .4 Conduct work in such a way as to minimize the creation of dust and to avoid contaminating areas beyond the immediate location.
 - .5 Discuss and obtain Departmental Representative's approval beforehand on the type and extent of dust barriers, protective devices and measures needed.
 - .6 Be responsible for temporarily moving office furnishings, workstations, computer equipment and other objects as needed to gain access and conduct work. Reinstall all dislocated items at end of each workshift making the area operational again.
 - .7 Disconnect and reconnect any power and communications systems feeding workstations as required.
 - .8 Clean such areas as well as those corridors and routes used to gain entry and access.
- .14 Cleaning of tenant occupied areas used by Contractor:
 - .1 Clean lobbies, corridors, stairs and other circulation routes used by workers to gain access to work by conducting cleaning, vacuuming and washing of floors, walls and other soiled surfaces.
 - .2 Meager attempts at controlling dust and ineffective unprofessional cleaning procedures will not be tolerated.
 - .3 Failure to provide effective dust control, allowing construction dust and dirt to escape beyond construction areas and contaminate occupied areas and building circulation areas will result in Contractor being ordered to immediately provide professional cleaning services without delay to remedy the situation and conduct all cleaning to the extent as determined by Departmental Representative. Alternatively, Departmental Representative may, at certain times and at own discretion, obtain the services of an independent building cleaning agency when cleaning being provided by Contractor is ineffective or tardy in response. Costs of such services will be charged against Contractor in the form of financial penalties or holdback assessments against the Contract.
- .15 Ensure that all sub-trades are made aware of and abide by the contents of this section and in particularly the work restrictions specified herein due to tenant operational requirements.

1.5 PROJECT MEETINGS

- .1 Departmental Representative will arrange project meetings and assume responsibility for setting times and recording minutes.

1.6 WORK COORDINATION

- .1 General Contractor is responsible for coordinating the work of the various trades and predetermining where the work of such trades interfaces with each other.
 - .1 Designate one person from own employ having overall responsibility to review contract documents and shop drawings, plan and manage such coordination.
- .2 General Contractor shall convene meetings between trades whose work interfaces and ensure that

they are fully aware of the areas and the extent of where interfacing is required.

- .1 Provide each trade with the plans and specs of the interfacing trade, as required, to assist them in planning and carrying out their respective work.
 - .2 Develop coordination drawings when deemed required illustrating potential interference between work of various trades and distribute to all affected parties including structural trade.
 - .1 Pay particularly close attention to overhead work above ceilings and within or near to building structural elements.
 - .2 Coordination drawings to identify all building elements, services lines, rough-in points and indicate from where various services are coming.
 - .3 Review coordination drawings at purposely called meetings. Have subcontractors sign-off on drawings and publish minutes of each meeting.
 - .4 Plan and coordinate work in such a way to minimize quantity of service line offsets.
 - .5 Submit copy of coordination drawings and meeting minutes to Departmental Representative for information purposes.
- .3 Submission of shop drawings and ordering of prefabricated equipment or prebuilt components shall only occur once coordination meeting for such items has taken place between trades and all conditions affecting the work of the interfacing trades has been made known and accounted for.
- .4 Work Cooperation:
 - .1 Ensure cooperation between trades in order to facilitate the general progress of the work and avoid situations of spatial interference.
 - .2 Ensure that each trade provides all other trades reasonable opportunity for the completion of the work and in such a way as to prevent unnecessary delays, cutting, patching and the need to remove and replace completed work.
- .5 No extra costs to the Contract will be considered by the Departmental Representative as a result of Contractor's failure to effectively coordinate all portions of the Work. Disputes between the various trades as a result of their not being informed of the areas and extent of interface work shall be the sole responsibility of the General Contractor to be resolved at own cost.

1.7 OTHER CONTRACTS

- .1 Other contracts will be in progress at the building during the course of this work.
- .2 Cooperate with other Contractors in carrying out their respective works and carry out all instructions from the Departmental Representative in this regard.
- .3 Connect properly and coordinate work with that of other Contractors. If any part of the work under this Contract depends for its proper execution or result upon the work of another Contractor, report promptly to the Departmental Representative, in writing, any defects in the work of such other Contractors as may interfere with the proper execution of this work.

END OF SECTION

1.1 RELATED SECTIONS

- .1 Section 01 78 00: Closeout Submittals.

1.2 SUBMITTAL GENERAL REQUIREMENTS

- .1 Submit to Departmental Representative for review requested submittals specified in various sections of the specifications including shop drawings, samples, permits, compliance certificates, test reports, work management plans and other data required as part of the work.
- .2 Submit with reasonable promptness and in orderly sequence so as to allow for Departmental Representative's review and not cause delay in Work. Failure to submit in ample time will not be considered sufficient reason for an extension of Contract time and no claim for extension by reason of such default will be allowed.
- .3 Do not proceed with work until relevant submissions have been reviewed.
- .4 Present shop drawings, product data, samples and mock-ups in SI Metric units.
- .5 Where items or information is not produced in SI Metric units, provide soft converted values.
- .6 Review submittals prior to submission. Ensure that necessary requirements have been determined and verified and that each submittal has been checked and co-ordinated with requirements of Work and Contract Documents.
 - .1 Submittals not stamped, signed, dated and identified as to specific project will be returned unexamined by Departmental Representative and considered rejected.
- .7 Verify field measurements and affected adjacent Work are coordinated.
- .8 Notify Departmental Representative, in writing at time of submission, identifying deviations from requirements of Contract Documents stating reasons for deviations.
- .9 Contractor's responsibility for errors, omissions or deviations in submission from requirements of Contract Documents is not relieved by Departmental Representative's review.
- .10 Submittal format:
 - .1 Submit paper originals, or alternatively clear and fully legible photocopies of originals. Facsimiles are not acceptable, except in special circumstances pre-approved by Departmental Representative. Poorly printed non-legible photocopies or facsimiles will not be accepted and be returned for resubmission.
 - .2 Submit in electronic format as pdf files. Forward pdf and in the native program format on USB compatible with PWGSC encryption requirements or through email or alternate electronic file sharing service such as ftp, as directed by Departmental Representative.
- .11 Make changes or revision to submissions which Departmental Representative may require, consistent with Contract Documents and resubmit as directed by Departmental Representative. When resubmitting, identify in writing of any revisions other than those requested.
- .12 Keep one reviewed copy of each submittal document on site for duration of Work.

1.3 SHOP DRAWINGS AND PRODUCT DATA

- .1 The term "shop drawings" means fabrication drawings, erection drawings, diagrams, illustrations, schedules, performance charts, technical product data, brochures, specifications, test reports installation instructions and other data which are to be provided by Contractor to illustrate compliance with specified materials and details of a portion of work.
- .3 Shop Drawing Quantities: submit sufficient copies required by the General Contractor and sub-contractors plus 3 copies which will be retained by Departmental Representative.
- .4 Shop Drawings Format:
 - .1 Opaque white prints or photocopies of original drawings or standard drawings modified to clearly illustrate work specific to project requirements. Maximum sheet size to be 1000 x 707 mm.
 - .2 Product Data from manufacturer's standard catalogue sheets, brochures, literature, performance charts and diagrams, used to illustrate standard manufactured products, to be original full colour brochures, clearly marked indicating applicable data and deleting information not applicable to project.
 - .3 Non or poorly legible drawings, photocopies or facsimiles will not be accepted and returned not reviewed.
- .5 Shop Drawings Content:
 - .1 Indicate materials, methods of construction and attachment or anchorage, erection diagrams, connections, explanatory notes and other information necessary for completion of Work. Where items or equipment attach or connect to other items or equipment, confirm that all interrelated work have been coordinated, regardless of section or trade from which the adjacent work is being supplied and installed.
 - .2 Supplement manufacturer's standard drawings and literature with additional information to provide details applicable to project.
 - .3 Delete information not applicable to project on all submittals.
 - .4 Equipment installation/start-up data: include manufacturer's recommended installation instructions, pre-start and start-up checklists for equipment.
- .6 Allow 14 calendar days for Departmental Representative's review of each submission.
- .7 Adjustments or corrections made on shop drawings by Departmental Representative are not intended to change Contract Amount. If adjustments affect value of Work, advise Departmental Representative in writing prior to proceeding with Work.
- .8 If upon review by Departmental Representative, no errors or omissions are discovered or if only minor corrections and comments are made, fabrication and installation may proceed upon receipt of shop drawings. If shop drawings are rejected and noted to be Resubmitted, do not proceed with that portion of work until resubmission and review of corrected shop drawings, through same submission procedures indicated above.
- .9 Be advised that costs and expenses incurred by Departmental Representative to conduct more than one review of incorrectly prepared shop drawing submittal for a particular material, equipment or component of work may be assessed against the Contractor in the form of a financial holdback to the Contract.
- .10 Accompany each submissions with transmittal letter, in, containing:
 - .1 Date.
 - .2 Project title and project number.
 - .3 Contractor's name and address.

- .4 Identification and quantity of each shop drawing, product data and sample.
- .5 Other pertinent data.

- .11 Submissions shall include:
 - .1 Date and revision dates.
 - .2 Project title and project number.
 - .3 Name and address of:
 - .1 Subcontractor.
 - .2 Supplier.
 - .3 Manufacturer.
 - .4 Contractor's stamp, signed by Contractor's authorized Representative certifying approval of submissions, verification of field measurements and compliance with Contract Documents.
 - .5 Cross references to particular details of contract drawings and specifications section number for which shop drawing submission addresses.
 - .6 Details of appropriate portions of Work as applicable:
 - .1 Layout, showing dimensions, including identified field dimensions, and clearances.
 - .2 Capacities.
 - .3 Performance characteristics.
 - .4 Wiring diagrams.
 - .5 Single line and schematic diagrams.

- .12 After Departmental Representative's review, distribute copies.

- .13 The review of shop drawings by the Departmental Representative or by an authorized Consultant or designate is for sole purpose of ascertaining conformance with general concept. This review shall not mean that Canada approves the detail design inherent in the shop drawings, responsibility for which shall remain with Contractor submitting same, and such review shall not relieve Contractor of responsibility for errors or omissions in shop drawings or of responsibility for meeting all requirements of the construction and Contract Documents. Without restricting generality of foregoing, Contractor is responsible for dimensions to be confirmed and correlated at job site, for information that pertains solely to fabrication processes or to techniques of construction and installation and for co-ordination of Work of all sub-trades.

END OF SECTION

1.1 SECTION INCLUDES

- .1 Procedures to isolate and lockout electrical facility and other equipment from energy sources.

1.2 RELATED SECTIONS

- .1 Section 01 35 29: Health and Safety

1.3 REFERENCES

- .1 CSA C22.1-12, Canadian Electrical Code, Part 1, Safety Standard for Electrical Installations.
- .2 CAN/CSA-C22.3 No.1-06, Overhead Systems.
- .3 CSA C22.3 No.7-06, Underground Systems.
- .4 COSH: Canada Occupational Health and Safety Regulations made under Part II of the Canada Labour Code.

1.4 DEFINITIONS

- .1 Electrical Facility: means any system, equipment, device, apparatus, wiring, conductor, assembly or part thereof that is used for the generation, transformation, transmission, distribution, storage, control, measurement or utilization of electrical energy, and that has an amperage and voltage that is dangerous to persons.
- .2 Guarantee of Isolation: means a guarantee by a competent person in control or in charge that a particular facility or equipment has been isolated.
- .3 De-energize: in the electrical sense, that a piece of equipment is isolated and grounded, e.g. if the equipment is not grounded, it cannot be considered de-energized (DEAD).
- .4 Guarded: means that an equipment or facility is covered, shielded, fenced, enclosed, inaccessible by location, or otherwise protected in a manner that, to the extent that is reasonably practicable, will prevent or reduce danger to any person who might touch or go near such item.
- .5 Isolate: means that an electrical facility, mechanical equipment or machinery is separated or disconnected from every source of electrical, mechanical, hydraulic, pneumatic or other kind of energy that is capable of making it dangerous.
- .6 Live/alive: means that an electrical facility produces, contains, stores or is electrically connected to a source of alternating or direct current of an amperage and voltage that is dangerous or contains any hydraulic, pneumatic or other kind of energy that is capable of making the facility dangerous to persons.

1.5 COMPLIANCE REQUIREMENTS

- .1 Comply with the following in regards to isolation and lockout of electrical facilities and equipment:
 - .1 Canadian Electrical Code.
 - .2 Federal and Provincial Occupational Health and Safety Acts and Regulations.
 - .3 Regulations and code of practise as applicable to mechanical equipment or other machinery being de-energized.
 - .4 Procedures specified herein.
- .2 In event of conflict between any provisions of above authorities the most stringent provision will apply.

1.6 SUBMITTALS

- .1 Submit copy of lockout procedures, sample of lockout permit and lockout tags proposed for use in accordance with Section [01 33 00]. Submit within [14] calendar days of acceptance of bid.

1.7 ISOLATION OF EXISTING SERVICES

- .1 Obtain Departmental Representative's written authorization prior to working on existing live or active electrical facilities and equipment and before proceeding with isolation of such item.
- .2 To obtain authorization, submit to Departmental Representative the following documentation:
 - .1 Written request to isolate the particular service or facility and;
 - .2 Copy of Contractor's Lockout Procedures.
- .3 Make a Request for Isolation for each event, unless directed otherwise by Departmental Representative, as follows:
 - .1 Fill-out standard form in current use at the Facility as provided by Departmental Representative or;
 - .2 Where no form exist, make written request indicating:
 - .1 The equipment, system or service to be isolated and it's location;
 - .2 Duration of isolation period (ie: start time & date and completion time & date).
 - .3 Voltage of service feed to system or equipment being isolated.
 - .4 Name of person making the request.
- .4 Do not proceed with isolation until receipt of written notification from Departmental Representative granting the Isolation Request and authorizing to proceed with the work.
 - .1 Note that Departmental Representative may designate another person at the Facility being authorized to grant the Isolation Request.
- .5 Conduct safe, orderly shut down of equipment or facility. De-energize, isolate and lockout power and other sources of energy feeding the equipment or facility.
- .6 Determine in advance, as much as possible, in cooperation with the Departmental Representative, the type and frequency of situations which will require isolation of existing services.
- .7 Plan and schedule shut down of existing services in consultation with the Departmental Representative and the Facility Manager. Minimize impact and downtime of Facility operations. Follow Departmental Representative's directives in this regard.

- .8 Conduct hazard assessment as part of the process in accordance with health and safety requirements specified Section 01 35 29.

1.8 LOCKOUTS

- .1 De-energize, isolate and lockout electrical facility, mechanical equipment and machinery from all potential sources of energy prior to working on such items.
- .2 Develop and implement clear and specific lockout procedures to be followed as part of the Work.
- .3 Prepare typed written Lockout Procedures describing safe work practices, procedures, worker responsibilities and sequence of activities to be followed on site by workforce to safely isolate an active piece of equipment or electrical facility and effectively lockout and tagout it's sources of energy.
- .4 Include as part of the Lockout Procedures a system of lockout permits managed by Contractor's Superintendent or other qualified person designated by him/her as being "in-charge" at the site.
 - .1 A lockout permit shall be issued to specific worker providing a Guarantee of Isolation before each event when work must be performed on a live equipment or electrical facility.
 - .2 Duties of person managing the permit system to include:
 - .1 Issuance of permits and lockout tags to workers.
 - .2 Determining permit duration.
 - .3 Maintaining record of permits and tags issued.
 - .4 Making a Request for Isolation to Departmental Representative when required as specified above.
 - .5 Designating a Safety Watcher, when one is required based on type of work.
 - .6 Ensuring equipment or facility has been properly isolated.
 - .7 Collecting and safekeeping lockout tags returned by workers as a record of the event.
- .5 Clearly establish, describe and allocate responsibilities of:
 - .1 Workers.
 - .2 Person managing the lockout permit system.
 - .3 Safety Watcher.
 - .4 Subcontractor(s) and General Contractor.
- .6 Generic procedures, if used, must be edited and supplemented with pertinent information to reflect specific project requirements.
 - .1 Incorporate site specific rules and procedures in force at site as provided by Facility Manager through the Departmental Representative.
 - .2 Clearly label the document as being the Lockout procedures applicable to work of this contract.
- .7 Use energy isolation lockout devices specifically designed and appropriate for type of facility or equipment being locked out.
- .8 Use industry standard lockout tags.
- .9 Provide appropriate safety grounding and guards as required.

1.9 CONFORMANCE

- .1 Brief all workers and subcontractors on requirements of this section. Stringently enforce use and compliance.

1.10 DOCUMENTS ON SITE

- .1 Post Lockout Procedures on site in common location for viewing by workers.
- .2 Keep copies of Request for Isolation forms and lockout permits and tags issued to workers on site for full duration of Work.
- .3 Upon request, make available to Departmental Representative or to authorized safety representative for inspection.

END OF SECTION

1.1 RELATED SECTIONS

- .1 Section 01 35 24: Special Procedures on Fire Safety Requirements.
- .2 Section 01 35 25: Special Procedures on Lockout Requirements.

1.2 DEFINITIONS

- .1 COSH: Canada Occupational Health and Safety Regulations made under Part II of the Canada Labour Code.
- .2 Competent Person: means a person who is:
 - .1 Qualified by virtue of personal knowledge, training and experience to perform assigned work in a manner that will ensure the health and safety of persons in the workplace, and;
 - .2 Knowledgeable about the provisions of occupational health and safety statutes and regulations that apply to the Work and;
 - .3 Knowledgeable about potential or actual danger to health or safety associated with the Work.
- .3 Medical Aid Injury: any minor injury for which medical treatment was provided and the cost of which is covered by Workers' Compensation Board of the province in which the injury was incurred.
- .4 PPE: personal protective equipment.
- .5 Work Site: where used in this section shall mean areas, located at the premises where Work is undertaken, used by Contractor to perform all of the activities associated with the performance of the Work.

1.3 SUBMITTALS

- .1 Make submittals in accordance with Section 01 33 00.
- .2 Submit site-specific Health and Safety Plan prior to commencement of Work.
 - .1 Submit within 10 work days of notification of Bid Acceptance. Allow for 5-10 days for Department review and recommendations prior to the commencement of work. Provide 3 copies.
 - .2 Departmental Representative will review Health and Safety Plan and provide comments.
 - .3 Revise the Plan as appropriate and resubmit within 5 work days after receipt of comments.
 - .4 Departmental Representative's review and comments made of the Plan shall not be construed as an endorsement, approval or implied warranty of any kind by Canada and does not reduce Contractor's overall responsibility for Occupational Health and Safety of the Work.
 - .5 Submit revisions and updates made to the Plan during the course of Work.
- .3 Submit name of designated Health and Safety Site Representative and support documentation specified in the Safety Plan.
- .4 Submit building permit, compliance certificates and other permits obtained.
- .5 Submit copy of Letter in Good Standing from Provincial Workers Compensation or other Department of Labour organization.

- .1 Submit update of Letter of Good Standing whenever expiration date occurs during the period of Work.
- .6 Submit copies of reports or directions issued by Federal, Provincial and Territorial health and safety inspectors.
- .7 Submit copies of incident reports.
- .8 Submit WHMIS MSDS - Material Safety Data Sheets.

1.4 COMPLIANCE REQUIREMENTS

- .1 Comply with Occupational Health and Safety Act for Province of Prince Edward Island, and Occupational Health and Safety Regulations made pursuant to the Act.
- .2 Comply with Canada Labour Code - Part II (entitled Occupational Health and Safety) and the Canada Occupational Health and Safety Regulations as well as any other regulations made pursuant to the Act.
 - .1 The Canada Labour Code can be viewed at: [www.http://laws-lois.justice.gc.ca/eng/acts/L-2/fulltext.html](http://laws-lois.justice.gc.ca/eng/acts/L-2/fulltext.html).
 - .2 Canadian Occupational Health and Safety Regulations can be viewed at: <http://laws-lois.justice.gc.ca/eng/regulations/SOR-86-304/index.html>.
 - .3 A copy may be obtained at: Canadian Government Publishing Public Works & Government Services Canada Ottawa, Ontario, K1A 0S9 Tel: 819-956-4800 or 1-800-635-7943 Publication No. L31-85/2000 (E or F).
- .3 Treasury Board of Canada Secretariat (TBS):
 - .1 Treasury Board, Fire Protection Standard April 1, 2010 www.tbs-sct.gc.ca/pol/doc-eng.aspx?id=17316§ion=text.
- .4 Canadian Standards Association (CSA):
 - .1 CSA S350-M1980(R2003), Code of Practice for Safety in Demolition of Structures.
- .5 Observe construction safety measures of:
 - .1 NBC 2010, Division B, Part 8.
 - .2 Municipal by-laws and ordinances.
- .9 In case of conflict or discrepancy between above specified requirements, the more stringent shall apply.
- .10 Maintain Workers Compensation Coverage in good standing for duration of Contract. Provide proof of clearance through submission of Letter in Good Standing.
- .11 Medical Surveillance: Where prescribed by legislation or regulation, obtain and maintain worker medical surveillance documentation.

1.5 RESPONSIBILITY

- .1 Be responsible for health and safety of persons on site, safety of property on site and for protection of persons and environment adjacent to the site to extent that they may be affected by conduct of Work.

- .2 Comply with and enforce compliance by all workers, sub-contractors and other persons granted access to Work Site with safety requirements of Contract Documents, applicable federal, provincial, and local by-laws, regulations, and ordinances, and with site-specific Health and Safety Plan.

1.6 SITE CONTROL AND ACCESS

- .1 Control the Work and entry points to Work Site. Approve and grant access only to workers and authorized persons. Immediately stop and remove non-authorized persons.
 - .1 Departmental Representative will provide names of those persons authorized by Departmental Representative to enter onto Work Site and will ensure that such authorized persons have the required knowledge and training on Health and Safety pertinent to their reason for being at the site, however, Contractor remains responsible for the health and safety of authorized persons while at the Work Site.
- .2 Isolate Work Site from other areas of the premises by use of appropriate means.
 - .1 Erect fences, hoarding, barricades and temporary lighting as required to effectively delineate the Work Site, stop non-authorized entry, and to protect pedestrians and vehicular traffic around and adjacent to the Work and create a safe environment. [See Section 01 50 00 for minimum acceptable requirements].
 - .2 Post signage at entry points and other strategic locations indicating restricted access and conditions for access.
 - .3 Use professionally made signs with bilingual message in the 2 official languages or international known graphic symbols.
- .3 Provide safety orientation session to persons granted access to Work Site. Advise of hazards and safety rules to be observed while on site.
- .4 Ensure persons granted site access wear appropriate PPE. Supply PPE to inspection authorities who require access to conduct tests or perform inspections.
- .5 Secure Work Site against entry when inactive or unoccupied and to protect persons against harm. [Provide security guard where adequate protection cannot be achieved by other means].

1.7 PROTECTION

- .1 Give precedence to safety and health of persons and protection of environment over cost and schedule considerations for Work.
- .2 Should unforeseen or peculiar safety related hazard or condition become evident during performance of Work, immediately take measures to rectify situation and prevent damage or harm. Advise Departmental Representative verbally and in writing.

1.8 FILING OF NOTICE

- .1 File Notice of Project with pertinent provincial health and safety authorities prior to beginning of Work.
 - .1 Departmental Representative will assist in locating address if needed.

1.9 PERMITS

- .1 Post permits, licenses and compliance certificates, specified in section 01 10 10, at Work Site.
- .2 Where a particular permit or compliance certificate cannot be obtained, notify Departmental Representative in writing and obtain approval to proceed before carrying out applicable portion of work.

1.10 HAZARD ASSESSMENTS

- .1 Perform site specific health and safety hazard assessment of the Work and its site.
- .2 Carryout initial assessment prior to commencement of Work with further assessments as needed during progress of work, [including when new trades and subcontractors arrive on site].
- .3 Record results and address in Health and Safety Plan.
- .4 Keep documentation on site for entire duration of the Work.

1.11 PROJECT/SITE CONDITIONS

- .1 MSDS Data sheets of pertinent hazardous and controlled products stored on site can be obtained from Departmental Representative.

1.12 MEETINGS

- .1 Attend pre-construction health and safety meeting, convened and chaired by Departmental Representative, prior to commencement of Work, at time, date and location determined by Departmental Representative. Ensure attendance of:
 - .1 Superintendent of Work.
 - .2 Designated Health & Safety Site Representative.
 - .3 Subcontractors.
- .2 Conduct regularly scheduled tool box and safety meetings during the Work in conformance with Occupational Health and Safety regulations.
- .3 Keep documents on site.

1.13 HEALTH AND SAFETY PLAN

- .1 Prior to commencement of Work, develop written Health and Safety Plan specific to the Work. Implement, maintain, and enforce Plan for entire duration of Work and until final demobilization from site.

- .2 Health and Safety Plan shall include the following components:
 - .1 List of health risks and safety hazards identified by hazard assessment.
 - .2 Control measures used to mitigate risks and hazards identified.
 - .3 On-site Contingency and Emergency Response Plan as specified below.
 - .4 On-site Communication Plan as specified below.
 - .5 Name of Contractor's designated Health & Safety Site Representative and information showing proof of his/her competence and reporting relationship in Contractor's company.
 - .6 Names, competence and reporting relationship of other supervisory personnel used in the Work for occupational health and safety purposes.
- .3 On-site Contingency and Emergency Response Plan shall include:
 - .1 Operational procedures, evacuation measures and communication process to be implemented in the event of an emergency.
 - .2 Evacuation Plan: site and floor plan layouts showing escape routes, marshalling areas. Details on alarm notification methods, fire drills, location of firefighting equipment and other related data.
 - .3 Name, duties and responsibilities of persons designated as Emergency Warden(s) and deputies.
 - .4 Emergency Contacts: name and telephone number of officials from:
 - .1 General Contractor and subcontractors.
 - .2 Pertinent Federal and Provincial Departments and Authorities having jurisdiction.
 - .3 Local emergency resource organizations.
 - .5 Harmonize Plan with Facility's Emergency Response and Evacuation Plan. Departmental Representative will provide pertinent data including name of PWGSC and Facility Management contacts.
- .4 On-site Communication Plan:
 - .1 Procedures for sharing of work related safety information to workers and subcontractors, including emergency and evacuation measures.
 - .2 List of critical work activities to be communicated with Facility Manager which have a risk of endangering health and safety of Facility users.
- .5 Address all activities of the Work including those of subcontractors.
- .6 Review Health and Safety Plan regularly during the Work. Update as conditions warrant to address emerging risks and hazards, such as whenever new trade or subcontractor arrive at Work Site.
- .7 Departmental Representative will respond in writing, where deficiencies or concerns are noted and may request re-submission of the Plan with correction of deficiencies or concerns.
- .8 Post copy of the Plan, and updates, prominently on Work Site.

1.14 SAFETY SUPERVISION

- .1 Employ Health & Safety Site Representative responsible for daily supervision of health and safety of the Work.
- .2 Health & Safety Site Representative may be the Superintendent of the Work or other person designated by Contractor and shall be assigned the responsibility and authority to:
 - .1 Implement, monitor and enforce daily compliance with health and safety requirements of the Work
 - .2 Monitor and enforce Contractor's site-specific Health and Safety Plan.
 - .3 Conduct site safety orientation session to persons granted access to Work Site.
 - .4 Ensure that persons allowed site access are knowledgeable and trained in health and

safety pertinent to their activities at the site or are escorted by a competent person while on the Work Site.

- .5 Stop the Work as deemed necessary for reasons of health and safety.
- .3 Health & Safety Site Representative must:
 - .1 Be qualified and competent person in occupational health and safety.
 - .2 Have site-related working experience specific to activities of the Work.
 - .3 Be on Work Site at all times during execution of the Work.
- .4 All supervisory personnel assigned to the Work shall also be competent persons.
- .5 Inspections:
 - .1 Conduct regularly scheduled safety inspections of the Work on a minimum [bi-weekly] basis. Record deficiencies and remedial action taken.
- .6 Cooperate with Facility's Occupational Health and Safety representative should one be designated by Departmental Representative.
- .7 Keep inspection reports and supervision related documentation on site.

1.15 TRAINING

- .1 Use only skilled workers on Work Site who are effectively trained in occupational health and safety procedures and practices pertinent to their assigned task.
- .2 Maintain employee records and evidence of training received. Make data available to Departmental Representative upon request.
- .3 When unforeseen or peculiar safety-related hazard, or condition occur during performance of Work, follow procedures in place for Employee's Right to Refuse Work in accordance with Acts and Regulations of Province having jurisdiction and advise Departmental Representative verbally and in writing.

1.16 MINIMUM SITE SAFETY RULES

- .1 Notwithstanding requirement to abide by federal and provincial health and safety regulations; ensure the following minimum safety rules are obeyed by persons granted access to Work Site:
 - .1 Wear appropriate PPE pertinent to the Work or assigned task; minimum being hard hat, safety footwear, safety glasses and hearing protection.
 - .2 Immediately report unsafe condition at site, near-miss accident, injury and damage.
 - .3 Maintain site and storage areas in a tidy condition free of hazards causing injury.
 - .4 Obey warning signs and safety tags.
- .2 Brief persons of disciplinary protocols to be taken for noncompliance.

1.17 CORRECTION OF NON-COMPLIANCE

- .1 Immediately address health and safety non-compliance issues identified by authority having jurisdiction or by Departmental Representative.

- .2 Provide Departmental Representative with written report of action taken to correct non-compliance of health and safety issues identified.
- .3 Departmental Representative will stop Work if non-compliance of health and safety regulations is not corrected in a timely manner.

1.18 INCIDENT REPORTING

- .1 Investigate and report the following incidents to Departmental Representative:
 - .1 Incidents requiring notification to Provincial Department of Occupational Safety and Health, Workers Compensation Board or to other regulatory Agency.
 - .2 Medical aid injuries.
 - .3 Property damage in excess of \$10,000.00,
 - .4 Interruptions to Facility operations resulting in an operational lost to a Federal department in excess of \$5,000.00.
- .2 Submit report in writing.

1.19 HAZARDOUS PRODUCTS

- .1 Comply with requirements of Workplace Hazardous Materials Information System (WHMIS).
- .2 Keep MSDS data sheets for all products delivered to site.
 - .1 Post on site.
 - .2 Submit copy to Departmental Representative.
 - .3 For interior work in an occupied Facility, post additional copy in one or more publically accessible locations.

1.20 BLASTING

- .1 Blasting or other use of explosives is not permitted on site.

1.21 POWDER ACTUATED DEVICES

- .1 Use powder actuated fastening devices only after receipt of written permission from Departmental Representative.

1.22 CONFINED SPACES

- .1 Abide by occupational health and safety regulations regarding work in confined spaces.

1.23 SITE RECORDS

- .1 Maintain on Work Site copy of safety related documentation and reports stipulated to be produced

in compliance with Acts and Regulations of authorities having jurisdiction and of those documents specified herein.

- .2 Upon request, make available to Departmental Representative or authorized Safety Officer for inspection.

1.24 POSTING OF DOCUMENTS

- .1 Ensure applicable items, articles, notices and orders are posted in conspicuous location on Work Site in accordance with Acts and Regulations of Province having jurisdiction.
- .2 Post other documents as specified herein, including:
 - .1 Site specific Health and Safety Plan.
 - .2 WHMIS data sheets.

END OF SECTION

1.1 RELATED SECTIONS

- .1 Waste Management and Disposal: Section 01 74 22.

1.2 DEFINITIONS

- .1 Hazardous Material: Product, substance, or organism that is used for its original purpose; and that is either dangerous goods or a material that may cause adverse impact to the environment or adversely affect health of persons, animals, or plant life when released into the environment.
- .2 Environmental Pollution and Damage: presence of chemical, physical, biological elements or agents which adversely affect human health and welfare; unfavourably alter ecological balances of importance to human life; affect other species of importance to humans; or degrade environment aesthetically, culturally and/or historically.
- .3 Environmental Protection: prevention/control of pollution and habitat or environment disruption during construction.

1.4 HAZARDOUS MATERIAL HANDLING

- .1 Store and handle hazardous materials in accordance with applicable federal and provincial laws, regulations, codes and guidelines. Store in location that will prevent spillage into the environment
- .2 Label containers to WHMIS requirements and keep MSDS data sheets on site for all hazardous materials.
- .3 Maintain inventory of hazardous materials and hazardous waste stored on site. List items by product name, quantity and date when storage began.
- .4 Store and handle flammable and combustible materials in accordance with National Fire Code.
- .5 Transport hazardous materials in accordance with federal Transportation of Dangerous Goods Regulations and applicable Provincial regulations.

1.5 DISPOSAL OF WASTES

- .1 Do not dispose of hazardous waste or volatile materials, such as mineral spirits, paints, thinners, oil or fuel into waterways, storm or sanitary sewers or waste landfill sites.
- .2 Dispose of hazardous waste in accordance with applicable federal and provincial laws, regulations, codes and guidelines.

END OF SECTION

1.1 GENERAL

- .1 Use new material and equipment unless otherwise specified.
- .2 Within 7 days of written request by Departmental Representative, submit following information for any materials and products proposed for supply:
 - .1 Name and address of manufacturer.
 - .2 Trade name, model and catalogue number.
 - .3 Performance, descriptive and test data.
 - .4 Compliance to specified standards.
 - .5 Manufacturer's installation or application instructions.
 - .6 Evidence of arrangements to procure.
 - .7 Evidence of manufacturer delivery problems or unforeseen delays.
- .3 Provide material and equipment of specified design and quality, performing to published ratings and for which replacement parts are readily available.
- .4 Use products of one manufacturer for equipment or material of same type or classification unless otherwise specified.
- .5 Permanent labels, trademarks and nameplates on products are not acceptable in prominent locations, except where required for operating instructions, or when located in mechanical or electrical rooms.

1.2 PRODUCT QUALITY

- .1 Contractor shall be solely responsible for submitting relevant technical data and independent test reports to confirm whether a product or system proposed for use meets contract requirements and specified standards.
- .2 Final decision as to whether a product or system meets contract requirements rest solely with the Departmental Representative in accordance with the General Conditions of the Contract.

1.3 ACCEPTABLE MATERIALS AND ALTERNATIVES

- .1 **Acceptable Materials:** When materials specified include trade names or trade marks or manufacturer's or supplier's name as part of the material description, select and only use one of the names listed for incorporation into the Work.
- .2 **Alternative Materials:** Submission of alternative materials to trade names or manufacturer's names specified must be done during the bidding period following procedures indicated in the Instructions to Bidders.
- .3 **Substitutions:** After contract award, substitution of a specified material will be dealt with as a change to the Work in accordance with the General Conditions of the Contract.

1.4 MANUFACTURERS INSTRUCTIONS

- .1 Unless otherwise specified, comply with manufacturer's latest printed instructions for materials and installation methods to be used. Do not rely on labels or enclosure provided with products. Obtain written instructions directly from manufacturers.
- .2 Notify Departmental Representative in writing of any conflict between these specifications and manufacturers instructions, so that Departmental Representative will designate which document is to be followed.

1.5 AVAILABILITY

- .1 Immediately notify Departmental Representative in writing of unforeseen or unanticipated material delivery problems by manufacturer. Provide support documentation as per clause 1.1.2 above.

1.6 WORKMANSHIP

- .1 Ensure quality of work is of highest standard, executed by workers experienced and skilled in respective duties for which they are employed.
- .2 Remove unsuitable or incompetent workers from site as stipulated in the General Conditions of the Contract.
- .3 Ensure cooperation of workers in laying out work. Maintain efficient and continuous supervision on site at all times.
- .4 Coordinate work between trades and subcontractors..
- .5 Coordinate placement of openings, sleeves and accessories.

1.7 FASTENINGS - GENERAL

- .1 Provide metal fastenings and accessories in same texture, colour and finish as base metal in which they occur. Prevent electrolytic action between dissimilar metals. Use non- corrosive fasteners, anchors and spacers for securing exterior work and in humid areas.
- .2 Space anchors within limits of load bearing or shear capacity and ensure that they provide positive permanent anchorage. Wood or organic material plugs not acceptable.
- .3 Keep exposed fastenings to minimum, space evenly and lay out neatly.
- .4 Fastenings which cause spalling or cracking of material to which anchorage is made, are not acceptable.
- .5 Do not use explosive actuated fastening devices unless approved by Departmental Representative. See section on Health and Safety Requirements in this regard.

1.8 FASTENINGS - EQUIPMENT

- .1 Use fastenings of standard commercial sizes and patterns with material and finish suitable for service.
- .2 Use heavy hexagon heads, semi-finished unless otherwise specified.
- .3 Bolts may not project more than one diameter beyond nuts.
- .4 Use plain type washers on equipment, sheet metal and soft gasket lock type washers where vibrations occur and, use resilient washers with stainless steel.

1.9 STORAGE, HANDLING AND PROTECTION

- .1 Deliver, handle and store materials in manner to prevent deterioration and soiling and in accordance with manufacturer's instructions when applicable. Provide same degree of protection to materials supplied by Departmental Representative.
- .2 Store packaged or bundled materials in original and undamaged condition with manufacturer's seal and labels intact. Do not remove from packaging or bundling until required in Work. Provide additional cover where manufacturer's packaging is insufficient to provide adequate protection.
- .3 Store products subject to damage from weather in weatherproof enclosures.
- .4 Store cementitious products clear of earth or concrete floors, and away from walls.
- .5 Keep sand, when used for grout or mortar materials, clean and dry. Store sand on wooden platforms and cover with waterproof tarpaulins during inclement weather.
- .6 Store sheet materials and lumber on flat, solid supports and keep clear of ground. Slope to shed moisture.
- .7 Store and mix paints in heated and ventilated room. Remove oily rags and other combustible debris from site daily. Take every precaution necessary to prevent spontaneous combustion.
- .8 Immediately remove damaged or rejected materials from site.
- .9 Touch-up damaged factory finished surfaces to Departmental Representative's satisfaction. Use touch-up materials to match original. Do not paint over name plates.

END OF SECTION

1.1 GENERAL

- .1 Conduct cleaning and disposal operations to comply with local ordinances and anti-pollution laws.
- .2 Store volatile waste in covered metal containers, and remove from premises at end of each working day.
- .3 Provide adequate ventilation during use of volatile or noxious substances. Use of building ventilation systems is not permitted for this purpose.

1.2 MATERIALS

- .1 Use only cleaning materials recommended by manufacturer of surface to be cleaned, and as recommended by cleaning material manufacturer.

1.3 CLEANING DURING CONSTRUCTION

- .1 Maintain work areas in a tidy condition, free from accumulations of waste material and debris. Clean areas on a daily basis.
- .2 Keep building entrances, corridors, stairwells and tenant occupied areas of building in a clean dust free condition at all times. Conduct thorough cleaning of these areas at end of each workshift when used by workers or affected by the Work.
- .3 Provide on-site containers for collection of waste materials and debris.
- .4 Use separate collection bins, clearly marked as to purpose, for source separation and recycling of waste and debris in accordance with waste management requirements specified.
- .5 Remove waste materials, and debris from site on a daily basis.
- .6 Schedule cleaning operations so that resulting dust, debris and other contaminants will not fall on wet, newly painted surfaces nor contaminate building systems.
- .7 Provide dust barriers, dividers, seals on doors and employ other dust control measures as required to ensure that dust and dirt, generated by work, are not transmitted to other areas of building. Should dust migrate into tenant occupied and public areas of building, employ such means as may be necessary to immediately clean all contaminated surfaces to the satisfaction of the Departmental Representative.
 - .1 See Section 01 50 00 for requirements on dust control and for erection of dust partitions.
- .8 Immediately clean all dust, dirt, smears, scuffs and soiled surfaces within tenant occupied areas resulting from the Work.
 - .1 Perform cleaning, dusting and washing operations, carpet vacuuming (including shampooing if deemed required by Departmental Representative) and floor washing as necessary to thoroughly clean all soiled surfaces.
- .9 Remove snow and ice from access doors used by workforce.

1.4 FINAL CLEANING

- .1 In preparation for acceptance of the completed work perform final cleaning.
- .2 Remove grease, dust, dirt, stains, labels, fingerprints, marks and other foreign materials, from interior and exterior finished surfaces. Clean and polish surfaces including glass, mirrors, hardware, wall tile, stainless steel, chrome, baked enamel, plastic laminate, mechanical and electrical fixtures.
- .3 Replace items with broken pieces, scratches or disfigured.
- .5 Vacuum clean and dust building interiors, behind grilles, louvres and screens.
- .7 Inspect finishes, fitments and equipment. Ensure specified workmanship and operation.
- .9 Remove debris and surplus materials from crawl areas, roof areas and other accessible concealed spaces.
- .10 Replace filters of mechanical equipment if exposed to dust during construction.

END OF SECTION

1.1 SECTION INCLUDES

- .1 Administrative procedures preceding inspection and acceptance of Work by Departmental Representative.

1.2 RELATED SECTIONS

- .1 Section 01 78 00: Closeout Submittals.

1.3 INSPECTION AND DECLARATION

- .1 Contractor's Inspection: Coordinate and perform, in concert with subcontractors, an inspection and check of all Work. Identify and correct deficiencies, defects, repairs and perform outstanding items as required to complete work in conformance with Contract Documents.
 - .1 Notify Departmental Representative in writing when deficiencies from Contractor's inspection have been rectified and that Work is deemed to be complete and ready for Departmental Representative's inspection of the completed work.
- .2 Departmental Representative's Inspection: Accompany Departmental Representative during all substantial and final inspections of the Work.
 - .1 Address defects, faults and outstanding items of work identified by such inspections.
 - .2 Advise Departmental Representative when all deficiencies identified have been rectified.
- .3 Note that Departmental Representative will not issue a Certificate of Substantial Performance of the work until such time that Contractor performs following work and turns over the specified documents:
 - .1 Project record as-built documents;
 - .2 Final Operations and Maintenance manuals;
 - .3 Demonstration and training complete with user manuals;
 - .4 Manufacturer's Guarantee certificates.
 - .5 Testing, adjusting and balancing of equipment and systems complete with submission of test reports.
- .4 Correct all discrepancies before Departmental Representative will issue the Certificate of Completion.

END OF SECTION

1.1 SECTION INCLUDES

- .1 Project Record Documents.
- .2 Operations and Maintenance data.

1.2 RELATED SECTIONS

- .1 Section 01 79 00: Demonstration and Training.

1.3 PROJECT RECORD DOCUMENTS

- .1 Departmental Representative will provide 2 white print sets of contract drawings and 2 copies of Specifications Manual specifically for "As-Built" purposes.
- .2 Maintain at site one set of the contract drawings and specifications to record actual As-Built site conditions.
- .3 Maintain up-to-date, real time as-built drawings and specifications in good condition and make available for inspection by the Departmental Representative upon request.
- .4 As-Built Drawings:
 - .1 Record changes in red ink on the prints. Mark only on one set of prints and at completion of work, neatly transfer notations to second set (also by use of red ink).
 - .2 Submit both sets to Departmental Representative prior to application for Certificate of Substantial Performance.
 - .3 Stamp all drawings with "As-Built". Label and place Contractor's signature and date.
 - .4 Show all modifications, substitutions and deviations from what is shown on the contract drawings.
- .5 Record following information:
 - .1 Location of all capped or terminated services and utilities.
 - .2 Plumbing, heating, air conditioning and ventilation, sprinkler and electrical service installation locations; all to be dimensioned and referenced to building columns or load bearing walls;
 - .3 Any details produced in the course of the contract by the Departmental Representative to supplement or to change existing design drawings;
 - .4 All change orders issued over the course of the contract must be documented on the finished As-Built documents, accurately and consistently depicting the changed condition as it applies to all affected drawing details.
- .5 As-Built Specifications: legibly mark in red each item to record actual construction, including:
 - .1 Changes made by Addenda and Change Orders.
 - .2 Mark up both copies of specifications; stamp "As-Built", sign and date similarly to drawings as per above clause.

- .6 Maintain As-Built documents current as the contract progresses. Departmental Representative will conduct reviews and inspections of the documents on a regular basis. Failure to maintain as-builts current and complete to satisfaction of the Departmental Representative shall be subject to financial penalties in the form of progress payment reductions and holdback assessments.
- .7 Submit on paper and in electronic format as pdf files. Forward pdf and in the native program format, and Autocad dwg files on USB compatible with PWGSC encryption requirements or through email or alternate electronic file sharing service such as ftp, as directed by Departmental Representative.

1.4 REVIEWED SHOP DRAWINGS

- .1 Provide a complete set of all shop drawings reviewed for project to incorporate into each copy of the Operations and Maintenance Manuals.
- .2 Submit full sets at same time and as part of the contents of the Operation and Maintenance Manuals specified.

1.5 OPERATIONS & MAINTENANCE MANUAL

- .1 O&M Manual - Definition: an organized compilation of operating and maintenance data including detailed technical information, documents and records describing operation and maintenance of individual products or systems as specified in individual sections of the specifications.
- .2 Manual Language: final manuals to be in [English] [French] [both English and French] languages.
- .3 Submission Date: submit complete operation and maintenance manual to Departmental Representative 3 weeks prior to application for Certificate of Substantial Performance of the work.
- .4 Binding:
 - .1 Assemble, coordinate, bind and index required data into Operation and Maintenance Manual.
 - .2 Use vinyl, hard covered, 3 "D" ring binders, loose leaf, sized for 215 x 280 mm paper, with spine pocket.
 - .3 Where multiple binders are needed, correlate data into related consistent groupings.
 - .4 Identify contents of each binder on spine.
 - .5 Organize and divide data following same numerical system as the section numbers of the Specification Manual.
 - .6 Dividers: separate each section by use of cardboard dividers and labels. Provide tabbed fly leaf for each individual product and system and give description of product or component.
 - .7 Type lists and notes. Do not hand write.
 - .8 Drawings, diagrams and manufacturers' literature must be legible. Provide with reinforced, punched binder tab. Bind in with text; fold larger drawings to size of text pages.
- .5 Manual Contents:
 - .1 Cover sheet containing:
 - .1 Date submitted.
 - .2 Project title, location and project number.
 - .3 Names and addresses of Contractor, and all Sub-Contractors.
 - .2 Table of Contents: provide full table of contents in each binder(s), clearly indicate which contents are in each binder.
 - .3 List of maintenance materials.

- .4 List of spare parts.
- .5 Original or certified copy of warranties and product guarantees.
- .6 Copy of reports and test results performed by Contractor as specified.
- .7 Product Information (PI Data) on materials, equipment and systems as specified in various sections of the specifications. Data to include:
 - .1 List of equipment including manufacturer's name, supplier, local source of supplies and service depot(s). Provide full addresses and telephone numbers.
 - .2 Nameplate information including equipment number, make, size, capacity, model number and serial number.
 - .3 Parts list.
 - .4 Installation details.
 - .5 Operating instructions.
 - .6 Maintenance instructions for equipment.
- .7 Shop drawings:
 - .1 Include complete set of reviewed shop drawings into each copy of the operations and maintenance manual.
 - .2 Fold and bind material professionally in a manner that corresponds with the specification section numbering system.
 - .3 When large quantity of data is submitted, place into separate binders of same size as O&M binders.

1.7 SPARE PARTS, TOOLS AND MAINTENANCE MATERIALS

- .1 Provide spare parts, special tools and extra materials for maintenance purposes in quantities specified in individual specification sections.
- .2 Tag all items with associated function or equipment.
- .3 Provide items of same manufacture and quality as items in Work.
- .4 Deliver to site in well packaged condition. Store in location as directed by Departmental Representative.
- .5 Prepare and submit complete inventory list of items supplied. Include list within Maintenance Manual.

END OF SECTION

1.1 RELATED SECTIONS

- .1 Operations and Maintenance Manual: Section 01 78 00.

1.2 DESCRIPTION

- .1 Demonstrate scheduled operation and maintenance of equipment and systems to Owner's personnel prior to date of final inspection.
- .2 Departmental Representative will provide a list of Owner's personnel to receive instructions,
- .3 Cooperate with Departmental Representative in coordinating time and attendance of Owner's personnel with manufacturer's training Representative(s).

1.3 QUALITY CONTROL

- .1 Ensure that only personnel from own forces, Subcontractors or Suppliers competent and fully knowledgeable in the particular material component, equipment or system installation are used to provide training and demonstrations.
- .2 When specified in individual Sections, obtain the manufacturers authorized Representative to demonstrate operation of equipment and systems, instruct Owner's personnel, and provide written report that demonstration and instructions have been completed.
- .3 Upon request, provide evidence to Departmental Representative of individual Trainor's knowledge and qualifications.

1.4 SUBMITTALS

- .1 Submit schedule of time, date and complete list of equipment and systems for which demonstration and training sessions will be provided. Submit schedule a minimum of 2 weeks prior to designated dates, for Departmental Representative's approval.
- .2 Submit report within 1 week after completion of demonstration, that demonstration and instructions have been satisfactorily completed. Provide time and date of when each demonstration was actually given, with list of persons present.

1.5 CONDITIONS FOR DEMONSTRATIONS

- .1 Prior to carrying out demonstration and training, ensure that equipment has been inspected and tested, is fully operational, has been performance verified and TAB has been carried out.
- .2 Provide copies of completed operation and maintenance manuals for use in demonstrations and instructions.

1.6 PREPARATION

- .1 Verify that conditions for demonstration and instructions comply with requirements.
- .2 Verify that designated personnel are present.

1.7 DEMONSTRATION AND INSTRUCTIONS

- .1 Include the following items within the demonstration and training:
 - .1 Demonstrate start-up, operation, control, adjustment, trouble-shooting, servicing, and maintenance of each of equipment.
 - .2 Instruct personnel in all phases of operation and maintenance using operation and maintenance manuals as the basis of instruction.
 - .3 Review contents of manual in detail to explain all aspects of operation and maintenance.
 - .4 Prepare and insert additional data in operations and maintenance manuals when the need for additional data becomes apparent during instructions.
 - .5 Provide other specific training and instructions as specified in trade sections.

1.8 TIME ALLOCATED FOR INSTRUCTIONS

- .1 Observe the allocated time period specified in trade sections. Provide additional time when required to ensure all personnel fully understand all aspects of the information and instructions being provided. Allow for questions by participants.

END OF SECTION

1.1 GENERAL

- .1 Due to nature of the JAG Building, and CRA operations therein, security regulations pertaining to site will be in place during the work resulting in need for:
 - .1 Control and limitation of movement of construction workers inside building;
 - .2 Escort and continuous supervision of workers by security personnel; unless, as per Clause 1.2 not required;
 - .3 Specific rules and regulations as specified in this section and as directed by the Departmental Representative or CRA Security to be stringently followed.

- .2 It is the Contractor's responsibility to:
 - .1 Provide Commissionaires as per Clause 1.2;
 - .2 Become familiar with and abide by CRA Security rules and regulations;
 - .3 Brief all workers and subcontractors with respect to CRA Security regulations and ensure that they abide by all rules and directives.
 - .4 Allow for 1 to 2 hours of on-site training per Commissionaire, by CRA Security, prior to work commencing on-site

- .3 The Departmental Representative will coordinate pre-construction training, for the Supplier's retained Commissionaires, by CRA Security. CRA will provide details and directives on control and movement within the building.

- .4 Any infraction of CRA Security requirements on the part of the Supplier, members of work force or any Subcontractor in their employ, could result in:
 - .1 Immediate removal of offending party from the site. The Commissionaire is empowered with this Authority on behalf of CRA Security.

1.2 SECURITY PERSONNEL

- .1 Obtain and pay for the services of security personnel, employed by the Canadian Corps of Commissionaires to provide escort and security supervision of workers and Supplier representatives during the work.

- .2 Commissionaires employed on this project must have a current Reliability Security Clearance status issued by CISD (refer to Cl. 1.3).

-
- .3 Provide sufficient Commissionaire to assure, *per work shift, visual contact by the Commissionaires of each of the Contractor's workers or representatives.*
 - .4 Commissionaires are required outside of the CRA work hours of 7 a.m. to 5 p.m. Mon to Fri.
 - .5 During CRA work hours, Commissionaires are required if any worker or representative does not have a valid CISD Reliability Clearance number.
 - .6 Commissionaires to have the following responsibilities:
 - .1 Limit movement of workers to within the boundaries established by CRA Security and the Departmental Representative for each work phase;
 - .2 Maintain a security control list of workers authorized to be on site as determined by the Contractor, the Departmental Representative, and CRA Security;
 - .3 Manage the distribution and control of worker ID tags;
 - .4 Escort workers who need to circulate on-site beyond the established boundaries of work, including the corridors, stairwells and elevators used for access to and from work areas.
 - .5 Escort and supervise short term visitors who need access to the work site; such as, for material deliveries or to conduct inspections.
 - .6 Maintain visual contact of each worker. Commissionaires' effectiveness of maintaining visual contact will be monitored by CRA 24/7 Security. CRA Security may guide or adjust Commissionaires monitoring technique.
 - .5 Provide additional Commissionaires when required to perform supervision or escort function as may be needed due to Contractor's work operations in order that no worker is left unsupervised inside building and beyond main lobby.
 - .6 Ensure Commissionaire(s) are present on site for entire work shift including work breaks and time period after work shifts until all workers have left the building.
 - .7 Ensure Commissionaire is fitted with and wears approved safety hard hat, safety footwear and other personnel protective equipment appropriate to work in accordance with applicable Occupational Health and Safety requirements specified.

1.3 CISD CLEARANCE CONTACT

- .1 **Address for Submission of Application:**
Canadian Industrial Security Directorate (CISD)

Public Services and Procurement Canada
Contract Security Program
Personnel Security Screening Division
2745 Iris Street
c/o PSPC Central Mail Room
Portage III 0B3
11 Laurier St
Gatineau QC K1A 0S5

.2 Application: personal, criminal and credit checks required.

.3 Website for Forms and Instructions:

<https://www.tpsgc-pwgsc.gc.ca/esc-src/personnel/enquete-screening-eng.html#taba>

1.4 SECURITY PASSES

- .1 Visitor or worker ID Tags are required for all personnel requiring access inside the building and beyond the main public lobby.
- .2 ID Tags will be provided by CRA Security, issued to Contractor for distribution to authorized workers which shall also be placed on the Security Control List specified below.
- .3 All persons while on site, must wear the ID Tag issued regardless of daytime or nighttime work.
- .4 Be responsible to obtain ID Tags before work commences, including those required by subcontractors, and continually control their distribution and use by workers. Submit request for tags as early as possible and prior to commencement of work.
- .5 For the duration of this contract, anyone not in possession of the ID Tag will not be allowed access on site.
- .6 At end of project, return to Departmental Representative all tags issued to workers and to subcontractors.
 - .1 The Departmental Representative will levy a \$25.00 holdback against the Contract for each pass not returned regardless of the reason the pass is not returned.
- .7 Immediately report any lost, stolen or destroyed ID Tags to the Departmental Representative.

1.5 SECURITY CONTROL LIST

- .1 Provide a list of employee names from workforce and from subcontractors who will be present at site during the course of work.

- .2 List to include each person's name, address and telephone number.
- .3 Submit copy of list to Departmental Representative and to Security Commissionaire for control of workers.
- .4 Update list as work and clearances progress and to indicate the workers CISD clearance number.
- .5 Ensure that each worker can provide proof of identity upon demand, when requested by CRA Security Personnel, Departmental Representative or by the JAG Facility Manager.

1.6 BUILDING ACCESS

- .1 Keys and security access cards given to the Commissionaire for his sole possession, as determined by Departmental Representative, shall not under any circumstances be given to any worker or subcontractor.
- .2 At end of project, return to Departmental Representative all keys [and access cards] issued. Departmental Representative will deduct from final contract payment, \$25.00 for each item not returned, regardless of the reason.
- .3 Immediately report to Departmental Representative any lost, stolen or destroyed keys [and door security access cards].
- .4 When work must be carried out during Off Hours or beyond the work hours previously agreed upon at start of work, provide notice within 48 hours beforehand to minimize impact on Facility's security and tenant operations.

END OF SECTION