



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
1713 Bedford Row
Halifax, N.S./Halifax, (N.É.)
Halifax
Nova Scotia
B3J 1T3
Bid Fax: (902) 496-5016

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions
1713 Bedford Row
Halifax, N.S./Halifax, (N.É.)
Halifax
Nova Scotia
B3J 1T3

Title - Sujet Data Centre Hosting Services	
Solicitation No. - N° de l'invitation MA021-200048/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client MA021-20-0048	Date 2020-12-09
GETS Reference No. - N° de référence de SEAG PW-SHAL-219-11124	
File No. - N° de dossier HAL-0-85155 (219)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Atlantic Standard Time AST on - le 2021-01-07 Heure Normale de l'Atlantique HNA	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Richard, Linda K.	Buyer Id - Id de l'acheteur hal219
Telephone No. - N° de téléphone (902) 402-9059 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

SOLICITATION AMENDMENT 1

This amendment is issued to reflect the following:

1. In Annex "A" – Statement of Work: Under Section A.2 Data Centre Minimum Standards

Delete: in its entirety

Insert:

Type of facility	<ul style="list-style-type: none">Designed to Tier 3 standards
Availability Performance	<ul style="list-style-type: none">99% 99.982%No more than 1.6 hours of downtime per year
Electrical grid supply	<ul style="list-style-type: none">2 main service entrances feed
power generation	<ul style="list-style-type: none">N+1 configurationOn-site fuel capacity – 12 hoursLive refuelling available as requiredPriority delivery agreement
Uninterruptible power supplies (UPS)	<ul style="list-style-type: none">30 minutes of protection from power outages
Environmental Monitoring	<ul style="list-style-type: none">24/7 x365 days per year
Power distribution/Monitoring	<ul style="list-style-type: none">Redundant power supply to customer cabinetStandard configuration with two cabinet distribution units (CDU) in each cabinetPeak power monitored at the cabinet and distribution levels
Physical and Process Access Controls	<ul style="list-style-type: none">Continuous controlled and recorded access 24x7x365
HVAC (Heating, Ventilation and Cooling)	<ul style="list-style-type: none">Cooling is handled through a centralized cooling systemN+1 chillersCooling demand is monitored and adjusted to support the growth of the Data Center and respective rooms.Redundancy and fault tolerance built into the cooling solution
Fire detection and suppression	<ul style="list-style-type: none">Detection zones for each room within the data center.Fire Suppression System:<ul style="list-style-type: none">Fire ExtinguishersFire AlarmsSmoke Detectors /Heat SensorsDry/Waterless fire suppression systems

Solicitation No. - N° de l'invitation
MA021-200048
Client Ref. No. - N° de réf. du client
MA021-20-0048

Amd. No. - N° de la modif.
001
File No. - N° du dossier
HAL-0-85155

Buyer ID - Id de l'acheteur
ha1219
CCC No./N° CCC - FMS No./N° VME

2. Add to Annex "A" – Statement of Work

OFFEROR MUST SIGN TO CONFIRM THE FOLLOWING:		
1.	Offeror confirms they meet all Data Centre Minimum Standards as specified in Section A-2, Annex "A" of the Statement of Work	
2.	Company Name: Authorized Person: Title: Date: Signature	

All other terms and conditions remain unchanged.