

**RETURN BIDS TO:**

Parks Canada Agency Bid Receiving Unit
National Contracting Services

Bid Fax: 1-877-558-2349

Bid E-mail Address:

pc.soumissionsest-bidseast.pc@canada.ca

This is the only acceptable email address for responses to the bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address may not be accepted.

The maximum email file size is **15 megabytes**. The Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

**REVISION 002 TO AN
INVITATION TO TENDER**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

Issuing Office:

Parks Canada Agency
National Contracting Services
Gatineau, QC

Title:

Access Road Resurfacing and Culvert Replacement, Forges-du-Saint-Maurice National Historic

Solicitation No.:

5P201-20-0075/A

Date:

December 17, 2020

Amendment No.:

002

Client Reference No.:

2140

GETS Reference No.:

PW-20-00928724

Solicitation Closes:

At: 2:00PM

On: January 19, 2021

Time Zone:

EST/HNE

F.O.B.:

Plant: ☐ Destination: ☒ Other: ☐

Address Enquiries to:

Christine Piché

Telephone No.:

873-355-8841

Fax No.:

1-877-558-2349

Email Address:

Christine.piche2@canada.ca

Destination of Goods, Services, and Construction:

See Herein

TO BE COMPLETED BY THE BIDDER**Vendor/ Firm Name:****Address:****Telephone No.:****Fax No.:**

Name of person authorized to sign on behalf of the Vendor/ Firm (type or print):

Signature:**Date:**

Solicitation No.:
5P201-20-0075/A

Amendment No.:
002

Contracting Authority:
Christine Piché

Client Reference No.:
2140

Title:
Access Road Resurfacing and Culvert Replacement, Forges-du-Saint-Maurice
National Historic

Amendment 002

The following is hereby amended:

- A. Answer questions from bidders.

A. QUESTIONS AND ANSWERS

1 QUESTIONS - ANSWERS

- .1 In section 2.11 of the bid table, do we need to plan for a temporary water connection?
- .1 Answer: You do not need to plan for temporary water supply. The water may be cut off to divert the water main. However, the water must be turned back on the same day.
- .2 In section 2.11 of the bid table, do we need to plan for system cleaning and disinfection following diversion of the water supply system?
- .1 Answer: Yes, tests must be completed for spot work on the water supply system, as specified in BNQ 1809-300/2018. The work on the water supply system must be performed by competent individuals in accordance with the requirements of Chapter V of the *Regulation respecting the quality of drinking water*.

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED