

GENERAL NOTES:

1. REFER TO DRAWING ED0.1 FOR DEMOLITION NOTES.

SPECIFIC NOTES:

1. CONTRACTOR TO LEAVE PANEL L22 OPERATIONAL. USE PANEL L22 TO PROVIDE CIRCUITS TO STAIRWAY (GRID LINE Z/21 AND Z/13) AND FIRE ALARM CONTROL PANEL.
2. CONTRACTOR TO ALLOW FOR THE SUPPLY AND INSTALLATION OF EIGHT (8) LED HIGH BAY FIXTURES. STANDARDS OF ACCEPTANCES IS 2x4 VAPOUR TIGHT SUSPENDED LED FIXTURE, 0–10 VOLT DIMMING DRIVER, 24.000 LUMENS, CRI 80 AND 120 VOLT. POWER FROM PANEL L22 WITH TEMPORARY AC90.
3. CONTRACTOR TO ALLOW FOR THE SUPPLY AND INSTALLATION OF EIGHT (8) LED HIGH BAY FIXTURES. STANDARDS OF ACCEPTANCES IS 2x4 VAPOUR TIGHT SUSPENDED LED FIXTURE, 0–10 VOLT DIMMING DRIVER, 24.000 LUMENS, CRI 80 AND 120 VOLT. POWER FROM PANEL IN MAIN ELECTRICAL ROOM WITH TEMPORARY AC90.

DEMOLITION PLAN – FIRST FLOOR – POWER

1 / ED2.1

SCALE : 1:100

0m 1m 2m 3m 4m 5m 6m 7m 8m 9m 10m

Public Works and Government Services Canada / Travaux Publics et Services gouvernementaux Canada

KEY PLAN 1:5000
COAST GUARD
WAREHOUSE
ENERGY
SALT WATER
FISH LAB (AREA OF CONSTRUCTION)
STRICKLAND
BEDFORD BASIN
PIER

REPUBLIC ARCHITECTURE INC
385 St. Mary Avenue
Winnipeg, MB R3C 0N1
T 204 989 0102
F 204 989 0094
www.republicarchitecture.ca

MCW Maricor
7051 Bayer Road, Suite 102
Halifax, NS B3L 2C1
Bus: (506) 857-8880 Fax: (506) 859-8393
WWW.MCW.COM ENG. JOB NO. 10-19-100

Gardiner MacNeill
Digitally signed by Gardiner MacNeill
Date: 2020.12.17 14:21:26 -04'00'

PROFESSIONAL ENGINEERS PROVINCE OF NOVA SCOTIA DATE DEC 14 2020 MacNEILL 8687

revisions		date
0	ISSUED FOR TENDER	DEC.14 2020

project / projet

FISH LAB RENOVATION FACILITY FOR INTELLIGENT MARINE SYSTEMS B.I.O. DARTMOUTH, N.S. DEMOLITION

drawing / dessin

DEMOLITION FIRST FLOOR POWER

designed H.E.G./G.A.M. / conçu
date DECEMBER 14, 2020
drawn H.E.G. / dessiné
date DECEMBER 14, 2020
approved G.A.M. / approuvé
date DECEMBER 14, 2020
Tender / Soumission
IAN SCELES
PWGSC Project Manager / Administrateur de projets TPSGC

project number / no. du projet
R.089911.001

drawing no. / no. du dessin
ED2.1