



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Travaux publics et Services gouvernementaux
Canada

Voir dans le document/

See herein

NA

Québec

NA

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Travaux publics et Services gouvernementaux Canada
Place Bonaventure, portail Sud-Oue
800, rue de La Gauchetière Ouest
7^e étage, suite 7300
Montréal
Québec
H5A 1L6

Title - Sujet Remplacement des contrôles CVAC	
Solicitation No. - N° de l'invitation EF944-211315/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client R.107062.001	Date 2021-01-07
GETS Reference No. - N° de référence de SEAG PW-\$MTC-410-15948	
File No. - N° de dossier MTC-0-43160 (410)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Eastern Standard Time EST on - le 2021-01-21 Heure Normale du l'Est HNE	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Spina, Angelina	Buyer Id - Id de l'acheteur mtc410
Telephone No. - N° de téléphone (514) 703-4764 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

INVITATION TO TENDER

**Replacement of HVAC Controls of Buildings Nos. 001 and 002
Situated at 3600 Casavant Boulevard West, St.Hyacinthe, QC, J2S 8E3.**

THIS DOCUMENT CONTAINS AN INDUSTRIAL SECURITY REQUIREMENT

For further instructions please consult "Special Instruction to Bidders", SI09, "Industrial Security Related Requirements" and "Supplementary Conditions" SC01 "Industrial Security Related Requirements, Document Safeguarding Location".

Note to Bidders, there will no Public Opening for the purposes of this solicitation. See SI05 for further Instructions.

Amendment 004

THE INVITATION TO TENDER IS MODIFIED AS MENTIONED BELOW:

Please find enclosed herewith the above-mentioned addendum 2.

The closing date for the above mentioned project has been postponed from January 15th 2021 at 2:00 pm until January 21st 2021 at 2:00 PM.

ALL OTHER TERMS, CLAUSES AND CONDITIONS REMAIN UNCHANGED.

TABLE OF CONTENTS

SPECIAL INSTRUCTIONS TO BIDDERS (SI)

- SI01 Bid Documents
- SI02 Enquiries during the Solicitation Period
- SI03 Optional Site Visit
- SI04 Revision of Bid
- SI05 Bid Results
- SI06 Insufficient Funding
- SI07 Bid Validity Period
- SI08 Construction Documents
- SI09 Industrial Security Related Requirements
- SI10 Web Sites

R2710T GENERAL INSTRUCTIONS - CONSTRUCTION SERVICES - BID SECURITY REQUIREMENTS (GI) (2019-05-30)

The following GI's are included by reference and are available at the following Web Site

<https://buyandsell.gc.ca/policy-and-guidelines/standard-acquisition-clauses-and-conditions-manual/5/R>

- GI01 Integrity Provisions - Bid
- GI02 Completion of Bid
- GI03 Identity or Legal Capacity of the Bidder
- GI04 Applicable Taxes
- GI05 Capital Development and Redevelopment Charges
- GI06 Registry and Pre-qualification of Floating Plant
- GI07 Listing of Subcontractors and Suppliers
- GI08 Bid Security Requirements
- GI09 Submission of Bid
- GI10 Revision of Bid
- GI11 Rejection of Bid
- GI12 Bid Costs
- GI13 Procurement Business Number
- GI14 Compliance with Applicable Laws
- GI15 Approval of Alternative Materials
- GI16 Performance Evaluation
- GI17 Conflict of Interest-Unfair Advantage
- GI18 Code of Conduct for Procurement—bid

CONTRACT DOCUMENTS (CD)

SUPPLEMENTARY CONDITIONS (SC)

- SC01 Industrial Security Related Requirements, Documents Safeguarding
- SC02 Limitation of Liability
- SC03 Insurance Terms

BID AND ACCEPTANCE FORM (BA)

- BA01 Identification
- BA02 Business Name and Address of Bidder
- BA03 The Offer
- BA04 Bid Validity Period
- BA05 Acceptance and Contract
- BA06 Construction Time
- BA07 Bid Security
- BA08 Signature

Solicitation No. - N° de l'invitation
EF944-211315
Client Ref. No. - N° de réf. du client
R.107062.001

Amd. No. - N° de la modif.
004
File No. - N° du dossier
MTC-0-43160

Buyer ID - Id de l'acheteur
MTC410
CCC No./N° CCC - FMS No./N° VME

APPENDIX "1" INTEGRITY PROVISIONS

APPENDIX "2" VOLUNTARY CERTIFICATION TO SUPPORT THE USE OF APPRENTICES

ANNEX "A" ANNEX "B" CERTIFICATE OF INSURANCE

ANNEX "B" VOLUNTARY REPORTS FOR APPRENTICES EMPLOYED DURING THE CONTRACT

ANNEX "C" SECURITY REQUIREMENT CHECK LIST (SRCL)

SPECIAL INSTRUCTIONS TO BIDDERS (SI)

SI01 BID DOCUMENTS

1. The following are the Bid Documents:
 - a. Invitation to Tender - Page 1;
 - b. Special Instructions to Bidders;
 - c. General Instructions - Construction Services - Bid Security Requirements R2710T (2019-05-30)
 - d. Clauses & Conditions identified in "Contract Documents";
 - e. Drawings and Specifications;
 - f. Bid and Acceptance Form and related Appendix(s); and
 - g. Any amendment issued prior to solicitation closing.

Submission of a bid constitutes acknowledgement that the Bidder has read and agrees to be bound by these documents.

2. General Instructions - Construction Services - Bid Security Requirements R2710T is incorporated by reference and is set out in the Standard Acquisition Clauses and Conditions (SACC) Manual, issued by Public Works and Government Services Canada (PWGSC). The SACC Manual is available on the PWGSC Web site: <https://buyandsell.gc.ca/policy-and-guidelines/standard-acquisition-clauses-and-conditions-manual/5/R>

SI02 ENQUIRIES DURING THE SOLICITATION PERIOD

1. Enquiries regarding this bid must be submitted in writing to the Contracting Authority named on the Invitation to Tender - Page 1 at e-mail address angelina.spina@tpsgc-pwgsc.gc.ca Except for the approval of alternative materials as described in GI15 of R2710T, enquiries should be received no later than **3 business days** prior to the date set for solicitation closing to allow sufficient time to provide a response. Enquiries received after that time may result in an answer NOT being provided.
2. To ensure consistency and quality of the information provided to Bidders, PWGSC will examine the content of the enquiry and will decide whether or not to issue an amendment.
3. All enquiries and other communications related to this bid sent throughout the solicitation period must be directed ONLY to the Contracting Authority named in paragraph 1. above. Failure to comply with this requirement may result in the bid being declared non-compliant.

SI03 OPTIONAL SITE VISIT

1. There will be a site visit on Wednesday December 9th 2020 at 2h00 PM. Interested bidders are to meet the main door of the establishment located at 3600 Casavant Boulevard West, St.Hyacinthe, QC, J2S 8E3. All the individuals interested in attending the site visit must send forward an email at angelina.spina@tpsgc-pwgsc.gc.ca to confirm their presence.

SI04 REVISION OF BID

A bid may be revised by facsimile in accordance with GI10 of R2710T. The facsimile number for receipt of revisions is (514) 496-3822.

SI05 BID RESULTS

1. There will be no Public Opening for the purposes of this solicitation.
2. The responsive bid carrying the lowest price will be recommended for contract award.
3. Following solicitation closing, bid results may be obtained by e-mailing a request to angelina.spina@tpsgc-pwgsc.gc.ca.

SI06 INSUFFICIENT FUNDING

In the event that the lowest compliant bid exceeds the amount of funding allocated for the Work, Canada in its sole discretion may

- a. cancel the solicitation; or
- b. obtain additional funding and award the Contract to the Bidder submitting the lowest compliant bid.

SI07 BID VALIDITY PERIOD

1. Canada reserves the right to seek an extension to the bid validity period prescribed in BA04 of the Bid and Acceptance Form. Upon notification in writing from Canada, Bidders will have the option to either accept or reject the proposed extension.
2. If the extension referred to in paragraph 1. above is accepted, in writing, by all those who submitted bids, then Canada will continue immediately with the evaluation of the bids and its approvals processes.
3. If the extension referred to in paragraph 1. above is not accepted in writing by all those who submitted bids then Canada will, at its sole discretion, either
 - a. continue to evaluate the bids of those who have accepted the proposed extension and seek the necessary approvals; or
 - b. cancel the invitation to tender.
4. The provisions expressed herein do not in any manner limit Canada's rights in law or under GI11 of R2710T.

SI08 CONSTRUCTION DOCUMENTS

The successful Contractor will be provided **with 1 electronic** of the sealed and signed drawings, the specifications and the amendments upon acceptance of the offer. Obtaining more copies will be the responsibility of the Contractor including costs.

SI09 INDUSTRIAL SECURITY RELATED REQUIREMENTS

1. **At bid closing, the Bidder must hold a valid** Security Clearance as indicated in section SC01 of the Supplementary Conditions. Failure to comply with this requirement will render the Bid non-compliant and no further consideration will be given to the Bid.
2. The successful Bidder's personnel, as well as any subcontractor and its personnel, who are required to perform any part of the Work pursuant to the subsequent contract must meet the mandatory security requirement as indicated in section SC01 of the Supplementary Conditions. **Individuals who do not have the required level of security will not be allowed on site.** It is the responsibility of the successful Bidder to ensure that the security requirements are met throughout the performance of the contract. Canada will not be held liable or accountable for any delays or additional costs associated with the successful Bidder's non-compliance with the mandatory security requirement.
3. For additional information on security requirements, bidders should consult the Web site Industrial Security Program

SI10 WEB SITES

The connection to some of the Web sites in the solicitation documents is established by the use of hyperlinks. The following is a list of the addresses of the Web sites:

Treasury Board Appendix L, Acceptable Bonding Companies
<http://www.tbs-sct.gc.ca/pol/doc-eng.aspx?id=14494§ion=text#appl>

Buy and Sell

<https://www.achatsetventes-buyandsell.gc.ca>

Canadian economic sanctions

<http://www.international.gc.ca/sanctions/index.aspx?lang=eng>

Contractor Performance Evaluation Report (Form PWGSC-TPSGC 2913)

<http://www.tpsgc-pwgsc.gc.ca/app-acq/forms/documents/2913.pdf>

Bid Bond (form PWGSC-TPSGC 504)

<http://www.tpsgc-pwgsc.gc.ca/app-acq/forms/documents/504.pdf>

Performance Bond (form PWGSC-TPSGC 505)

http://www.tpsgc-pwgsc.gc.ca/app-acq/forms/documents/505_eng.pdf

Labour and Material Payment Bond (form PWGWS-TPSGC 506)

<http://www.tpsgc-pwgsc.gc.ca/app-acq/forms/documents/506.pdf>

Standard Acquisition Clauses and Conditions (SACC) Manual

<https://buyandsell.gc.ca/policy-and-guidelines/standard-acquisition-clauses-and-conditions-manual/5/R>

PWGSC, Industrial Security Services

<http://ssi-iss.tpsgc-pwgsc.gc.ca/index-eng.html>

PWGSC, Code of Conduct and Certifications

<http://www.tpsgc-pwgsc.gc.ca/app-acq/cndt-cndct/contexte-context-eng.html>

Construction and Consultant Services Contract Administration Forms Real Property Contracting

<http://www.tpsgc-pwgsc.gc.ca/app-acq/forms/formulaires-forms-eng.html>

Declaration Form

<http://www.tpsgc-pwgsc.gc.ca/ci-if/formulaire-form-eng.html>

Trade agreements

<https://buyandsell.gc.ca/policy-and-guidelines/Policy-and-Legal-Framework/Trade-Agreements>

CONTRACT DOCUMENTS (CD)

1. The following are the Contract Documents:
 - a. Contract Page when signed by Canada;
 - b. Duly completed Bid and Acceptance Form and any Appendices attached thereto;
 - c. Drawings and Specifications;
 - d. General Conditions and clauses

GC1	General Provisions – Construction Services	R2810D	(2017-11-28);
GC2	Administration of the Contract	R2820D	(2016-01-28);
GC3	Execution and Control of the Work	R2830D	(2019-11-28);
GC4	Protective Measures	R2840D	(2008-05-12);
GC5	Terms of Payment	R2850D	(2016-01-28);
GC6	Delays and Changes in the Work	R2860D	(2019-05-30);
GC7	Default, Suspension or Termination of Contract	R2870D	(2018-06-21);
GC8	Dispute Resolution	R2880D	(2019-11-28);
GC9	Contract Security	R2890D	(2018-06-21);
GC10	Insurance	R2900D	(2008-05-12);
	Allowable Costs for Contract Changes Under GC6.4.1	R2950D	(2015-02-25);
 - e. Supplementary Conditions
 - f. Any amendment issued or any allowable bid revision received before the date and time set for solicitation closing;
 - g. Any amendment incorporated by mutual agreement between Canada and the Contractor before acceptance of the bid; and
 - h. Any amendment or variation of the contract documents that is made in accordance with the General Conditions.
2. The documents identified by title, number and date above are incorporated by reference and are set out in the Standard Acquisition Clauses and Conditions (SACC) Manual, issued by Public Works and Government Services Canada (PWGSC). The SACC Manual is available on the PWGSC Web site: <https://buyandsell.gc.ca/policy-and-guidelines/standard-acquisition-clauses-and-conditions-manual>
3. The language of the contract documents is the language of the Bid and Acceptance Form submitted.

SUPPLEMENTARY CONDITIONS (SC)

SC01 INDUSTRIAL SECURITY RELATED REQUIREMENTS, DOCUMENT SAFEGUARDING

The following security requirement (SRCL and related clauses) applies and form part of the Contract.

SECURITY REQUIREMENT FOR CANADIAN SUPPLIER: PWGSC FILE No. R-107062-001

1. The Contractor/Offeror must, at all times during the performance of the Contract/Standing Offer, hold a valid Designated Organization Screening (DOS), issued by the Contract Security Program (CSP), Public Works and Government Services Canada (PWGSC).
2. The Contractor/Offeror personnel requiring access to PROTECTED information, assets or sensitive site(s) must EACH hold a valid RELIABILITY STATUS, granted or approved by the CSP, PWGSC.
3. The Contractor/Offeror MUST NOT remove any PROTECTED information or assets from the identified site(s), and the Contractor/Offeror must ensure that its personnel are made aware of and comply with this restriction.
4. Subcontracts which contain security requirements are NOT to be awarded without the prior written permission of the CSP, PWGSC.
5. The Contractor/Offeror must comply with the provisions of the:
 - a) Security Requirements Check List and security guide (if applicable), attached at Annex C;
 - b) Industrial Security Manual (Latest Edition).

SC02 LIMITATION OF LIABILITY

GC1.6 of R2810D is deleted and replaced with the following:

GC1.6 Indemnification by the Contractor

1. The Contractor shall indemnify and save Canada harmless from and against all claims, demands, losses, costs, damages, actions, suits, or proceedings whether in respect to losses suffered by Canada or in respect of claims by any third party, brought or prosecuted and in any manner based upon, arising out of, related to, occasioned by, or attributable to the activities of the Contractor in performing the Work, provided such claims are caused by the negligent or deliberate acts or omissions of the Contractor, or those for whom it is responsible at law.

The Contractor's obligation to indemnify Canada for losses related to first party liability shall be limited to:

- a. In respect to each loss for which insurance is to be provided pursuant to the insurance requirements of the Contract, the Commercial General Liability insurance limit for one occurrence as referred to in the insurance requirements of the Contract .
- b. In respect to losses for which insurance is not required to be provided in accordance with the insurance requirements of the Contract, the greater of the Contract Amount or \$5,000,000, but in no event shall the sum be greater than \$20,000,000.

The limitation of this obligation shall be exclusive of interest and all legal costs and shall not apply to any infringement of intellectual property rights or any breach of warranty obligations.

3. The Contractor's obligation to indemnify Canada for losses related to third party liability shall have no limitation and shall include the complete costs of defending any legal action by a third party. If requested by Canada, the Contractor shall defend Canada against any third party claims.
4. The Contractor shall pay all royalties and patent fees required for the performance of the Contract and, at the Contractor's expense, shall defend all claims, actions or proceedings against Canada charging or claiming that

the Work or any part thereof provided or furnished by the Contractor to Canada infringes any patent, industrial design, copyright trademark, trade secret or other proprietary right enforceable in Canada.

5. Notice in writing of a claim shall be given within a reasonable time after the facts, upon which such claim is based, became known.

SC03 INSURANCE TERMS

1) Insurance Contracts

- (a) The Contractor must, at the Contractor's expense, obtain and maintain insurance contracts in accordance with the requirements of the Certificate of Insurance. Coverage must be placed with an Insurer licensed to carry out business in Canada.
- (b) Compliance with the insurance requirements does not release the Contractor from or reduce its liability under the Contract. The Contractor is responsible for deciding if additional insurance coverage is necessary to fulfill its obligation under the Contract and to ensure compliance with any applicable law. Any additional insurance coverage is at the Contractor's expense, and for its own benefit and protection.

2) Period of Insurance

- (a) The policies required in the Certificate of Insurance must be in force from the date of contract award and be maintained throughout the duration of the Contract.
- (b) The Contractor must be responsible to provide and maintain coverage for Products/Completed Operations hazards on its Commercial General Liability insurance policy, for a period of six (6) years beyond the date of the Certificate of Substantial Performance.

3) Proof of Insurance

- (a) Before commencement of the Work, and no later than thirty (30) days after contract award, the Contractor must deposit with Canada a Certificate of Insurance on the form attached herein.
- (b) Upon request by Canada, the Contractor must provide originals or certified true copies of all contracts of insurance maintained by the Contractor pursuant to the Certificate of Insurance.

4) Insurance Proceeds

In the event of a claim, the Contractor must, without delay, do such things and execute such documents as are necessary to effect payment of the proceeds.

5) Deductible

The payment of monies up to the deductible amount made in satisfaction of a claim must be borne by the Contractor.

BID AND ACCEPTANCE FORM (BA)

BA01 IDENTIFICATION

EF944-211315 - Replacement of HVAC Controls of Buildings Nos. 001 and 002 - R.107062.001

BA02 LEGAL NAME AND ADDRESS OF BIDDER

Legal Name: _____

Operating Name (if any): _____

Address: _____

Telephone: _____ Fax: _____ PBN: _____

E-mail address: _____

Industrial Security Program Organisation Number (ISP ORG#) _____
(when required)

BA03 THE OFFER

The Bidder offers to Canada to perform and complete the Work for the above named project in accordance with the Bid Documents for the Total Bid Amount of

\$ _____ excluding Applicable Tax(es).
(amount in numbers)

BA04 BID VALIDITY PERIOD

The bid must not be withdrawn for a period of 60 days following the date of solicitation closing.

BA05 ACCEPTANCE AND CONTRACT

Upon acceptance of the Bidder's offer by Canada, a binding Contract will be formed between Canada and the Bidder. The documents forming the Contract will be the Contract Documents identified in "Contract Documents (CD)" section.

BA06 CONSTRUCTION TIME

The Contractor must perform and complete the Work within 32 weeks from the date of notification of acceptance of the offer.

BA07 BID SECURITY

The Bidder must enclose bid security with its bid in accordance with GI08 - Bid Security Requirements of R2710T - General Instructions - Construction Services - Bid Security Requirements.

BA08 SIGNATURE

Name and title of person authorized to sign on behalf of Bidder (Type or print)

Signature

Date

APPENDIX 2 - VOLUNTARY CERTIFICATION TO SUPPORT THE USE OF APPRENTICES

(page 1 of 2)

PUBLIC WORKS AND GOVERNMENT SERVICES CANADA APPRENTICE PROCUREMENT INITIATIVE

1. To encourage employers to participate in apprenticeship training, Bidders, bidding on construction and maintenance contracts by Public Works and Government Services Canada (PWGSC) are being asked to sign a voluntary certification, signaling their commitment to hire and train apprentices.
2. Canada is facing skills shortages across various sectors and regions, especially in the skilled trades. Equipping Canadians with skills and training is a shared responsibility. The Government of Canada made a commitment to support the use of apprentices in federal construction and maintenance contracts. Contractors have an important role in supporting apprentices through hiring and training and are encouraged to certify that they are providing opportunities to apprentices as part of doing business with the Government of Canada.
3. The Government of Canada is encouraging apprenticeships and careers in the skilled trades. In addition, the government offers a tax credit to employers to encourage them to hire apprentices. Information on this tax measure administered by the Canada Revenue Agency can be found at: www.cra-arc.gc.ca. Employers are also encouraged to find out what additional information and supports are available from their respective provincial or territorial jurisdiction.
4. Signed certifications on page 2 of 2 will be used to better understand contractor use of apprentices on Government of Canada maintenance and construction contracts and may inform future policy and program development.
5. The Contractor hereby certifies the following:

In order to help meet demand for skilled trades people, the Contractor agrees to use, and require its subcontractors to use, reasonable commercial efforts to hire and train registered apprentices, to strive to fully utilize allowable apprenticeship ratios * and to respect any hiring requirements prescribed by provincial or territorial statutes

The Contractor hereby consents to this information being collected and held by PWGSC, and Employment and Social Development Canada to support work to gather data on the hiring and training of apprentices in federal construction and maintenance contracts.

To support this initiative, a voluntary certification signaling the Contractor's commitment to hire and train apprentices is available at page 2 of 2.

If you accept fill out and sign page 2 of 2.

** The journey-person-apprentice ratio is defined as the number of qualified/certified journeypersons that an employer must employ in a designated trade or occupation in order to be eligible to register an apprentice as determined by provincial/territorial (P/T) legislation, regulation, policy directive or by law issued by the responsible authority or agency.*

Voluntary Certification

(To be filled out and returned with bid on a voluntary basis)

(page 2 of 2)

Note: The contractor will be asked to fill out a report every six months or at project completion as per sample "Voluntary Reports for Apprentices Employed during the Contract" provided at Annex C

Name: _____

Signature: _____

Company Name: _____

Company Legal Name: _____

Solicitation Number: _____

Number of company employees: _____

Number of apprentices planned to be working on this contract: _____

Trades of those apprentices:

ANNEX A - CERTIFICATE OF INSURANCE (Not required at solicitation closing)

CERTIFICATE OF INSURANCE

Page 1 of 2



Travaux publics et
Services gouvernementaux
Canada

Public Works and
Government Services
Canada

Description and Location of Work The project involves the Replacement of HVAC Controls of Buildings Nos. 001 and 002 Situated at : é au 3600 Casavant Boulevard West, St.Hyacinthe, QC, J2S 8E3.	Contract No. EF944-211315
	Project No. R.107062.001

Name of Insurer, Broker or Agent	Address (No., Street)	City	Province	Postal Code
Name of Insured (Contractor)	Address (No., Street)	City	Province	Postal Code
Additional Insured <i>Her Majesty the Queen in Right of Canada as represented by the Minister of Public Works and Government Services</i>				

Type of Insurance	Insurer Name and Policy Number	Inception Date D / M / Y	Expiry Date D / M / Y	Limits of Liability		
Commercial General Liability Umbrella/Excess Liability				Per Occurrence	Annual General Aggregate	Completed Operations Aggregate
				\$	\$	\$
				\$	\$	\$
Builder's Risk / Installation Floater				\$		
Pollution Liability				\$ <input type="checkbox"/> Per Incident <input type="checkbox"/> Per Occurrence		Aggregate \$

I certify that the above policies were issued by insurers in the course of their Insurance business in Canada, are currently in force and include the applicable insurance coverage's stated on page 2 of this Certificate of Insurance, including advance notice of cancellation / reduction in coverage.

<div></div> Name of person authorized to sign on behalf of Insurer(s) (Officer, Agent, Broker)	<div></div> Telephone number
<div></div> Signature	<div></div> Date D / M / Y

General

The insurance policies required on page 1 of the Certificate of Insurance must be in force and must include the insurance coverage listed under the corresponding type of insurance on this page.

The policies must insure the Contractor and must include Her Majesty the Queen in Right of Canada as represented by the Minister of Public Works and Government Services as an additional Insured.

The Policy shall be endorsed to provide the Owner with not less than 30 days' notice in writing in advance of any cancellation or change or amendment restricting coverage.

Without increasing the limit of liability, the policies must protect all insured parties to the full extent of coverage provided. Further, the policies must apply to each Insured in the same manner and to the same extent as if a separate policy had been issued to each.

Commercial General Liability

The insurance coverage provided must not be substantially less than that provided by the latest edition of IBC Form 2100.

The policy must either include or be endorsed to include coverage for the following exposures or hazards if the Work is subject thereto:

- (a) Blasting.
- (b) Pile driving and caisson work.
- (c) Underpinning.
- (d) Removal or weakening of support of any structure or land whether such support be natural or otherwise if the work is performed by the insured contractor.

The policy must have the following minimum limits:

- (a) **\$5,000,000** Each Occurrence Limit;
- (b) **\$10,000,000** General Aggregate Limit per policy year if the policy contains a General Aggregate; and
- (c) **\$5,000,000** Products/Completed Operations Aggregate Limit.

Umbrella or excess liability insurance may be used to achieve the required limits.

Builder's Risk / Installation Floater

The insurance coverage provided must not be less than that provided by the latest edition of IBC Forms 4042 and 4047.

The policy must permit use and occupancy of any of the projects, or any part thereof, where such use and occupancy is for the purposes for which a project is intended upon completion.

The policy may exclude or be endorsed to exclude coverage for loss or damage caused by asbestos, fungi or spores, cyber and terrorism.

The policy must have a limit that is **not less than the sum of the contract value** plus the declared value (if any) set forth in the contract documents of all material and equipment supplied by Canada at the site of the project to be incorporated into and form part of the finished Work. If the value of the Work is changed, the policy must be changed to reflect the revised contract value.

The policy must provide that the proceeds thereof are payable to Canada or as Canada may direct in accordance with GC10.2, "Insurance Proceeds" (<https://buyandsell.gc.ca/policy-and-guidelines/standard-acquisition-clauses-and-conditions-manual/5/R/R2900D/2>).

Contractors Pollution Liability

The policy must have a limit usual for a contract of this nature, but not less than **\$1,000,000** per incident or occurrence and in the aggregate.

ANNEX B - VOLUNTARY REPORT FOR APPRENTICES EMPLOYED DURING THE CONTRACT (Sample)

(This report is not required at bid deposit)

The Contractor should compile and maintain records on the number of apprentices and their trade that were hired to work on the contract.

The Contractor should provide this data in accordance with the format below. If no apprentices were hired during the contract period, the Contractor should still provide a "nil" report.

The data should be submitted to the Contracting Authority either six months after contract award or at the end of the contract, whichever comes first.

Number of apprentices hired	Trade

Solicitation No. - N° de l'invitation
EF944-211315
Client Ref. No. - N° de réf. du client
R.107062.001

Amd. No. - N° de la modif.
004
File No. - N° du dossier
MTC-0-43160

Buyer ID - Id de l'acheteur
MTC410
CCC No./N° CCC - FMS No./N° VME

ANNEX C - SECURITY REQUIREMENT CHECK LIST (SRCL)

**PUBLIC SERVICES AND
PROCUREMENT CANADA**

**St-Hyacinthe RDC
(Research and Development Center)**

**3600 Casavant Boulevard West,
St. Hyacinthe, Quebec, J2S 8E3**

**Replacement of HVAC Controls of Buildings
Nos. 001 and 002**

PSPC No.: R.107062.001

**ADDENDUM NO. 2
Mechanical**

Prepared for:

PSPC

Prepared by:

Alain Higgins, Eng. | Integrated Automation

January 7, 2021

O/Ref.: 157102757-300.001-GN-S-0002-03

Prepared by:



Alain Higgins, Eng.
Integrated Automation

END OF SECTION

PUBLIC SERVICES AND PROCUREMENT CANADA

**St-Hyacinthe RDC
(Research and Development Center)**

3600 Casavant Boulevard West,
St. Hyacinthe, Quebec, J2S 8E3

Replacement of HVAC Controls of Buildings Nos. 001 and 002

PSPC No.: R.107062.001

ADDENDUM No. 2

Mechanical

This addendum completes, modifies, or eliminates certain elements of the tender documents, which this addendum refers to. It is an integral part of the tender documents.

1. SPECIFICATIONS

The following Sections from the specifications are issued with the current addendum.

1.1.1 Section 01 35 29.06

- Section 01 35 29.06, item 1.13.1: This article is cancelled. Refer only to item 1.13.2.

1.1.2 Section 01 74 00

- Section 01 74 00, item 1.2: This section is not amended. Comply with this section. See addendum 1. Only the places where the contractor works are affected.

1.1.3 Section 01 79 00

- Section 01 79 00, item 1.1.5 and Appendix 4-Training:

"Electrical Training 2 hours; Fire Alarm Training 2 hours; ventilation training 4 hours; controls training 60 hours."

1.1.4 Section 01 91 13

- Section 01 91 13, items 2.17 and 2.28, and Appendix 4- Commissioning Plan, item 6.2.6:

"The bank of hours for seasonal adjustments is 50 hours."

1.1.5 Section 23 05 00

- Section 23 05 00: item 3.3 modified:

"Clean up dirt and debris from work inside and outside systems."

ADDENDUM No. 2

1.1.6 Section 25 30 01

- Section 25 30 01, item 2.3.5.4 modified:

"The controller must have a register actuator and terminals for sensors and input and output devices. Provide 5 pre-programmed controller/actuator sets as spare parts."

1.1.7 Section 25 30 02

- Section 25 30 02, item 2.9.1.2.3 modified:

"Immersion: Use existing wells if suitable for application. If not, use stainless steel wells."

1.1.8 Section 25 90 01

- Section 25 90 01, item 2.32.1.3 added:

"For boxes/diffusers, provide and install a multi-point flow sensor at the entrance of the box. Ensure that the existing flow sensor (velocitrol) does not influence the new flow sensor, otherwise remove it."

- Section 25 90 01, item 3.1.6 modified:

"For systems that have recently been installed (2018), ducts, wiring and control boxes can be retained, provided the Contractor meets project requirements including, among other things, system downtime constraints. Control valves, VFD's and flow measurement stations (SMD) are retained."

- Section 25 90 01, item 3.1.7 added:

"All motorized dampers are existing to be retained. Only actuators (mainly pneumatic) are to be replaced. When dampers dimensions are not visible on the drawings, use actuators providing a torque of 20 Nm (180 lb-inch) for each replaced actuator. The dampers of the generator set, in particular, are made up of several sections, as indicated on the drawings."

2. DRAWINGS

2.1 MECHANICAL

The following drawings are modified, but not issued with the current addendum:

2.1.1 Drawing M02/46

- The symbol "*" means: existing.

ADDENDUM No. 2

2.1.2 Drawing M11/46

- All boxes/diffusers will be shown in black instead of grey. These boxes are no different from the other boxes shown in black on the other drawings.

2.1.3 Drawing M18/46

- The rectangle with a "D" shown at the top right represents a shower flow detector and will be modified to conform to the legend.

2.1.4 Drawing M19/46

- The 4 boxes of the laboratory hoods are not visible on the drawing, but are located on the vertical duct above each laboratory hood, in the ceiling. So there are 12 venturi valves to modernize. A note has been added to the drawing.

2.1.5 Drawing M25/46

- The dotted framed sections are out of contract. The out-of-contract note has been added to the drawing.

2.1.6 Drawing M44/46

- The R25.5 faucet must be 4 inches, Cv 150.
- The general note at the bottom of the VFD table referring to the type of engine (ODP) is removed. See the specifications.
- A note is added for humidifier models. Generally speaking, the humidifiers are Armstrong-branded, 9X series. In Block E, however, humidifiers are equipped with a Barber-Colman electric valve, VB9273 style.