



**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:**

**Bid Receiving Box/Boîte de Réception des
Soumissions**
1st Floor/1^{ère} étage, Suite 1212
100-1045 Main Street
Moncton
New Brunswick
E1C 1H1
Bid Fax: (506) 851-6759

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Acquisitions NB/PEI (Moncton Office) – Bureau
d'acquisitions N.-B./Î.-P.-É. (Moncton)
1045 Main Street / 1045, rue Main
Moncton
New Bruns
E1C 1H1

Title - Sujet Electrical Upgrades-AAFC Benton, NB	
Solicitation No. - N° de l'invitation EC373-212009/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client EC373-212009	Date 2021-01-08
GETS Reference No. - N° de référence de SEAG PW-\$PWJ-004-5856	
File No. - N° de dossier PWJ-0-43111 (004)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Atlantic Standard Time AST on - le 2021-01-14 Heure Normale de l'Atlantique HNA	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Johnston (PWJ), Edward	Buyer Id - Id de l'acheteur pwj004
Telephone No. - N° de téléphone (506) 343-6382 ()	FAX No. - N° de FAX (506) 851-6759
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Solicitation Amendment No. one (1) is raised to include the following Addendum No. one (1). The following Addendum to the tender is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

QUESTIONS AND ANSWERS

Q1. On the single line diagram they show a 400A 1 Phase main service disconnect and then a meter cabinet and meter socket. I am thinking as per NB Power standards on a 400Amp single phase service that the meter socket has to be ahead of the disconnect. Would we need to install a JS4B self contained meter socket on the exterior of the building and come from that to the main service disconnect?

A1. Based on the NB Power metering standards, 120/240V services between 201 and 600A may be either installed indoors or outdoors on commercial buildings. (Refer to item 16.7, page 31 and 32 in the link below) and the preference/design intent is to install the meter indoors. For indoor applications, the CT cabinet and meter/test switch are to be installed on the load side (downstream) of the service entrance switch.

<https://www.nbpower.com/media/1635/d-html-en-about-operating-service-entrance.pdf>

SPECIFICATIONS

Section 26 32 13 – Power Generation Diesel

1. Delete item 1.3.2.11 “Remote annunciator”
2. Revise item 1.8.1 to: “Provide a zero deductible comprehensive warranty that expressly states the diesel engine generator...”
3. Add item 1.8.2 as follows: “All repairs/replacement costs for warranty items shall be covered by the warranty including but not limited to supply/delivery of material, labour, travel and accommodations.
4. Delete item 2.1.9 in its entirety.
5. Add items 2.3.3.1.5 to 2.3.3.1.8 as follows:
 - .5 Lube oil pressure.
 - .6 Coolant temperature.
 - .7 Coolant level.
 - .8 Running time meter.
6. Revise item 2.2.8 to: “torque matched or permanent magnet”
7. Revise item 2.2.9 to: “EEMAC class H insulation on windings.”
8. Add item 2.10.7 as follows: “Insulated top and sides with sound attenuation to Level 2 (63-78dBA at 7m from the generator set).”

DRAWINGS

Drawing E04 – SINGLE LINE DIAGRAMS

1. Revise note 4 to: “GENERATOR TO BE COMPLETE WITH PRE-WIRED LOADCENTRE TO FEED INTERNAL COMPONENTS SUCH AS BLOCK HEATER, BATTERY CHARGER ETC.”