

LEGEND

- | | | |
|---------------------------|----------------------------|-----------------------------|
| 1099 - JANITOR | 1121 - E.E.P. | 1143 - ELECTRICAL |
| 1100 - GYMNASIUM | 1121A - OFFICE | 1144 - TELEPHONE |
| 1101 - STORAGE | 1122 - CANTEEN | 1145 - JANITOR |
| 1103 - MECHANICAL | 1123 - PROGRAM OFFICE | 1146 - MECHANICAL |
| 1104 - COMMON | 1124 - ARTS & CRAFTS | 1148 - COR. MANAGER OFFICE. |
| 1105 - EQUIPMENT | 1125 - STORAGE | 1149 - PAROLE OFFICER |
| 1106 - ABORIGINAL OFFICE | 1126 - CORRIDOR | 1150 - PAROLE OFFICER |
| 1107 - GYM KITCHEN | 1127 - CORRIDOR | 1151 - FILE ROOM |
| 1108 - VESTIBULE | 1129 - CORRIDOR | 1152 - PAROLE OFFICE |
| 1109 - FITNESS CENTRE | 1130 - WASHROOM | 1153 - STAFF LOUNGE |
| 1110 - CORRIDOR | 1131 - JANITOR | 1154 - CORRIDOR |
| 1111 - VESTIBULE | 1132 - MECHANICAL | 1155 - FILE ROOM |
| 1112 - WASHROOM (FEMALE) | 1133 - GROUP ROOM | 1156 - MAIL ROOM |
| 1113 - LOCKERS | 1134 - STORAGE | 1157 - OPEN OFFICE |
| 1114 - SHOWERS | 1135 - OFFICE | 1158 - SMALL MEETING ROOM |
| 1115 - LOCKER ROOM (MALE) | 1136 - CORRIDOR | 1160 - PHOTOCOPIY ROOM |
| 1116 - WASHROOM (MALE) | 1137 - PRIMARY WORK OFFICE | 1160A - STORAGE |
| 1118 - SHOWER | 1138 - OFFICE | 1161 - CORRIDOR |
| 1120 - HAIR-DRESSER | 1139 - LIBRARY | 1161A - DATA |
| | 1140 - CLASSROOM | 1162 - INT. |
| | 1142 - WASHROOM | 1163 - COR. MANAGER OFFICE |

GENERAL NOTES:

EXISTING SIEMENS FIRE ALARM SYSTEM IS TO BE REPLACED WITH NEW GENERATION ADDRESSABLE FIRE ALARM SYSTEM.


EXISTING INITIATING AND SIGNAL CIRCUIT WIRING IS TO BE MAINTAINED, UNLESS INDICATED OTHERWISE.

EXISTING SPRINKLER COMPONENTS ARE NOT TO BE MODIFIED, ONLY ADDRESSABLE MODULES ARE TO BE REPLACED UNLESS INDICATED OTHERWISE.

FIRE ALARM NOTES:

- ◇ EXISTING INITIATING CIRCUIT DEVICE TO BE REPLACED WITH NEW DEVICE.
- ◇ EXISTING BELL/STROBE SIGNAL CIRCUIT DEVICE TO BE REPLACED WITH NEW HORN/STROBE DEVICE.
- ◇ EXTEND EXISTING FIRE ALARM INITIATING CIRCUITRY TO NEW DEVICE.
- ◇ EXTEND EXISTING FIRE ALARM SIGNAL CIRCUITRY TO NEW DEVICE.
- ◇ RELOCATE EXISTING MANUAL PULL STATION SUCH THAT IT IS 1100mm ABOVE THE FINISHED FLOOR. REPAIR WALL AND REPAIR WALL FINISH TO MATCH EXISTING FINISH.
- ◇ REMOVE EXISTING MANUAL PULL STATION. REPAIR WALL AND REPAIR WALL FINISH TO MATCH EXISTING FINISH.

SCALE: 1:100



1	ISSUED FOR TENDER	10/27/2020
---	-------------------	------------

revisions	date
-----------	------

project **FIRE ALARM UPGRADE NOVA INSTITUTION** project

TRURO, NS

drawing **MAIN BUILDING GROUND FLOOR SOUTH SIDE FIRE ALARM PLAN** dessin

designed PM conçu

date MARCH 2020

drawn BD dessiné

date MARCH 2020

approved RGR approuvé

date MARCH 2020

Tender Soumission

PWSC Project Manager / Administrateur de projets TPSGC

project number / no. du projet

R.089585.001

drawing no. / no. du dessin

E-3