



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving PWGSC/TPSGC reception des
soumissions

Victory Building/Édifice Victory

Room 310/pièce 310

269 Main Street/269 rue Main

Winnipeg

Manitoba

R3C 1B3

Bid Fax: (204) 983-0338

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Public Works and Government Services Canada -
Western Region

Victory Building/Édifice Victory

Room 310/pièce 310

269 Main Street/269 rue Main

Winnipeg

Manitoba

R3C 1B3

Title - Sujet AAFC Feed Mill Building Upgrades	
Solicitation No. - N° de l'invitation EP922-211766/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client EP922-211766	Date 2021-01-15
GETS Reference No. - N° de référence de SEAG PW-\$PWZ-102-11135	
File No. - N° de dossier PWZ-0-43161 (102)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Central Standard Time CST on - le 2021-01-19 Heure Normale du Centre HNC	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Wiebe, Dallas	Buyer Id - Id de l'acheteur pwz102
Telephone No. - N° de téléphone (204) 899-5257 ()	FAX No. - N° de FAX (204) 983-7796
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

NOTICE TO TENDERERS

Amendment 003 to Solicitation No. EP922-211766/A is being issued for the following:

- 1) See Addendum No. 2.**

If your bid has already been forwarded and you wish to revise the same, this revision should reach the Bid Receiving Unit identified before the closing date. The bid number and closing date are to be clearly identified.

END OF AMENDMENT 003

Part 1 General

1.1 ADDENDUM FORM

- .1 This Addendum forms part of the Contract Documents and modifies the Bidding Documents dated November 26, 2020, with amendments and additions noted below.
- .2 Acknowledge receipt of this Addendum in the space provided in the Bid Form. Failure to do so may disqualify the Bidder at the Owner's discretion.
- .3 This addendum consists of one (1) page plus the following:

No.	Title	Issue Date
01	MPE Addendum M-02	Jan 14 2021

1.2 MECHANICAL CLARIFICATIONS AND REVISIONS

- .1 Refer to attached Addendum from MPE (M-02).

END OF ADDENDUM NUMBER NO. 2

ADDENDUM 2

To The Contract Specifications and Drawings For
1648-001-00 AAFC LeRDC – Feed Mill (116) Building Upgrades

MPE Engineering Ltd.
300, 714 – 5th Avenue South
Lethbridge, Alberta T1J 0V1

Date: January 14th, 2020

File: 1648-001-00

1. Precedence

This Addendum forms an integral part of the Contract Specifications and Drawings covering all aspects of this job and is to be read in conjunction therewith. However, should points arise which are at variance, this Addendum shall take precedence, unless otherwise clarified by the Engineer.

2. Purpose

This addendum provides specific clauses to add to and/or amend the specifications and/or drawings.

3. Specification 211310 – Fire Pump System:

.1 ADD: Item 2.2.6 as noted below:

.1 Fire pump is to be a vertical in-line type.

4. Drawing M5.1:

.1 CLARIFICATION: FP-1 Power:

.1 The existing fire pump is a 7.5 hp pump, and based on our calculations, the replacement pump should also be a 7.5 hp pump. While this will need to be reviewed during construction, the pump supplied for tender bids should be 7.5 hp based on this specification.

5. Specification 262816 –Molded Case Circuit Breakers

.1 CLARIFICATION: Item 2.1.1

.1 The Make and Model Number of Panel C is Federal Pioneer – NBLP-42-4L. The Splitter is a generic splitter.

6. Specification 260631 –Diesel Electric Generating Units

.1 CLARIFICATION: Item 2.8.4

- .1 The fuel tank shall be sized for a **Minimum** 8 hour operation. A larger tank is acceptable provided it is not greater than 24 hours (+/- 5%).

END OF ADDENDUM