



ADDENDUM # 4

Solicitation Number: 20-1207

Title: Conference Room Renovations-Building 59, CEF, Ottawa

Date: January 25th, 2021

The following supplements and/or supersedes the Invitation to Tender documents issued on January 5th, 2021. This addendum forms part of the contract documents and is to be read, interpreted, and coordinated with all other parts. Any change to the cost of the work as a result of this addendum is to be included in the price proposal. The following revisions supersede the information contained in the original Invitation to Tender Package for the above-mentioned project to the extent referenced and shall become part thereof.

QUESTIONS AND ANSWERS (Q & A)

Q 1. Is the Data Cabling by others ?

A 1. Cabling by Owner

Q 2. Drawing E200, New Layout – Note 10, How many Data Cables are there ? (Is this the Main Data Cabinet for all the floor ?)


A 2. Attached is a photo of the mentioned junction box with cover removed.

Q 3. Drawing E200, New Layout – Note 9, is this the J Box for the cables that run to the Floor box under the Table ?

A 3. Junction box to be located behind removable soffit panel to facilitate pulling because there are several 90 degree turns. Refer to Architectural elevations and sections for details. See sketch below.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.

End of Addendum #4



2 PROPOSED REFLECTED CEILING PLAN
A-103 Scale: 1:50

