



**RETURN BIDS TO:
RETOURNER LES SUBMISSION À :**

Parks Canada Agency Bid Receiving Unit
National Contracting Services

Bid Fax: 1-866-246-6893

Bid Email: soumissionsouest-bidswest@canada.ca

This is the only acceptable email address for responses to bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address may not be accepted.

The maximum email file size is 15 megabytes. Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

**REVISION 005 TO A
INVITATION TO TENDER**

**RÉVISION 005 INVITATION À
SOUMISSIONNER
DEMANDE D'OFFRES À
COMMANDES**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the offer remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'offre demeurent les mêmes.

Issuing Office - Bureau de distribution :
Parks Canada Agency
Calgary, AB

Title - Sujet : Lake Louise Pipestone Waterline Crossing – Banff National Park	
Solicitation No. - N° de l'invitation : 5P420-20-0346/A	Date : January 27, 2021
Amendment No. - N° de modification : 005	
Client Reference No. - N° de référence du client : 914	
GETS Reference No. N° de référence de SEAG : PW-20-00938896	

Solicitation Closes - L'invitation prend fin : At - à : 2:00 PM On - le : January 29, 2021	Time Zone - Fuseau horaire MST
-----------------------------------------------------------------------------------------------------------------------	------------------------------------------

F.O.B. - F.A.B. : Plant - Usine : <input type="checkbox"/> Destination : <input checked="" type="checkbox"/> Other - Autre : <input type="checkbox"/>		
Address Enquiries to - Adresser toutes demande de renseignements à : Jen Maheu		
Telephone No. - N° de telephone : (587) 432-8458	Fax No. -N° de télécopieur : (866) 246-6893	Email Address – Courriel : jennifer.maheu@canada.ca
Destination of Goods, Services, and Construction - Destination des biens, services, et construction : See Herein		

TO BE COMPLETED BY THE BIDDER - À REMPLIR PAR LE SOUMISSIONNAIRE

Vendor/ Firm Name - Nom du fournisseur/ de l'entrepreneur :	
Address - Adresse :	
Telephone No. - N° de telephone :	Fax No. - N° de télécopieur :
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Signature :	Date :

Solicitation No. - N° de l'invitation :
5P420-20-0346/A

Amd. No. - N° de la modif. :
005

Contracting Authority - Autorité contractante :
Jen Maheu

Client Ref. No. - N° de réf. du client :
914

Title – Titre :
Lake Louise Pipestone Waterline Crossing – Banff National Park

Amendment 005

This amendment is raised to distribute the answers to bidder questions.

A. QUESTIONS & ANSWERS

Q45 Does/will Parks Canada have a laydown area available for use by the contractor for staging the contractor's materials/equipment/site trailers etc.

A45 Refer to Q31 from Solicitation Amendment 04

Q46 Does Parks Canada have a dumpsite, other than the Regional District, available for clean fill?

A46 Refer to Q30 from Solicitation Amendment 04 - Clean fill can be hauled and disposed of at Pit 69.

Q47 The standard references applied (26 05 00) and (26 05 31) do not specify what is required to quote. Tier rating? Weight rating for enclosure and cover.

A47 Refer to Q25 from Solicitation Amendment 03

Q48 Dimensions required;

A48 Refer to Q25 from Solicitation Amendment 03

Q49 Open or solid bottom;

A49 Refer to Q25 from Solicitation Amendment 03 – Open bottom.

Q50 Heat Trace system along with alarm signals, seems to be supplied by URECON and installed by Division 26;

A50 Refer to Q44 from Solicitation Amendment 04

Q51 I need to know what type of panel the breaker is going into. Looks like it's an 800A CDP so more than likely this is a moulded case breaker. Do you have pictures of the existing CDP?

A51 Refer to Q10 from Solicitation Amendment 03

Q52 Could you also advise the KA rating of the breaker needed? I can't make it out on the provided picture.

A52 22 KA (Kilo Amp Interrupting Capacity)

Q53 In reference to the 600mm casing pipe, the watermain details on drawing C105 states the material is to be Stainless Steel. In contradiction to that, specification 33 11 16.21 "Casing Pipe" states the material should be "smooth wall carbon steel pipe." Please provide clarification as to what material is required for the casing pipe.

A53 600mm casing pipe to be carbon steel as listed in the Specifications.

Q54 Amendment 3 Q18 states casing pipe to meet AT spec for coatings. Can you be a bit more specific please. Are any coatings required for the casing pipe? Or where can we find this information?

A54 A coating is required as the intent is to provide corrosion resistance. Coating to be composed of an organic zinc primer, epoxy mid-coat, and a polyurethane top-coat. Products to be selected from AT's Approved Product list for Bridge Coating Systems - Paint and approved by the Departmental Representative. All work shall comply with PCA's BMPs for Roadway, Highway, Parkway and Related Infrastructure for bridge and structure painting to be supplied upon award.

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED