



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Fort Nelson 12 Residences Building Amélioration de l'enveloppe du bâtiment de 12 résidences à Fort Nelson	
Solicitation No. - N° de l'invitation EZ899-211939/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client	Date 2021-01-28
GETS Reference No. - N° de référence de SEAG PW-\$PWY-031-8909	
File No. - N° de dossier PWY-0-43172 (031)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Pacific Standard Time PST on - le 2021-02-11 Heure Normale du Pacifique HNP	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Leung, Janie	Buyer Id - Id de l'acheteur pwy031
Telephone No. - N° de téléphone (778) 919-3273 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: RCMP – Fort Nelson, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Les documents français seront disponibles sur demande.

This Amendment 001 is raised to address questions and to issue Addendum No. 1.

Questions and Answers

Q1. Should all windows/doors be replaced as per window and door schedule or just the windows marked on pictures of each house?

A1. All exterior doors (D1, D2 and D3) and all windows to be replaced per sheet A0-0.1 (Window and door schedules).

Q2. Section 01 11 55 1.2.5 indicates hours of work 8:00 am to 5:00 pm Monday to Friday. Please confirm if work can be completed 7 days a week as crews will be coming from out of town.

A2. The construction may take place between 8am-5pm Monday to Sunday. See Addendum No. 1.

Q3. What is the anticipated award date, and can the work begin right after the award?

A3. The anticipated award date is 2 weeks after the solicitation closes. Contractors can start mobilizing and construction soon after the contract is awarded (pending the submission of the Contract security, insurance certificate, and health and safety plan).

Q4. The specification calls the Hardie Panel up as 5/16" Artisan Lap. Artisan Lap only comes in 5/8" thick, which is the most expensive Hardie Profile. Standard Hardie lap siding is 5/16" available in smooth or cedarmill. Please confirm thickness and profile.

A4. See Addendum No. 1.

All other terms and conditions remain unchanged.

ADDENDUM NO. 1

**Fort Nelson 12 Residences
Building Envelope Upgrade**

Project No: R.109055.001

CHERNOFF THOMPSON ARCHITECTS

January 28, 2021

Total 3 pages
including this page

ADDENDUM #1

Date: Jan. 28, 2021

Fort Nelson 12 Residences
Building Envelope Upgrade
Project No: R.109055.001

The following revisions supersede the information contained in the original drawings and specification issued for the above named project, and shall become part thereof. No consideration will be allowed for extras due to the contractor or any subcontractor not being familiar with this Addendum.

1.0 ARCHITECTURAL SPECIFICATIONS

1.1 Specification Section 01 11 55 General Instructions

Delete:

1.5 HOURS OF WORK

.1 The hours of work are restricted to between 8am to 5pm, Monday to Friday throughout the contract period. Approval is required for weekend/holiday work schedule.

Add:

1.5 HOURS OF WORK

.1 The hours of work are restricted to between 8am to 5pm, Monday to **Sunday** throughout the contract period. **Approval is required for statutory holiday work schedule.**

1.1 Specification Section 07 46 46 Fiber Cement Siding System

Delete:

2.1 MATERIALS

.1 Fiber Cement Siding:

- .1 Basis of Design: Artisan Collection by James Hardie
- .2 Fiber Cement Siding.
- .3 Meet ASTM C1186, Type A, Grade II.
- .4 Formulated from Portland cement, ground sand, cellulose fibers, additives, and water; formed under pressure to required profile.
- .5 Type: Artisan lap and matching artisan trim, factory painted.
- .6 Thickness: 5/16 inch (7.5 mm).
- .7 Surface texture: Smooth.
- .8 Fire hazard classification: Maximum flame spread/smoke developed rating of 0/5, tested to ASTM E84.
- .9 Combustibility; Noncombustible, tested to ASTM E136.
- .10 Finish: ColorPlus factory-applied, baked on finish,
 - .1 Color 1: Night Gray
 - .2 Color 2: Deep Ocean
- .11 Departmental Representative will consider products which meet or exceed the properties of specified product that is used as the basis of design, and are similar in material, construction, thickness, color, texture, and overall quality, provided that proposed products are submitted to Departmental Representative completed

with samples and data sheets that Departmental Representative may require to evaluate the proposed product.

Add:

2.1 MATERIALS

- .1 Fiber Cement Siding:
 - .1 Fiber Cement Siding.
 - .2 Meet ASTM C1186, Type A, Grade II.
 - .3 Formulated from Portland cement, ground sand, cellulose fibers, additives, and water; formed under pressure to required profile.
 - .4 Type: **Lap siding and matching trim**, factory painted.
 - .5 **Width: 5.25" (133mm) with 4" (102mm) exposed**
 - .6 Thickness: **5/8 inch (15.9mm)**.
 - .7 Surface texture: Smooth.
 - .8 Fire hazard classification: Maximum flame spread/smoke developed rating of 0/5, tested to ASTM E84.
 - .9 Combustibility; Noncombustible, tested to ASTM E136.
 - .10 Finish: ColorPlus factory-applied, baked on finish,
 - .1 Color 1: Night Gray
 - .2 Color 2: Deep Ocean
 - .11 Departmental Representative will consider products which will meet or exceed this **performance specification**, and are similar in material, construction, thickness, color, texture, and overall quality.

END OF ADDENDUM #1