



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Roofing Remediation, Stage 1	
Solicitation No. - N° de l'invitation F1737-200109/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client F1737-200109	Date 2021-02-02
GETS Reference No. - N° de référence de SEAG PW-\$PWY-036-8904	
File No. - N° de dossier PWY-0-43166 (036)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Pacific Standard Time PST on - le 2021-02-09 Heure Normale du Pacifique HNP	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Martin (PWY), Delia	Buyer Id - Id de l'acheteur pwy036
Telephone No. - N° de téléphone (778) 707-2139 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO – Pacific Geoscience Centre – Institute of Ocean Science – Sidney, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Les documents français seront disponibles sur demande.

This Amendment 003 is raised to:

- 1: Extend the bid closing date and time
- 2: Issue an Addendum

- 1: The solicitation's bid closing date and time has been changed as follows:

Extension of Time for Tenderers

Roofing Remediation, Stage 1
Pacific Geoscience Centre – Institute of Ocean Science – Sidney, BC

Solicitation No: F1737-200109/A

Notice is hereby given that the time for reception of tenders previously due at 2:00 p.m. P.S.T. on February 04, 2021 is hereby extended to 2:00 p.m. P.S.T. on February 09, 2021.

- 2: Please see Addendum No. 03 attached.
The addendum will form part of the contract documents.

All other terms and conditions remain unchanged.

The following changes in the tender documents are effective immediately. This Addendum will form part of the contract documents.

Q1. The drawings indicate that roof Area 01 is Inverted Roof Membrane Assembly. Which assembly is it?

A1. 2-Ply SBS Membrane Assembly

Q2. The specs_updated.pdf seems to have been duplicated starting at page 118. Are there any differences?

A2. No, it's a duplication

----End of Addendum----